

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 10/2/2024 11:32:33 AM

JOB DESCRIPTION

RED-HILL

JOB NUMBER

380-112520-1

Eurofins Eaton Analytical Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.
(DW,Water matrices)

Authorization



Generated
10/2/2024 11:32:33 AM

Authorized for release by
Rachelle Arada, Project Manager
Rachelle.Arada@et.eurofinsus.com
(626)386-1106

Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	12
Surrogate Summary	13
QC Sample Results	15
QC Association Summary	28
Lab Chronicle	30
Certification Summary	31
Method Summary	33
Sample Summary	34
Chain of Custody	35
Receipt Checklists	38
	15
	16

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Qualifiers

GC/MS Semi VOA

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

GC Semi VOA

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
S1+	Surrogate recovery exceeds control limits, high biased.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-112520-1

Job ID: 380-112520-1

Eurofins Eaton Analytical Pomona

Job Narrative 380-112520-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 9/11/2024 10:09 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.2°C.

GC/MS Semi VOA

Method 625.1_SIM: The laboratory control sample (LCS) and laboratory control sample (LCSD) for preparation batch 570-480477 and analytical batch 570-482655 recovered outside control limits for the following analytes: 1-Methylnaphthalene, Acenaphthene, Fluorene, Phenanthrene and Pyrene. The LCS/LCSD was re-prep/re-ran on a different instrument. The LCS/LCSD still failed low. HT has expired therefore, no re-extraction. Data excluded due to this QC failure.

Method 625.1_SIM: The RPD of the laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) for preparation batch 570-480477 and analytical batch 570-482655 recovered outside control limits for the following analytes: 1-Methylnaphthalene and 2-Methylnaphthalene. Data excluded due to this QC failure.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Gasoline Range Organics

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Diesel Range Organics

Method 8015B_DRO_LL_CS: Surrogate recovery for the following sample was outside the upper control limit: Ka'amilo Wells (380-112520-1). This sample did not contain any target analytes; therefore, re-extraction and/or re-analysis was not performed.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Client Sample ID: Ka'amilo Wells

Lab Sample ID: 380-112520-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Dieldrin	0.046		0.0097	ug/L	1		525.2	Total/NA

Client Sample ID: TB: Ka'amilo Wells

Lab Sample ID: 380-112520-2

No Detections.

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Lab Sample ID: 380-112520-3

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Dieldrin	0.037		0.0097	ug/L	1		525.2	Total/NA
Heptachlor epoxide (isomer B)	0.014		0.0097	ug/L	1		525.2	Total/NA

Client Sample ID: TB: HALAWA WELLS UNITS 1 & 2

Lab Sample ID: 380-112520-4

No Detections.

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Client Sample ID: Ka'amilo Wells
Date Collected: 09/09/24 11:28
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-1
Matrix: Water

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
2,4'-DDD	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
2,4'-DDE	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
2,4'-DDT	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
2,4-Dinitrotoluene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
2,6-Dinitrotoluene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
2-Methylnaphthalene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
4,4'-DDD	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
4,4'-DDE	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
4,4'-DDT	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Acenaphthene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Acenaphthylene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Acetochlor	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Alachlor	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
alpha-BHC	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
alpha-Chlordane	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Anthracene	<0.019		0.019	ug/L	09/12/24 12:00	09/13/24 13:34		1
Atrazine	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Benz(a)anthracene	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Benzo[a]pyrene	<0.019		0.019	ug/L	09/12/24 12:00	09/13/24 13:34		1
Benzo[b]fluoranthene	<0.019		0.019	ug/L	09/12/24 12:00	09/13/24 13:34		1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Benzo[k]fluoranthene	<0.019		0.019	ug/L	09/12/24 12:00	09/13/24 13:34		1
beta-BHC	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Bis(2-ethylhexyl) phthalate	<0.58		0.58	ug/L	09/12/24 12:00	09/13/24 13:34		1
Bromacil	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Butachlor	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Butylbenzylphthalate	<0.49		0.49	ug/L	09/12/24 12:00	09/13/24 13:34		1
Chlorobenzilate	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Chloroneb	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Chlorothalonil (Draconil, Bravo)	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Chlorpyrifos	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Chrysene	<0.019		0.019	ug/L	09/12/24 12:00	09/13/24 13:34		1
delta-BHC	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Di(2-ethylhexyl)adipate	<0.58		0.58	ug/L	09/12/24 12:00	09/13/24 13:34		1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Diclorvos (DDVP)	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Dieldrin	0.046		0.0097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Diethylphthalate	<0.49		0.49	ug/L	09/12/24 12:00	09/13/24 13:34		1
Dimethylphthalate	<0.49		0.49	ug/L	09/12/24 12:00	09/13/24 13:34		1
Di-n-butyl phthalate	<0.97		0.97	ug/L	09/12/24 12:00	09/13/24 13:34		1
Di-n-octyl phthalate	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Endosulfan I (Alpha)	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Endosulfan II (Beta)	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Endosulfan sulfate	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Endrin	<0.0097		0.0097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Endrin aldehyde	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
EPTC	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Fluoranthene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Client Sample ID: Ka'amilo Wells

Lab Sample ID: 380-112520-1

Matrix: Water

Date Collected: 09/09/24 11:28
Date Received: 09/11/24 10:09

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluorene	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
gamma-Chlordane	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Heptachlor	<0.0097		0.0097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Heptachlor epoxide (isomer B)	<0.0097		0.0097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Hexachlorobenzene	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Isophorone	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Lindane	<0.0097		0.0097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Malathion	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Methoxychlor	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Metolachlor	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Molinate	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Naphthalene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Parathion	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Pendimethalin (Penoxaline)	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Phenanthrene	<0.039		0.039	ug/L	09/12/24 12:00	09/13/24 13:34		1
Propachlor	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Pyrene	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Simazine	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Terbacil	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Terbutylazine	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Thiobencarb	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1
Total Permethrin (mixed isomers)	<0.19		0.19	ug/L	09/12/24 12:00	09/13/24 13:34		1
trans-Nonachlor	<0.049		0.049	ug/L	09/12/24 12:00	09/13/24 13:34		1
Trifluralin	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:34		1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	09/12/24 12:00	09/13/24 13:34	1
Surrogate									
%Recovery									
2-Nitro-m-xylene									
96									
70 - 130									
Perylene-d12									
88									
70 - 130									
Triphenylphosphate									
90									
70 - 130									
Prepared									
09/12/24 12:00									
Analyzed									
09/13/24 13:34									
Dil Fac									
1									

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac	
GRO (C6-C10)	<10		10	ug/L			09/18/24 02:42	1	
Surrogate									
%Recovery									
4-Bromofluorobenzene (Surr)									
86									
Prepared									
09/18/24 02:42									
Analyzed									
09/18/24 02:42									
Dil Fac									
1									

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac	
Diesel Range Organics (C10-C24)	<26		26	ug/L	09/16/24 17:02	09/23/24 04:01		1	
Motor Oil Range Organics [C24-C36]	<26		26	ug/L	09/16/24 17:02	09/23/24 04:01		1	
C8-C18	<26		26	ug/L	09/16/24 17:02	09/23/24 04:01		1	
Surrogate									
%Recovery									
n-Octacosane (Surr)									
131									
S1+									
Limits									
60 - 130									
Prepared									
09/16/24 17:02									
Analyzed									
09/23/24 04:01									
Dil Fac									
1									

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Client Sample ID: TB: Ka'amilo Wells

Date Collected: 09/09/24 11:28
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-2

Matrix: Water

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			09/18/24 01:09	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	84		38 - 134				09/18/24 01:09	1

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Date Collected: 09/09/24 10:06
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-3

Matrix: Drinking Water

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
2,4'-DDD	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
2,4'-DDE	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
2,4'-DDT	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
2,4-Dinitrotoluene	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
2,6-Dinitrotoluene	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
2-Methylnaphthalene	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
4,4'-DDD	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
4,4'-DDE	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
4,4'-DDT	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Acenaphthene	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Acenaphthylene	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Acetochlor	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Aalachlor	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
alpha-BHC	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
alpha-Chlordane	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
Anthracene	<0.019		0.019	ug/L			09/12/24 12:00	09/13/24 13:54
Atrazine	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
Benz(a)anthracene	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
Benzo[a]pyrene	<0.019		0.019	ug/L			09/12/24 12:00	09/13/24 13:54
Benzo[b]fluoranthene	<0.019		0.019	ug/L			09/12/24 12:00	09/13/24 13:54
Benzo[g,h,i]perylene	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
Benzo[k]fluoranthene	<0.019		0.019	ug/L			09/12/24 12:00	09/13/24 13:54
beta-BHC	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Bis(2-ethylhexyl) phthalate	<0.58		0.58	ug/L			09/12/24 12:00	09/13/24 13:54
Bromacil	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Butachlor	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
Butylbenzylphthalate	<0.48		0.48	ug/L			09/12/24 12:00	09/13/24 13:54
Chlorobenzilate	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Chloroneb	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Chlorothalonil (Draconil, Bravo)	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Chlorpyrifos	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
Chrysene	<0.019		0.019	ug/L			09/12/24 12:00	09/13/24 13:54
delta-BHC	<0.097		0.097	ug/L			09/12/24 12:00	09/13/24 13:54
Di(2-ethylhexyl)adipate	<0.58		0.58	ug/L			09/12/24 12:00	09/13/24 13:54
Dibenz(a,h)anthracene	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
Diclorvos (DDVP)	<0.048		0.048	ug/L			09/12/24 12:00	09/13/24 13:54
Dieldrin	0.037		0.0097	ug/L			09/12/24 12:00	09/13/24 13:54
Diethylphthalate	<0.48		0.48	ug/L			09/12/24 12:00	09/13/24 13:54

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Lab Sample ID: 380-112520-3

Matrix: Drinking Water

Date Collected: 09/09/24 10:06

Date Received: 09/11/24 10:09

Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Dimethylphthalate	<0.48		0.48	ug/L	09/12/24 12:00	09/13/24 13:54		1
Di-n-butyl phthalate	<0.97		0.97	ug/L	09/12/24 12:00	09/13/24 13:54		1
Di-n-octyl phthalate	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Endosulfan I (Alpha)	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Endosulfan II (Beta)	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Endosulfan sulfate	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Endrin	<0.0097		0.0097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Endrin aldehyde	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
EPTC	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Fluoranthene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Fluorene	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
gamma-Chlordane	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Heptachlor	<0.0097		0.0097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Heptachlor epoxide (isomer B)	0.014		0.0097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Hexachlorobenzene	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Hexachlorocyclopentadiene	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Indeno[1,2,3-cd]pyrene	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Isophorone	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Lindane	<0.0097		0.0097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Malathion	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Methoxychlor	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Metolachlor	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Molinate	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Naphthalene	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Parathion	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Pendimethalin (Penoxaline)	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Phenanthrene	<0.039		0.039	ug/L	09/12/24 12:00	09/13/24 13:54		1
Propachlor	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Pyrene	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Simazine	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Terbacil	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Terbutylazine	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Thiobencarb	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1
Total Permethrin (mixed isomers)	<0.19		0.19	ug/L	09/12/24 12:00	09/13/24 13:54		1
trans-Nonachlor	<0.048		0.048	ug/L	09/12/24 12:00	09/13/24 13:54		1
Trifluralin	<0.097		0.097	ug/L	09/12/24 12:00	09/13/24 13:54		1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	09/12/24 12:00	09/13/24 13:54	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	94		70 - 130	09/12/24 12:00	09/13/24 13:54	1
Perylene-d12	89		70 - 130	09/12/24 12:00	09/13/24 13:54	1
Triphenylphosphate	90		70 - 130	09/12/24 12:00	09/13/24 13:54	1

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			09/20/24 14:32	1

Eurofins Eaton Analytical Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Date Collected: 09/09/24 10:06
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-3

Matrix: Drinking Water

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	85		38 - 134		09/20/24 14:32	1

Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26	ug/L	09/16/24 17:02	09/23/24 04:22		1
Motor Oil Range Organics [C24-C36]	<26		26	ug/L	09/16/24 17:02	09/23/24 04:22		1
C8-C18	<26		26	ug/L	09/16/24 17:02	09/23/24 04:22		1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	122		60 - 130	09/16/24 17:02	09/23/24 04:22	1

Client Sample ID: TB: HALAWA WELLS UNITS 1 & 2

Date Collected: 09/09/24 10:06
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-4

Matrix: Water

Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L		09/18/24 01:33		1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac

4-Bromofluorobenzene (Surr)	84		38 - 134		09/18/24 01:33	1
-----------------------------	----	--	----------	--	----------------	---

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Client Sample ID: Ka'amilo Wells

Lab Sample ID: 380-112520-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL		Prep Type	
				Limit	RL		
Alachlor	<0.049		ug/L	2	0.049	525.2	Total/NA
Atrazine	<0.049		ug/L	3	0.049	525.2	Total/NA
Benzo[a]pyrene	<0.019		ug/L	0.2	0.019	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.58		ug/L	6	0.58	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.58		ug/L	400	0.58	525.2	Total/NA
Endrin	<0.0097		ug/L	2	0.0097	525.2	Total/NA
Heptachlor	<0.0097		ug/L	0.4	0.0097	525.2	Total/NA
Heptachlor epoxide (isomer B)	<0.0097		ug/L	0.2	0.0097	525.2	Total/NA
Hexachlorobenzene	<0.049		ug/L	1	0.049	525.2	Total/NA
Hexachlorocyclopentadiene	<0.049		ug/L	50	0.049	525.2	Total/NA
Lindane	<0.0097		ug/L	0.2	0.0097	525.2	Total/NA
Methoxychlor	<0.049		ug/L	40	0.049	525.2	Total/NA
Simazine	<0.049		ug/L	4	0.049	525.2	Total/NA

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Lab Sample ID: 380-112520-3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL		Prep Type	
				Limit	RL		
Alachlor	<0.048		ug/L	2	0.048	525.2	Total/NA
Atrazine	<0.048		ug/L	3	0.048	525.2	Total/NA
Benzo[a]pyrene	<0.019		ug/L	0.2	0.019	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.58		ug/L	6	0.58	525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.58		ug/L	400	0.58	525.2	Total/NA
Endrin	<0.0097		ug/L	2	0.0097	525.2	Total/NA
Heptachlor	<0.0097		ug/L	0.4	0.0097	525.2	Total/NA
Heptachlor epoxide (isomer B)	0.014		ug/L	0.2	0.0097	525.2	Total/NA
Hexachlorobenzene	<0.048		ug/L	1	0.048	525.2	Total/NA
Hexachlorocyclopentadiene	<0.048		ug/L	50	0.048	525.2	Total/NA
Lindane	<0.0097		ug/L	0.2	0.0097	525.2	Total/NA
Methoxychlor	<0.048		ug/L	40	0.048	525.2	Total/NA
Simazine	<0.048		ug/L	4	0.048	525.2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-112520-3	HALAWA WELLS UNITS 1 & 2	94	89	90

Surrogate Legend

2NMX = 2-Nitro-m-xylene

PRY = Perylene-d12

TPP = Triphenylphosphate

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-112518-B-1-A MS	Matrix Spike	95	92	93
380-112518-B-2-A DU	Duplicate	95	88	89
380-112520-1	Ka'amilo Wells	96	88	90
LCS 380-108010/23-A	Lab Control Sample	94	88	93
MB 380-108010/21-A	Method Blank	94	82	88
MRL 380-108010/22-A	Lab Control Sample	96	81	90

Surrogate Legend

2NMX = 2-Nitro-m-xylene

PRY = Perylene-d12

TPP = Triphenylphosphate

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		BFB1 (38-134)		
380-112520-3	HALAWA WELLS UNITS 1 & 2	85		
380-112520-3 MS	HALAWA WELLS UNITS 1 & 2	88		
380-112520-3 MSD	HALAWA WELLS UNITS 1 & 2	92		

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		BFB1 (38-134)		
380-111916-C-3 MS	Matrix Spike	95		
380-111916-F-3 MSD	Matrix Spike Duplicate	95		
380-112520-1	Ka'amilo Wells	86		
380-112520-2	TB: Ka'amilo Wells	84		
380-112520-4	TB: HALAWA WELLS UNITS 1 & 2	84		
LCS 570-481747/1009	Lab Control Sample	96		
LCS 570-483045/4	Lab Control Sample	89		
LCSD 570-481747/10	Lab Control Sample Dup	94		

Eurofins Eaton Analytical Pomona

Surrogate Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

BFB1

Lab Sample ID	Client Sample ID	(38-134)
LCSD 570-483045/5	Lab Control Sample Dup	92
MB 570-481747/11	Method Blank	92
MB 570-483045/6	Method Blank	85
MRL 570-481747/1004	Lab Control Sample	89
MRL 570-483045/3	Lab Control Sample	86

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Drinking Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

OTCSN1

Lab Sample ID	Client Sample ID	(60-130)
380-112520-3	HALAWA WELLS UNITS 1 & 2	122
380-112520-3 MS	HALAWA WELLS UNITS 1 & 2	125
380-112520-3 MSD	HALAWA WELLS UNITS 1 & 2	122

Surrogate Legend

OTCSN = n-Octacosane (Surr)

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

OTCSN1

Lab Sample ID	Client Sample ID	(60-130)
380-112520-1	Ka'amilo Wells	131 S1+
LCS 570-481430/2-A	Lab Control Sample	125
LCSD 570-481430/3-A	Lab Control Sample Dup	130
MB 570-481430/1-A	Method Blank	119
MRL 570-481430/4-A	Lab Control Sample	124

Surrogate Legend

OTCSN = n-Octacosane (Surr)

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-108010/21-A

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 108010

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
2,4'-DDD	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
2,4'-DDE	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
2,4'-DDT	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
2,4-Dinitrotoluene	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
2,6-Dinitrotoluene	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
2-Methylnaphthalene	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
4,4'-DDD	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
4,4'-DDE	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
4,4'-DDT	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Acenaphthene	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Acenaphthylene	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Acetochlor	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Alachlor	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
alpha-BHC	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
alpha-Chlordane	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Anthracene	<0.020		0.020	ug/L	09/12/24 10:45	09/13/24 12:32		1
Atrazine	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Benz(a)anthracene	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Benzo[a]pyrene	<0.020		0.020	ug/L	09/12/24 10:45	09/13/24 12:32		1
Benzo[b]fluoranthene	<0.020		0.020	ug/L	09/12/24 10:45	09/13/24 12:32		1
Benzo[g,h,i]perylene	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Benzo[k]fluoranthene	<0.020		0.020	ug/L	09/12/24 10:45	09/13/24 12:32		1
beta-BHC	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Bis(2-ethylhexyl) phthalate	<0.60		0.60	ug/L	09/12/24 10:45	09/13/24 12:32		1
Bromacil	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Butachlor	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Butylbenzylphthalate	<0.50		0.50	ug/L	09/12/24 10:45	09/13/24 12:32		1
Chlorobenzilate	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Chloroneb	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Chlorothalonil (Draconil, Bravo)	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Chlorpyrifos	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Chrysene	<0.020		0.020	ug/L	09/12/24 10:45	09/13/24 12:32		1
delta-BHC	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Di(2-ethylhexyl)adipate	<0.60		0.60	ug/L	09/12/24 10:45	09/13/24 12:32		1
Dibenz(a,h)anthracene	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Diclorvos (DDVP)	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Dieldrin	<0.010		0.010	ug/L	09/12/24 10:45	09/13/24 12:32		1
Diethylphthalate	<0.50		0.50	ug/L	09/12/24 10:45	09/13/24 12:32		1
Dimethylphthalate	<0.50		0.50	ug/L	09/12/24 10:45	09/13/24 12:32		1
Di-n-butyl phthalate	<1.0		1.0	ug/L	09/12/24 10:45	09/13/24 12:32		1
Di-n-octyl phthalate	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Endosulfan I (Alpha)	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Endosulfan II (Beta)	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Endosulfan sulfate	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Endrin	<0.010		0.010	ug/L	09/12/24 10:45	09/13/24 12:32		1
Endrin aldehyde	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
EPTC	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 380-108010/21-A

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 108010

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoranthene	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Fluorene	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
gamma-Chlordane	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Heptachlor	<0.010		0.010	ug/L	09/12/24 10:45	09/13/24 12:32		1
Heptachlor epoxide (isomer B)	<0.010		0.010	ug/L	09/12/24 10:45	09/13/24 12:32		1
Hexachlorobenzene	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Hexachlorocyclopentadiene	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Indeno[1,2,3-cd]pyrene	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Isophorone	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Lindane	<0.010		0.010	ug/L	09/12/24 10:45	09/13/24 12:32		1
Malathion	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Methoxychlor	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Metolachlor	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Molinate	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Naphthalene	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Parathion	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Pendimethalin (Penoxaline)	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Phenanthrene	<0.040		0.040	ug/L	09/12/24 10:45	09/13/24 12:32		1
Propachlor	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Pyrene	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Simazine	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Terbacil	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Terbutylazine	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Thiobencarb	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L	09/12/24 10:45	09/13/24 12:32		1
trans-Nonachlor	<0.050		0.050	ug/L	09/12/24 10:45	09/13/24 12:32		1
Trifluralin	<0.10		0.10	ug/L	09/12/24 10:45	09/13/24 12:32		1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Unknown	0.532	T J	ug/L		2.80	N/A	09/12/24 10:45	09/13/24 12:32	1
Decane	1.27	T J N	ug/L		2.85	124-18-5	09/12/24 10:45	09/13/24 12:32	1
Cyclohexasiloxane, dodecamethyl-	0.799	T J N	ug/L		3.96	540-97-6	09/12/24 10:45	09/13/24 12:32	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	94		70 - 130	09/12/24 10:45	09/13/24 12:32	1
Perlylene-d12	82		70 - 130	09/12/24 10:45	09/13/24 12:32	1
Triphenylphosphate	88		70 - 130	09/12/24 10:45	09/13/24 12:32	1

Lab Sample ID: LCS 380-108010/23-A

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 108010

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
1-Methylnaphthalene	1.99	1.91		ug/L		96	70 - 130
2,4'-DDD	1.99	2.03		ug/L		102	70 - 130
2,4'-DDE	1.99	2.06		ug/L		104	70 - 130
2,4'-DDT	1.99	2.13		ug/L		107	70 - 130
2,4-Dinitrotoluene	1.99	1.84		ug/L		93	70 - 130

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-108010/23-A

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
2,6-Dinitrotoluene	1.99	1.82		ug/L	92	70 - 130	
2-Methylnaphthalene	1.99	1.89		ug/L	95	70 - 130	
4,4'-DDD	1.99	2.02		ug/L	102	70 - 130	
4,4'-DDE	1.99	1.95		ug/L	98	70 - 130	
4,4'-DDT	1.99	2.16		ug/L	109	70 - 130	
Acenaphthene	1.99	1.96		ug/L	99	70 - 130	
Acenaphthylene	1.99	1.85		ug/L	93	70 - 130	
Acetochlor	1.99	2.13		ug/L	107	70 - 130	
Alachlor	1.99	2.06		ug/L	104	70 - 130	
alpha-BHC	1.99	2.04		ug/L	102	70 - 130	
alpha-Chlordane	1.99	2.08		ug/L	105	70 - 130	
Anthracene	1.99	1.81		ug/L	91	70 - 130	
Atrazine	1.99	2.18		ug/L	110	70 - 130	
Benz(a)anthracene	1.99	1.72		ug/L	87	70 - 130	
Benzo[a]pyrene	1.99	1.80		ug/L	91	70 - 130	
Benzo[b]fluoranthene	1.99	1.90		ug/L	95	70 - 130	
Benzo[g,h,i]perylene	1.99	1.92		ug/L	96	70 - 130	
Benzo[k]fluoranthene	1.99	2.11		ug/L	106	70 - 130	
beta-BHC	1.99	2.14		ug/L	107	70 - 130	
Bis(2-ethylhexyl) phthalate	1.99	1.91		ug/L	96	70 - 130	
Bromacil	1.99	1.87		ug/L	94	70 - 130	
Butachlor	1.99	2.09		ug/L	105	70 - 130	
Butylbenzylphthalate	1.99	2.04		ug/L	103	70 - 130	
Chlorobenzilate	1.99	2.26		ug/L	114	70 - 130	
Chloroneb	1.99	2.26		ug/L	114	70 - 130	
Chlorothalonil (Draconil, Bravo)	1.99	2.03		ug/L	102	70 - 130	
Chlorpyrifos	1.99	2.28		ug/L	115	70 - 130	
Chrysene	1.99	2.19		ug/L	110	70 - 130	
delta-BHC	1.99	2.05		ug/L	103	70 - 130	
Di(2-ethylhexyl)adipate	1.99	1.89		ug/L	95	70 - 130	
Dibenz(a,h)anthracene	1.99	1.82		ug/L	91	70 - 130	
Diclorvos (DDVP)	1.99	1.85		ug/L	93	70 - 130	
Dieldrin	1.99	2.04		ug/L	103	70 - 130	
Diethylphthalate	1.99	2.00		ug/L	101	70 - 130	
Dimethylphthalate	1.99	1.96		ug/L	99	70 - 130	
Di-n-butyl phthalate	3.97	4.11		ug/L	103	70 - 130	
Di-n-octyl phthalate	1.99	1.82		ug/L	92	70 - 130	
Endosulfan I (Alpha)	1.99	1.92		ug/L	97	70 - 130	
Endosulfan II (Beta)	1.99	1.92		ug/L	97	70 - 130	
Endosulfan sulfate	1.99	2.03		ug/L	102	70 - 130	
Endrin	1.99	2.08		ug/L	105	70 - 130	
Endrin aldehyde	1.99	1.76		ug/L	88	60 - 130	
EPTC	1.99	1.99		ug/L	100	70 - 130	
Fluoranthene	1.99	2.07		ug/L	104	70 - 130	
Fluorene	1.99	1.99		ug/L	100	70 - 130	
gamma-Chlordane	1.99	2.13		ug/L	107	70 - 130	
Heptachlor	1.99	2.31		ug/L	116	70 - 130	
Heptachlor epoxide (isomer B)	1.99	1.96		ug/L	99	70 - 130	
Hexachlorobenzene	1.99	1.94		ug/L	98	70 - 130	

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 380-108010/23-A

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Hexachlorocyclopentadiene	1.99	1.95		ug/L	98	70 - 130	
Indeno[1,2,3-cd]pyrene	1.99	1.65		ug/L	83	70 - 130	
Isophorone	1.99	1.86		ug/L	94	70 - 130	
Lindane	1.99	1.96		ug/L	99	70 - 130	
Malathion	1.99	2.22		ug/L	112	70 - 130	
Methoxychlor	1.99	2.23		ug/L	112	70 - 130	
Metolachlor	1.99	2.03		ug/L	102	70 - 130	
Molinate	1.99	1.98		ug/L	100	70 - 130	
Naphthalene	1.99	1.99		ug/L	100	70 - 130	
Parathion	1.99	2.36		ug/L	119	70 - 130	
Pendimethalin (Penoxaline)	1.99	1.71		ug/L	86	70 - 130	
Phenanthrene	1.99	1.96		ug/L	99	70 - 130	
Propachlor	1.99	2.03		ug/L	102	70 - 130	
Pyrene	1.99	2.04		ug/L	103	70 - 130	
Simazine	1.99	1.93		ug/L	97	70 - 130	
Terbacil	1.99	2.17		ug/L	109	70 - 130	
Terbutylazine	1.99	2.13		ug/L	107	70 - 130	
Thiobencarb	1.99	2.04		ug/L	103	70 - 130	
trans-Nonachlor	1.99	2.00		ug/L	100	70 - 130	
Trifluralin	1.99	1.92		ug/L	96	70 - 130	

LCS LCS

Surrogate	%Recovery	Qualifier	Limits
2-Nitro-m-xylene	94		70 - 130
Perylene-d12	88		70 - 130
Triphenylphosphate	93		70 - 130

Lab Sample ID: MRL 380-108010/22-A

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
1-Methylnaphthalene	0.0992	0.106		ug/L	107	50 - 150	
2,4'-DDD	0.0992	0.0831	J	ug/L	84	50 - 150	
2,4'-DDE	0.0992	0.0956	J	ug/L	96	50 - 150	
2,4'-DDT	0.0992	0.0924	J	ug/L	93	50 - 150	
2,4-Dinitrotoluene	0.0992	0.0697	J	ug/L	70	50 - 150	
2,6-Dinitrotoluene	0.0992	0.0818	J	ug/L	82	50 - 150	
2-Methylnaphthalene	0.0992	0.0993		ug/L	100	50 - 150	
4,4'-DDD	0.0992	0.0911	J	ug/L	92	50 - 150	
4,4'-DDE	0.0992	0.0959	J	ug/L	97	50 - 150	
4,4'-DDT	0.0992	0.0843	J	ug/L	85	50 - 150	
Acenaphthene	0.0992	0.103		ug/L	103	50 - 150	
Acenaphthylene	0.0992	0.0851	J	ug/L	86	50 - 150	
Acetochlor	0.0992	0.110		ug/L	111	50 - 150	
Alachlor	0.0496	0.0492	J	ug/L	99	50 - 150	
alpha-BHC	0.0992	0.114		ug/L	115	50 - 150	
alpha-Chlordane	0.0248	<0.029		ug/L	100	50 - 150	
Anthracene	0.0198	0.0190	J	ug/L	96	50 - 150	

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-108010/22-A

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Atrazine	0.0496	<0.048		ug/L	85	50 - 150	
Benz(a)anthracene	0.0496	0.0449	J	ug/L	90	50 - 150	
Benzo[a]pyrene	0.0198	0.0138	J	ug/L	70	50 - 150	
Benzo[b]fluoranthene	0.0198	0.0150	J	ug/L	76	50 - 150	
Benzo[g,h,i]perylene	0.0496	0.0343	J	ug/L	69	50 - 150	
Benzo[k]fluoranthene	0.0198	<0.017		ug/L	85	50 - 150	
beta-BHC	0.0992	0.116		ug/L	117	50 - 150	
Bis(2-ethylhexyl) phthalate	0.595	0.457	J	ug/L	77	50 - 150	
Bromacil	0.0992	0.104		ug/L	105	50 - 150	
Butachlor	0.0496	0.0524		ug/L	106	50 - 150	
Butylbenzylphthalate	0.496	0.484	J	ug/L	98	50 - 150	
Chlorobenzilate	0.0992	0.0896	J	ug/L	90	50 - 150	
Chloroneb	0.0992	0.0722	J	ug/L	73	50 - 150	
Chlorothalonil (Draconil, Bravo)	0.0992	0.116		ug/L	117	50 - 150	
Chlorpyrifos	0.0496	0.0481	J	ug/L	97	50 - 150	
Chrysene	0.0198	0.0213		ug/L	107	50 - 150	
delta-BHC	0.0992	0.111		ug/L	112	50 - 150	
Di(2-ethylhexyl)adipate	0.595	0.511	J	ug/L	86	50 - 150	
Dibenz(a,h)anthracene	0.0496	<0.033		ug/L	62	50 - 150	
Diclorvos (DDVP)	0.0496	0.0473	J	ug/L	95	50 - 150	
Dieldrin	0.00992	0.0102		ug/L	102	50 - 150	
Diethylphthalate	0.496	0.494	J	ug/L	100	50 - 150	
Dimethylphthalate	0.496	0.499	J	ug/L	101	50 - 150	
Di-n-butyl phthalate	0.496	0.476	J	ug/L	96	49 - 243	
Di-n-octyl phthalate	0.0992	0.0670	J	ug/L	68	50 - 150	
Endosulfan I (Alpha)	0.0992	0.0931	J	ug/L	94	50 - 150	
Endosulfan II (Beta)	0.0992	0.104		ug/L	105	50 - 150	
Endosulfan sulfate	0.0992	0.0923	J	ug/L	93	50 - 150	
Endrin	0.00992	0.0121		ug/L	122	50 - 150	
Endrin aldehyde	0.0992	0.0958	J	ug/L	97	50 - 150	
EPTC	0.0992	0.0937	J	ug/L	94	50 - 150	
Fluoranthene	0.0992	0.0953	J	ug/L	96	50 - 150	
Fluorene	0.0496	<0.050		ug/L	98	50 - 150	
gamma-Chlordane	0.0248	0.0210	J	ug/L	85	50 - 150	
Heptachlor	0.00992	0.0133		ug/L	134	50 - 150	
Heptachlor epoxide (isomer B)	0.00992	0.0127		ug/L	128	50 - 150	
Hexachlorobenzene	0.0496	0.0491	J	ug/L	99	50 - 150	
Hexachlorocyclopentadiene	0.0496	0.0454	J	ug/L	92	50 - 150	
Indeno[1,2,3-cd]pyrene	0.0496	<0.027		ug/L	50	50 - 150	
Isophorone	0.0992	0.116		ug/L	117	50 - 150	
Lindane	0.00992	0.0148		ug/L	149	50 - 150	
Malathion	0.0992	0.0939	J	ug/L	95	50 - 150	
Methoxychlor	0.0496	0.0419	J	ug/L	84	50 - 150	
Metolachlor	0.0496	0.0543		ug/L	110	50 - 150	
Molinate	0.0992	0.103		ug/L	103	50 - 150	
Naphthalene	0.0992	0.108		ug/L	109	50 - 150	
Parathion	0.0992	0.0743	J	ug/L	75	50 - 150	
Pendimethalin (Penoxaline)	0.0992	0.0891	J	ug/L	90	50 - 150	
Phenanthrene	0.0397	0.0438		ug/L	110	50 - 150	

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MRL 380-108010/22-A

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Propachlor	0.0496	0.0508		ug/L		102	50 - 150
Pyrene	0.0496	0.0461	J	ug/L		93	50 - 150
Simazine	0.0496	0.0438	J	ug/L		88	50 - 150
Terbacil	0.0992	0.117		ug/L		118	50 - 150
Terbutylazine	0.0992	0.0856	J	ug/L		86	50 - 150
Thiobencarb	0.0992	0.0992		ug/L		100	50 - 150
trans-Nonachlor	0.0248	<0.026		ug/L		90	50 - 150
Trifluralin	0.0992	0.0675	J	ug/L		68	50 - 150

Surrogate	MRL	MRL	Limits
	%Recovery	Qualifier	
2-Nitro-m-xylene	96		70 - 130
Perylene-d12	81		70 - 130
Triphenylphosphate	90		70 - 130

Lab Sample ID: 380-112518-B-1-A MS

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
1-Methylnaphthalene	<0.098		1.95	1.87		ug/L		96	70 - 130
2,4'-DDD	<0.098		1.95	1.95		ug/L		100	70 - 130
2,4'-DDE	<0.098		1.95	1.92		ug/L		99	70 - 130
2,4'-DDT	<0.098		1.95	2.02		ug/L		104	70 - 130
2,4-Dinitrotoluene	<0.098		1.95	1.98		ug/L		102	70 - 130
2,6-Dinitrotoluene	<0.098		1.95	1.90		ug/L		98	70 - 130
2-Methylnaphthalene	<0.098		1.95	1.86		ug/L		95	70 - 130
4,4'-DDD	<0.098		1.95	1.90		ug/L		98	70 - 130
4,4'-DDE	<0.098		1.95	1.80		ug/L		93	70 - 130
4,4'-DDT	<0.098		1.95	2.02		ug/L		104	70 - 130
Acenaphthene	<0.098		1.95	1.92		ug/L		99	70 - 130
Acenaphthylene	<0.098		1.95	1.85		ug/L		95	70 - 130
Acetochlor	<0.098		1.95	2.00		ug/L		103	70 - 130
Alachlor	<0.049		1.95	1.98		ug/L		102	70 - 130
alpha-BHC	<0.098		1.95	1.95		ug/L		100	70 - 130
alpha-Chlordane	<0.049		1.95	1.99		ug/L		102	70 - 130
Anthracene	<0.020	F1	1.95	1.26	F1	ug/L		65	70 - 130
Atrazine	<0.049		1.95	2.08		ug/L		107	70 - 130
Benz(a)anthracene	<0.049		1.95	1.61		ug/L		83	70 - 130
Benzo[a]pyrene	<0.020		1.95	1.60		ug/L		82	70 - 130
Benzo[b]fluoranthene	<0.020		1.95	1.81		ug/L		93	70 - 130
Benzo[g,h,i]perylene	<0.049		1.95	1.86		ug/L		96	70 - 130
Benzo[k]fluoranthene	<0.020		1.95	2.02		ug/L		104	70 - 130
beta-BHC	<0.098		1.95	2.03		ug/L		105	70 - 130
Bis(2-ethylhexyl) phthalate	<0.59		1.95	1.63		ug/L		84	70 - 130
Bromacil	<0.098		1.95	2.00		ug/L		103	70 - 130
Butachlor	<0.049		1.95	2.01		ug/L		103	70 - 130
Butylbenzylphthalate	<0.49		1.95	1.95		ug/L		100	70 - 130
Chlorobenzilate	<0.098		1.95	2.20		ug/L		113	70 - 130

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-112518-B-1-A MS

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Chloroneb	<0.098		1.95	2.08		ug/L	107	70 - 130	
Chlorothalonil (Draconil, Bravo)	<0.098		1.95	1.96		ug/L	101	70 - 130	
Chlorpyrifos	<0.049		1.95	2.22		ug/L	114	70 - 130	
Chrysene	<0.020		1.95	2.09		ug/L	107	70 - 130	
delta-BHC	<0.098		1.95	1.94		ug/L	100	70 - 130	
Di(2-ethylhexyl)adipate	<0.59		1.95	1.70		ug/L	88	70 - 130	
Dibenz(a,h)anthracene	<0.049		1.95	1.76		ug/L	90	70 - 130	
Diclorvos (DDVP)	<0.049		1.95	1.84		ug/L	94	70 - 130	
Dieldrin	<0.0098		1.95	1.93		ug/L	99	70 - 130	
Diethylphthalate	<0.49		1.95	1.91		ug/L	98	70 - 130	
Dimethylphthalate	<0.49		1.95	1.90		ug/L	97	70 - 130	
Di-n-butyl phthalate	<0.98		3.89	3.99		ug/L	103	70 - 130	
Di-n-octyl phthalate	<0.098		1.95	1.53		ug/L	79	70 - 130	
Endosulfan I (Alpha)	<0.098		1.95	1.88		ug/L	97	70 - 130	
Endosulfan II (Beta)	<0.098		1.95	1.84		ug/L	95	70 - 130	
Endosulfan sulfate	<0.098		1.95	1.96		ug/L	101	70 - 130	
Endrin	<0.0098		1.95	2.00		ug/L	103	70 - 130	
Endrin aldehyde	<0.098		1.95	1.42		ug/L	73	60 - 130	
EPTC	<0.098		1.95	1.95		ug/L	100	70 - 130	
Fluoranthene	<0.098		1.95	2.00		ug/L	103	70 - 130	
Fluorene	<0.049		1.95	1.93		ug/L	99	70 - 130	
gamma-Chlordane	<0.049		1.95	2.03		ug/L	104	70 - 130	
Heptachlor	<0.0098		1.95	2.22		ug/L	114	70 - 130	
Heptachlor epoxide (isomer B)	<0.0098		1.95	1.91		ug/L	98	70 - 130	
Hexachlorobenzene	<0.049		1.95	1.92		ug/L	99	70 - 130	
Hexachlorocyclopentadiene	<0.049		1.95	2.09		ug/L	108	70 - 130	
Indeno[1,2,3-cd]pyrene	<0.049		1.95	1.59		ug/L	82	70 - 130	
Isophorone	<0.098		1.95	1.81		ug/L	93	70 - 130	
Lindane	<0.0098		1.95	1.88		ug/L	97	70 - 130	
Malathion	<0.098		1.95	2.13		ug/L	109	70 - 130	
Methoxychlor	<0.049		1.95	2.19		ug/L	113	70 - 130	
Metolachlor	<0.049		1.95	1.97		ug/L	101	70 - 130	
Molinate	<0.098		1.95	1.94		ug/L	100	70 - 130	
Naphthalene	<0.098		1.95	1.93		ug/L	99	70 - 130	
Parathion	<0.098		1.95	2.35		ug/L	121	70 - 130	
Pendimethalin (Penoxaline)	<0.098		1.95	1.81		ug/L	93	70 - 130	
Phenanthrene	<0.039		1.95	1.88		ug/L	97	70 - 130	
Propachlor	<0.049		1.95	1.94		ug/L	100	70 - 130	
Pyrene	<0.049		1.95	1.95		ug/L	100	70 - 130	
Simazine	<0.049		1.95	1.92		ug/L	99	70 - 130	
Terbacil	<0.098		1.95	2.15		ug/L	110	70 - 130	
Terbutylazine	<0.098		1.95	2.04		ug/L	105	70 - 130	
Thiobencarb	<0.098		1.95	1.94		ug/L	100	70 - 130	
trans-Nonachlor	<0.049		1.95	1.92		ug/L	99	70 - 130	
Trifluralin	<0.098		1.95	1.97		ug/L	101	70 - 130	

Surrogate	MS %Recovery	MS Qualifier	Limits
2-Nitro-m-xylene	95		70 - 130

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-112518-B-1-A MS

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Matrix Spike

Prep Type: Total/NA

Prep Batch: 108010

Surrogate	MS %Recovery	MS Qualifier	Limits
Perylene-d12	92		70 - 130
Triphenylphosphate	93		70 - 130

Lab Sample ID: 380-112518-B-2-A DU

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
1-Methylnaphthalene	<0.096		<0.096		ug/L		NC	20
2,4'-DDD	<0.096		<0.096		ug/L		NC	20
2,4'-DDE	<0.096		<0.096		ug/L		NC	20
2,4'-DDT	<0.096		<0.096		ug/L		NC	20
2,4-Dinitrotoluene	<0.096		<0.096		ug/L		NC	20
2,6-Dinitrotoluene	<0.096		<0.096		ug/L		NC	20
2-Methylnaphthalene	<0.096		<0.096		ug/L		NC	20
4,4'-DDD	<0.096		<0.096		ug/L		NC	20
4,4'-DDE	<0.096		<0.096		ug/L		NC	20
4,4'-DDT	<0.096		<0.096		ug/L		NC	20
Acenaphthene	<0.096		<0.096		ug/L		NC	20
Acenaphthylene	<0.096		<0.096		ug/L		NC	20
Acetochlor	<0.096		<0.096		ug/L		NC	20
Alachlor	<0.048		<0.048		ug/L		NC	20
alpha-BHC	<0.096		<0.096		ug/L		NC	20
alpha-Chlordane	<0.048		<0.048		ug/L		NC	20
Anthracene	<0.019		<0.019		ug/L		NC	20
Atrazine	<0.048		<0.048		ug/L		NC	20
Benz(a)anthracene	<0.048		<0.048		ug/L		NC	20
Benzo[a]pyrene	<0.019		<0.019		ug/L		NC	20
Benzo[b]fluoranthene	<0.019		<0.019		ug/L		NC	20
Benzo[g,h,i]perylene	<0.048		<0.048		ug/L		NC	20
Benzo[k]fluoranthene	<0.019		<0.019		ug/L		NC	20
beta-BHC	<0.096		<0.096		ug/L		NC	20
Bis(2-ethylhexyl) phthalate	<0.58		<0.58		ug/L		NC	20
Bromacil	<0.096		<0.096		ug/L		NC	20
Butachlor	<0.048		<0.048		ug/L		NC	20
Butylbenzylphthalate	<0.48		<0.48		ug/L		NC	20
Chlorobenzilate	<0.096		<0.096		ug/L		NC	20
Chloroneb	<0.096		<0.096		ug/L		NC	20
Chlorothalonil (Draconil, Bravo)	<0.096		<0.096		ug/L		NC	20
Chlorpyrifos	<0.048		<0.048		ug/L		NC	20
Chrysene	<0.019		<0.019		ug/L		NC	20
delta-BHC	<0.096		<0.096		ug/L		NC	20
Di(2-ethylhexyl)adipate	<0.58		<0.58		ug/L		NC	20
Dibenz(a,h)anthracene	<0.048		<0.048		ug/L		NC	20
Diclorvos (DDVP)	<0.048		<0.048		ug/L		NC	20
Dieldrin	<0.0096		0.0110		ug/L		NC	20
Diethylphthalate	<0.48		<0.48		ug/L		NC	20
Dimethylphthalate	<0.48		<0.48		ug/L		NC	20

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: 380-112518-B-2-A DU

Matrix: Water

Analysis Batch: 108249

Client Sample ID: Duplicate

Prep Type: Total/NA

Prep Batch: 108010

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
Di-n-butyl phthalate	<0.96		<0.96		ug/L		NC	20
Di-n-octyl phthalate	<0.096		<0.096		ug/L		NC	20
Endosulfan I (Alpha)	<0.096		<0.096		ug/L		NC	20
Endosulfan II (Beta)	<0.096		<0.096		ug/L		NC	20
Endosulfan sulfate	<0.096		<0.096		ug/L		NC	20
Endrin	<0.0096		<0.0096		ug/L		NC	20
Endrin aldehyde	<0.096		<0.096		ug/L		NC	20
EPTC	<0.096		<0.096		ug/L		NC	20
Fluoranthene	<0.096		<0.096		ug/L		NC	20
Fluorene	<0.048		<0.048		ug/L		NC	20
gamma-Chlordane	<0.048		<0.048		ug/L		NC	20
Heptachlor	<0.0096		<0.0096		ug/L		NC	20
Heptachlor epoxide (isomer B)	<0.0096		<0.0096		ug/L		NC	20
Hexachlorobenzene	<0.048		<0.048		ug/L		NC	20
Hexachlorocyclopentadiene	<0.048		<0.048		ug/L		NC	20
Indeno[1,2,3-cd]pyrene	<0.048		<0.048		ug/L		NC	20
Isophorone	<0.096		<0.096		ug/L		NC	20
Lindane	<0.0096		<0.0096		ug/L		NC	20
Malathion	<0.096		<0.096		ug/L		NC	20
Methoxychlor	<0.048		<0.048		ug/L		NC	20
Metolachlor	<0.048		<0.048		ug/L		NC	20
Molinate	<0.096		<0.096		ug/L		NC	20
Naphthalene	<0.096		<0.096		ug/L		NC	20
Parathion	<0.096		<0.096		ug/L		NC	20
Pendimethalin (Penoxaline)	<0.096		<0.096		ug/L		NC	20
Phenanthrene	<0.038		<0.038		ug/L		NC	20
Propachlor	<0.048		<0.048		ug/L		NC	20
Pyrene	<0.048		<0.048		ug/L		NC	20
Simazine	<0.048		<0.048		ug/L		NC	20
Terbacil	<0.096		<0.096		ug/L		NC	20
Terbutylazine	<0.096		<0.096		ug/L		NC	20
Thiobencarb	<0.096		<0.096		ug/L		NC	20
Total Permethrin (mixed isomers)	<0.19		<0.19		ug/L		NC	20
trans-Nonachlor	<0.048		<0.048		ug/L		NC	20
Trifluralin	<0.096		<0.096		ug/L		NC	20

Surrogate	%Recovery	DU Qualifier	Limits
2-Nitro-m-xylene	95		70 - 130
Perylene-d12	88		70 - 130
Triphenylphosphate	89		70 - 130

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: MB 570-481747/11

Matrix: Water

Analysis Batch: 481747

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L		09/17/24 17:23		1

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Surrogate	MB	MB	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Sur)			92		38 - 134		09/17/24 17:23	1

Lab Sample ID: LCS 570-481747/1009

Matrix: Water

Analysis Batch: 481747

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	400	357		ug/L		89	78 - 120

Surrogate

Surrogate	%Recovery	Qualifier	Limits
4-Bromofluorobenzene (Sur)	96		38 - 134

Lab Sample ID: LCSD 570-481747/10

Matrix: Water

Analysis Batch: 481747

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	400	368		ug/L		92	78 - 120	3	10

Surrogate

Surrogate	%Recovery	Qualifier	Limits
4-Bromofluorobenzene (Sur)	94		38 - 134

Lab Sample ID: MRL 570-481747/1004

Matrix: Water

Analysis Batch: 481747

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	10.0	12.5		ug/L		125	50 - 150

Surrogate

Surrogate	%Recovery	Qualifier	Limits
4-Bromofluorobenzene (Sur)	89		38 - 134

Lab Sample ID: 380-111916-C-3 MS

Matrix: Water

Analysis Batch: 481747

Client Sample ID: Matrix Spike
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	<10		400	365		ug/L		91	68 - 122

Surrogate

Surrogate	%Recovery	Qualifier	Limits
4-Bromofluorobenzene (Sur)	95		38 - 134

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

Lab Sample ID: 380-111916-F-3 MSD

Matrix: Water

Analysis Batch: 481747

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	364		ug/L		91	68 - 122	0	18
Surrogate											
4-Bromofluorobenzene (Surr)	%Recovery	MSD Qualifier		Limits							
	95			38 - 134							

Lab Sample ID: MB 570-483045/6

Matrix: Water

Analysis Batch: 483045

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			09/20/24 12:55	1
Surrogate								
4-Bromofluorobenzene (Surr)	%Recovery	MB Qualifier	Limits			Prepared	Analyzed	Dil Fac
	85		38 - 134				09/20/24 12:55	1

Lab Sample ID: LCS 570-483045/4

Matrix: Water

Analysis Batch: 483045

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte		Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)		400	362		ug/L		91	78 - 120		
Surrogate										
4-Bromofluorobenzene (Surr)	%Recovery	LCS Qualifier	Limits							
	89		38 - 134							

Lab Sample ID: LCSD 570-483045/5

Matrix: Water

Analysis Batch: 483045

Client Sample ID: Lab Control Sample Dup
Prep Type: Total/NA

Analyte		Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)		400	360		ug/L		90	78 - 120	1	10
Surrogate										
4-Bromofluorobenzene (Surr)	%Recovery	LCSD Qualifier	Limits							
	92		38 - 134							

Lab Sample ID: MRL 570-483045/3

Matrix: Water

Analysis Batch: 483045

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte		Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)		10.0	11.1		ug/L		111	50 - 150		
Surrogate										
4-Bromofluorobenzene (Surr)	%Recovery	MRL Qualifier	Limits							
	86		38 - 134							

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Lab Sample ID: 380-112520-3 MS

Matrix: Drinking Water

Analysis Batch: 483045

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	<10		400	343		ug/L		86	68 - 122

Surrogate	MS %Recovery	MS Qualifier	Limits
4-Bromofluorobenzene (Surr)	88		38 - 134

Lab Sample ID: 380-112520-3 MSD

Matrix: Drinking Water

Analysis Batch: 483045

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	363		ug/L		91	68 - 122	6	18

Surrogate	MSD %Recovery	MSD Qualifier	Limits
4-Bromofluorobenzene (Surr)	92		38 - 134

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Lab Sample ID: MB 570-481430/1-A

Matrix: Water

Analysis Batch: 483474

Client Sample ID: Method Blank

Prep Type: Total/NA

Prep Batch: 481430

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		09/16/24 17:02	09/23/24 02:16	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		09/16/24 17:02	09/23/24 02:16	1
C8-C18	<25		25	ug/L		09/16/24 17:02	09/23/24 02:16	1

Surrogate	MB %Recovery	MB Qualifier	Limits
n-Octacosane (Surr)	119		60 - 130

Client Sample ID: Prepared

Analyzed

Dil Fac

09/16/24 17:02

09/23/24 02:16

1

Lab Sample ID: LCS 570-481430/2-A

Matrix: Water

Analysis Batch: 483474

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
C10-C28	1600	1440		ug/L		90	56 - 127

Surrogate	LCS %Recovery	LCS Qualifier	Limits
n-Octacosane (Surr)	125		60 - 130

Lab Sample ID: LCSD 570-481430/3-A

Matrix: Water

Analysis Batch: 483474

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	Limits	RPD	RPD Limit
C10-C28	1600	1440		ug/L		90	56 - 127	0	23

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 481430

Eurofins Eaton Analytical Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

Lab Sample ID: LCSD 570-481430/3-A

Matrix: Water

Analysis Batch: 483474

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Prep Batch: 481430

Surrogate	LCSD	LCSD	
	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	130		60 - 130

Lab Sample ID: MRL 570-481430/4-A

Matrix: Water

Analysis Batch: 483474

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 481430

Analyte	Spike	MRL	MRL					
	Added	Result	Qualifier	Unit	D	%Rec	Limits	
C10-C28	0.0200	0.0241	J	mg/L	121	50 - 150		

Surrogate	MRL	MRL	
	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	124		60 - 130

Lab Sample ID: 380-112520-3 MS

Matrix: Drinking Water

Analysis Batch: 483474

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Prep Type: Total/NA

Prep Batch: 481430

Analyte	Sample	Sample	Spike	MS	MS			
	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec
C10-C28	<26		1630	1550		ug/L	95	70 - 130

Surrogate	MS	MS	
	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	125		60 - 130

Lab Sample ID: 380-112520-3 MSD

Matrix: Drinking Water

Analysis Batch: 483474

Client Sample ID: HALAWA WELLS UNITS 1 & 2

Prep Type: Total/NA

Prep Batch: 481430

Analyte	Sample	Sample	Spike	MSD	MSD			
	Result	Qualifier	Added	Result	Qualifier	Unit	D	%Rec
C10-C28	<26		1640	1540		ug/L	94	70 - 130

Surrogate	MSD	MSD	
	%Recovery	Qualifier	Limits
n-Octacosane (Surr)	122		60 - 130

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

GC/MS Semi VOA

Prep Batch: 108010

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-112520-1	Ka'amilo Wells	Total/NA	Water	525.2	
380-112520-3	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	525.2	
MB 380-108010/21-A	Method Blank	Total/NA	Water	525.2	
LCS 380-108010/23-A	Lab Control Sample	Total/NA	Water	525.2	
MRL 380-108010/22-A	Lab Control Sample	Total/NA	Water	525.2	
380-112518-B-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-112518-B-2-A DU	Duplicate	Total/NA	Water	525.2	

Analysis Batch: 108249

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-112520-1	Ka'amilo Wells	Total/NA	Water	525.2	108010
380-112520-3	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	525.2	108010
MB 380-108010/21-A	Method Blank	Total/NA	Water	525.2	108010
LCS 380-108010/23-A	Lab Control Sample	Total/NA	Water	525.2	108010
MRL 380-108010/22-A	Lab Control Sample	Total/NA	Water	525.2	108010
380-112518-B-1-A MS	Matrix Spike	Total/NA	Water	525.2	108010
380-112518-B-2-A DU	Duplicate	Total/NA	Water	525.2	108010

GC VOA

Analysis Batch: 481747

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-112520-1	Ka'amilo Wells	Total/NA	Water	8015B GRO LL	
380-112520-2	TB: Ka'amilo Wells	Total/NA	Water	8015B GRO LL	
380-112520-4	TB: HALAWA WELLS UNITS 1 & 2	Total/NA	Water	8015B GRO LL	
MB 570-481747/11	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-481747/1009	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-481747/10	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-481747/1004	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-111916-C-3 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-111916-F-3 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

Analysis Batch: 483045

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-112520-3	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	8015B GRO LL	
MB 570-483045/6	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-483045/4	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-483045/5	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-483045/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-112520-3 MS	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	8015B GRO LL	
380-112520-3 MSD	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	8015B GRO LL	

GC Semi VOA

Prep Batch: 481430

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-112520-1	Ka'amilo Wells	Total/NA	Water	3510C	
380-112520-3	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	3510C	
MB 570-481430/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-481430/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-481430/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-481430/4-A	Lab Control Sample	Total/NA	Water	3510C	

QC Association Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-112520-1

GC Semi VOA (Continued)

Prep Batch: 481430 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-112520-3 MS	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	3510C	
380-112520-3 MSD	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	3510C	

Analysis Batch: 483474

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-112520-1	Ka'amilo Wells	Total/NA	Water	8015B	481430
380-112520-3	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	8015B	481430
MB 570-481430/1-A	Method Blank	Total/NA	Water	8015B	481430
LCS 570-481430/2-A	Lab Control Sample	Total/NA	Water	8015B	481430
LCSD 570-481430/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	481430
MRL 570-481430/4-A	Lab Control Sample	Total/NA	Water	8015B	481430
380-112520-3 MS	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	8015B	481430
380-112520-3 MSD	HALAWA WELLS UNITS 1 & 2	Total/NA	Drinking Water	8015B	481430

Lab Chronicle

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Client Sample ID: Ka'amilo Wells
Date Collected: 09/09/24 11:28
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-1
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			108010	OTM3	EA POM	09/12/24 12:00
Total/NA	Analysis	525.2		1	108249	Q8LA	EA POM	09/13/24 13:34
Total/NA	Analysis	8015B GRO LL		1	481747	A9VE	EET CAL 4	09/18/24 02:42
Total/NA	Prep	3510C			481430	H6FE	EET CAL 4	09/16/24 17:02
Total/NA	Analysis	8015B		1	483474	SP9M	EET CAL 4	09/23/24 04:01

Client Sample ID: TB: Ka'amilo Wells
Date Collected: 09/09/24 11:28
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-2
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	481747	A9VE	EET CAL 4	09/18/24 01:09

Client Sample ID: HALAWA WELLS UNITS 1 & 2
Date Collected: 09/09/24 10:06
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-3
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	525.2			108010	OTM3	EA POM	09/12/24 12:00
Total/NA	Analysis	525.2		1	108249	Q8LA	EA POM	09/13/24 13:54
Total/NA	Analysis	8015B GRO LL		1	483045	A9VE	EET CAL 4	09/20/24 14:32
Total/NA	Prep	3510C			481430	H6FE	EET CAL 4	09/16/24 17:02
Total/NA	Analysis	8015B		1	483474	SP9M	EET CAL 4	09/23/24 04:22

Client Sample ID: TB: HALAWA WELLS UNITS 1 & 2
Date Collected: 09/09/24 10:06
Date Received: 09/11/24 10:09

Lab Sample ID: 380-112520-4
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8015B GRO LL		1	481747	A9VE	EET CAL 4	09/18/24 01:33

Laboratory References:

EA POM = Eurofins Eaton Analytical Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Accreditation/Certification Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-112520-1

Laboratory: Eurofins Eaton Analytical Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	1-Methylnaphthalene
525.2	525.2	Drinking Water	2,4'-DDD
525.2	525.2	Drinking Water	2,4'-DDE
525.2	525.2	Drinking Water	2,4'-DDT
525.2	525.2	Drinking Water	2,4-Dinitrotoluene
525.2	525.2	Drinking Water	2,6-Dinitrotoluene
525.2	525.2	Drinking Water	2-Methylnaphthalene
525.2	525.2	Drinking Water	4,4'-DDD
525.2	525.2	Drinking Water	4,4'-DDE
525.2	525.2	Drinking Water	4,4' DDT
525.2	525.2	Drinking Water	Acetochlor
525.2	525.2	Drinking Water	alpha-BHC
525.2	525.2	Drinking Water	alpha-Chlordane
525.2	525.2	Drinking Water	beta-BHC
525.2	525.2	Drinking Water	Chlorobenzilate
525.2	525.2	Drinking Water	Chloroneb
525.2	525.2	Drinking Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Drinking Water	Chlorpyrifos
525.2	525.2	Drinking Water	delta-BHC
525.2	525.2	Drinking Water	Diclorvos (DDVP)
525.2	525.2	Drinking Water	Endosulfan I (Alpha)
525.2	525.2	Drinking Water	Endosulfan II (Beta)
525.2	525.2	Drinking Water	Endosulfan sulfate
525.2	525.2	Drinking Water	Endrin aldehyde
525.2	525.2	Drinking Water	EPTC
525.2	525.2	Drinking Water	gamma-Chlordane
525.2	525.2	Drinking Water	Isophorone
525.2	525.2	Drinking Water	Malathion
525.2	525.2	Drinking Water	Parathion
525.2	525.2	Drinking Water	Pendimethalin (Penoxaline)
525.2	525.2	Drinking Water	Terbacil
525.2	525.2	Drinking Water	Terbutylazine
525.2	525.2	Drinking Water	Total Permethrin (mixed isomers)
525.2	525.2	Drinking Water	trans-Nonachlor
525.2	525.2	Water	1 Methylnaphthalene
525.2	525.2	Water	2,4'-DDD
525.2	525.2	Water	2,4'-DDE
525.2	525.2	Water	2,4'-DDT
525.2	525.2	Water	2,4-Dinitrotoluene
525.2	525.2	Water	2,6-Dinitrotoluene
525.2	525.2	Water	2-Methylnaphthalene
525.2	525.2	Water	4,4'-DDD
525.2	525.2	Water	4,4'-DDE
525.2	525.2	Water	4,4'-DDT
525.2	525.2	Water	Acetochlor

Accreditation/Certification Summary

Client: City & County of Honolulu

Project/Site: RED-HILL

Job ID: 380-112520-1

Laboratory: Eurofins Eaton Analytical Pomona (Continued)

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.			
Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Water	alpha-BHC
525.2	525.2	Water	alpha-Chlordane
525.2	525.2	Water	beta-BHC
525.2	525.2	Water	Chlorobenzilate
525.2	525.2	Water	Chloroneb
525.2	525.2	Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Water	Chlorpyrifos
525.2	525.2	Water	delta-BHC
525.2	525.2	Water	Diclorvos (DDVP)
525.2	525.2	Water	Endosulfan I (Alpha)
525.2	525.2	Water	Endosulfan II (Beta)
525.2	525.2	Water	Endosulfan sulfate
525.2	525.2	Water	Endrin aldehyde
525.2	525.2	Water	EPTC
525.2	525.2	Water	gamma-Chlordane
525.2	525.2	Water	Isophorone
525.2	525.2	Water	Malathion
525.2	525.2	Water	Parathion
525.2	525.2	Water	Pendimethalin (Penoxaline)
525.2	525.2	Water	Terbacil
525.2	525.2	Water	Terbutylazine
525.2	525.2	Water	Total Permethrin (mixed isomers)
525.2	525.2	Water	trans-Nonachlor

Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Arizona	State	AZ0830	11-16-24
Arkansas DEQ	State	88-0161	07-02-25
California	Los Angeles County Sanitation Districts	9257304	08-01-24 *
California	State	3082	07-31-26
Kansas	NELAP	E-10420	07-31-25
Nevada	State	CA00111	07-31-25
Oregon	NELAP	4175	02-02-25
USDA	US Federal Programs	P330-22-00059	06-08-26
Washington	State	C916-18	10-11-24

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Method	Method Description	Protocol	Laboratory
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
525.2	Extraction of Semivolatile Compounds	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EA POM = Eurofins Eaton Analytical Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-112520-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
380-112520-1	Ka'amilo Wells	Water	09/09/24 11:28	09/11/24 10:09
380-112520-2	TB: Ka'amilo Wells	Water	09/09/24 11:28	09/11/24 10:09
380-112520-3	HALAWA WELLS UNITS 1 & 2	Drinking Water	09/09/24 10:06	09/11/24 10:09
380-112520-4	TB: HALAWA WELLS UNITS 1 & 2	Water	09/09/24 10:06	09/11/24 10:09

Chain of Custody Record

eurofins | Environment Testing

ORIGIN ID HIKA
BWS CHEM LAB
HONOLULU BOARD OF WATER SUPPLY
630 S BERETANIA ST
CHEMICAL LABORATORY
HONOLULU HI 96643
UNITED STATES US

SHIP DATE: 10SEP24
ACTWGT: 62.00 LB
CAD: 258050552/INET4535

BILL RECIPIENT

TO **EUROFINS RECEIVING DEPARTMENT**
EUROFINS DRINKING WATER TESTING
941 CORPORATE CENTER DR

POMONA CA 91768

REF: [626] 386-1100

INV: [0263]

PO: [0201]

DEPT:



583J2/4EF9/9AE3
SHIP DATE: 10SEP24
ACTWGT: 62.00 LB
CAD: 258050552/INET4535
DEPT:
REF: [626] 386-1100
INV: [0263]
PO: [0201]

WED - 11 SEP 10:30A
PRIORITY OVERNIGHT

MPS# 7785 0206 0958
0263
Mstr# 7785 0206 0947
0201

91768
CA-US
ONT

WM ONTA

CA-US



1 Fold the printed page along the horizontal line
2 Place label in shipping pouch and affix it to your shipment
CONSIGNEE COPY. PLEASE PLACE IN FRONT OF POUCH
After printing this label



Chain of Custody Record

Note: Since laboratory accreditations are subject to change, Eurofins Eaton Analytical, LLC places the ownership of method, analysis & accreditation confidence upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analytical tests/marks being analyzed, the samples must be shipped back to the Eurofins Eaton Analytical or other subcontractors will be provided. Any changes to accreditation status should be brought to Eurofins Eaton Analytical, LLC attention immediately. If all requested certifications are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Eaton Analytical, LLC.

Possible Hazard Identification

Unconfirmed Delinquent Other

Second Kit Published by

~~Simply All Requirements~~

[Signature]
Renounced by:

Renounced by:

Custody Seal intact: Seal No.

Customer Service

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-112520-1

Login Number: 112520

List Source: Eurofins Eaton Analytical Pomona

List Number: 1

Creator: Ngo, Theodore

Question

Answer

Comment

The coolers custody seal, if present, is intact.

True

Sample custody seals, if present, are intact.

True

Samples were received on ice.

True

Cooler(s) Temperature is acceptable.

True

Cooler(s) Temperature is recorded.

True

COC is present.

True

COC is filled out in ink and is legible.

True

COC is filled out with all pertinent information.

True

There are no discrepancies between the containers received and the COC.

True

Samples are received within Holding Time (excluding tests with immediate HTs)

True

Sample containers have legible labels.

True

Containers are not broken or leaking.

True

Sample collection date/times are provided.

True

There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs

True

Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").

True

ClO₄ headspace requirement met (>50% for CA, >30% for other states).

True

Samples do not require splitting or compositing.

True

Container provided by EEA

True

Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-112520-1

Login Number: 112520

List Source: Eurofins Calscience

List Number: 2

List Creation: 09/12/24 03:31 PM

Creator: Khana, Piyush

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	1.2
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	N/A	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	