

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Erwin Kawata  
City & County of Honolulu  
630 South Beretania Street  
Public Service Bldg. Room 310  
Honolulu, Hawaii 96843

Generated 4/15/2026 4:34:27 PM

## JOB DESCRIPTION

RED-HILL  
PFAS: Halawa Shaft Viewing Pool

## JOB NUMBER

380-207441-1

# Eurofins Pomona

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

## Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

## Authorization



Authorized for release by  
Maria Lopez, Project Manager  
[Maria.Lopez@et.eurofinsus.com](mailto:Maria.Lopez@et.eurofinsus.com)  
(626)386-1100

Generated  
4/15/2026 4:34:27 PM



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	5
Detection Summary . . . . .	6
Client Sample Results . . . . .	7
Action Limit Summary . . . . .	11
Surrogate Summary . . . . .	12
Isotope Dilution Summary . . . . .	13
QC Sample Results . . . . .	14
QC Association Summary . . . . .	25
Lab Chronicle . . . . .	26
Certification Summary . . . . .	27
Method Summary . . . . .	28
Sample Summary . . . . .	29
Chain of Custody . . . . .	30
Receipt Checklists . . . . .	31

# Definitions/Glossary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Qualifiers

### LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: City & County of Honolulu  
Project: RED-HILL

Job ID: 380-207441-1

**Job ID: 380-207441-1**

**Eurofins Pomona**

## Job Narrative 380-207441-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

### Receipt

The samples were received on 4/9/2026 10:00 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.0°C.

### PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

# Detection Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Client Sample ID: Halawa Shaft Viewing Pool

Lab Sample ID: 380-207441-1

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Perfluorohexanesulfonic acid (PFHxS)	3.3		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.2		2.0	ng/L	1		533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.3		2.0	ng/L	1		EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.6		2.0	ng/L	1		EPA 537.1 V2	Total/NA

## Client Sample ID: Halawa Shaft Viewing Pool Blank

Lab Sample ID: 380-207441-2

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona



# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

**Client Sample ID: Halawa Shaft Viewing Pool**

**Lab Sample ID: 380-207441-1**

Date Collected: 04/07/26 09:35

Matrix: Water

Date Received: 04/09/26 10:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
<b>Perfluorohexanesulfonic acid (PFHxS)</b>	<b>3.3</b>		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
<b>Perfluorooctanesulfonic acid (PFOS)</b>	<b>3.2</b>		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:41	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	103		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C6 PFDA	98		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C5 PFHxA	103		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C4 PFHpA	111		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C8 PFOA	113		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C9 PFNA	107		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C7 PFUnA	102		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C2 PFDoA	101		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C4 PFBA	108		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C5 PFPeA	116		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C3 PFBS	113		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C3 PFHxS	111		50 - 200	04/13/26 18:05	04/14/26 10:41	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

**Client Sample ID: Halawa Shaft Viewing Pool**

**Lab Sample ID: 380-207441-1**

Date Collected: 04/07/26 09:35

Matrix: Water

Date Received: 04/09/26 10:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C8 PFOS	112		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C2-4:2-FTS	119		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C2-6:2-FTS	111		50 - 200	04/13/26 18:05	04/14/26 10:41	1
13C2-8:2-FTS	108		50 - 200	04/13/26 18:05	04/14/26 10:41	1

**Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
<b>Perfluorooctanesulfonic acid (PFOS)</b>	<b>3.3</b>		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
N-methylperfluorooctanesulfonamideacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
N-ethylperfluorooctanesulfonamideacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
<b>Perfluorohexanesulfonic acid (PFHxS)</b>	<b>3.6</b>		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 21:59	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>			<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
d5-NEtFOSAA	105		70 - 130			04/11/26 09:51	04/12/26 21:59	1
13C2 PFHxA	92		70 - 130			04/11/26 09:51	04/12/26 21:59	1
13C2 PFDA	99		70 - 130			04/11/26 09:51	04/12/26 21:59	1
13C3-GenX	92		70 - 130			04/11/26 09:51	04/12/26 21:59	1

**Client Sample ID: Halawa Shaft Viewing Pool Blank**

**Lab Sample ID: 380-207441-2**

Date Collected: 04/07/26 09:35

Matrix: Water

Date Received: 04/09/26 10:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

**Client Sample ID: Halawa Shaft Viewing Pool Blank**

**Lab Sample ID: 380-207441-2**

Date Collected: 04/07/26 09:35

Matrix: Water

Date Received: 04/09/26 10:00

**Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		04/13/26 18:05	04/14/26 10:51	1
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>			<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
13C3 HFPO-DA	100		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C6 PFDA	101		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C5 PFHxA	100		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C4 PFHpA	106		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C8 PFOA	106		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C9 PFNA	107		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C7 PFUnA	94		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C2 PFDoA	102		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C4 PFBA	107		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C5 PFPeA	113		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C3 PFBS	109		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C3 PFHxS	114		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C8 PFOS	109		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C2-4:2-FTS	112		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C2-6:2-FTS	107		50 - 200			04/13/26 18:05	04/14/26 10:51	1
13C2-8:2-FTS	106		50 - 200			04/13/26 18:05	04/14/26 10:51	1

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

**Client Sample ID: Halawa Shaft Viewing Pool Blank**

**Lab Sample ID: 380-207441-2**

Date Collected: 04/07/26 09:35

Matrix: Water

Date Received: 04/09/26 10:00

**Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		04/11/26 09:51	04/12/26 22:09	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>			<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
d5-NEtFOSAA	101		70 - 130			04/11/26 09:51	04/12/26 22:09	1
13C2 PFHxA	96		70 - 130			04/11/26 09:51	04/12/26 22:09	1
13C2 PFDA	102		70 - 130			04/11/26 09:51	04/12/26 22:09	1
13C3-GenX	94		70 - 130			04/11/26 09:51	04/12/26 22:09	1

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

**Client Sample ID: Halawa Shaft Viewing Pool**

**Lab Sample ID: 380-207441-1**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.3		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.2		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	3.3		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	3.6		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

**Client Sample ID: Halawa Shaft Viewing Pool Blank**

**Lab Sample ID: 380-207441-2**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-207441-1  
 SDG: PFAS: Halawa Shaft Viewing Pool

**Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020**

**Matrix: Water**

**Prep Type: Total/NA**

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-207357-A-1-B MS	Matrix Spike	104	98	105	99
380-207357-A-1-C MSD	Matrix Spike Duplicate	100	90	97	91
380-207441-1	Halawa Shaft Viewing Pool	105	92	99	92
380-207441-2	Halawa Shaft Viewing Pool	101	96	102	94
	Blank				
LCS 380-219307/23-A	Lab Control Sample	98	98	103	95
MBL 380-219307/21-A	Method Blank	99	98	102	99
MRL 380-219307/22-A	Lab Control Sample	97	98	103	96

**Surrogate Legend**

- d5NEFOS = d5-NEtFOSAA
- PFHxA = 13C2 PFHxA
- PFDA = 13C2 PFDA
- GenX = 13C3-GenX



# Isotope Dilution Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDoA (50-200)
380-207282-E-1-A MS	Matrix Spike	115	103	105	113	111	113	104	108
380-207282-F-1-A MSD	Matrix Spike Duplicate	113	100	111	107	107	107	103	101
380-207441-1	Halawa Shaft Viewing Pool	103	98	103	111	113	107	102	101
380-207441-2	Halawa Shaft Viewing Pool	100	101	100	106	106	107	94	102
LCS 380-219603/22-A	Lab Control Sample	107	102	107	109	110	107	105	102
MBL 380-219603/20-A	Method Blank	111	104	113	111	111	119	106	109
MRL 380-219603/21-A	Lab Control Sample	102	103	108	107	107	110	99	102

		Percent Isotope Dilution Recovery (Acceptance Limits)							
Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-207282-E-1-A MS	Matrix Spike	109	114	112	108	113	112	103	104
380-207282-F-1-A MSD	Matrix Spike Duplicate	103	115	109	110	110	106	104	100
380-207441-1	Halawa Shaft Viewing Pool	108	116	113	111	112	119	111	108
380-207441-2	Halawa Shaft Viewing Pool	107	113	109	114	109	112	107	106
LCS 380-219603/22-A	Lab Control Sample	102	105	110	107	110	111	103	101
MBL 380-219603/20-A	Method Blank	112	110	119	116	115	111	118	106
MRL 380-219603/21-A	Lab Control Sample	106	114	114	110	111	116	109	101

### Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDoA = 13C2 PFDoA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

**Lab Sample ID: MBL 380-219603/20-A**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosfluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<0.25		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		04/13/26 18:05	04/14/26 08:34	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	111		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C6 PFDA	104		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C5 PFHxA	113		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C4 PFHpA	111		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C8 PFOA	111		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C9 PFNA	119		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C7 PFUnA	106		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C2 PFDoA	109		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C4 PFBA	112		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C5 PFPeA	110		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C3 PFBS	119		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C3 PFHxS	116		50 - 200	04/13/26 18:05	04/14/26 08:34	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MBL 380-219603/20-A**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

<i>Isotope Dilution</i>	<i>MBL %Recovery</i>	<i>MBL Qualifier</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C8 PFOS	115		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C2-4:2-FTS	111		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C2-6:2-FTS	118		50 - 200	04/13/26 18:05	04/14/26 08:34	1
13C2-8:2-FTS	106		50 - 200	04/13/26 18:05	04/14/26 08:34	1

**Lab Sample ID: LCS 380-219603/22-A**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

<i>Analyte</i>	<i>Spike Added</i>	<i>LCS Result</i>	<i>LCS Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec Limits</i>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	120	107		ng/L		89	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	120	113		ng/L		94	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	120	118		ng/L		98	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	120	120		ng/L		100	70 - 130
Perfluorobutanesulfonic acid (PFBS)	120	115		ng/L		96	70 - 130
Perfluorodecanoic acid (PFDA)	120	120		ng/L		100	70 - 130
Perfluorododecanoic acid (PFDoA)	120	117		ng/L		97	70 - 130
Perfluoroheptanoic acid (PFHpA)	120	116		ng/L		97	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	120	115		ng/L		96	70 - 130
Perfluorohexanoic acid (PFHxA)	120	114		ng/L		95	70 - 130
Perfluorononanoic acid (PFNA)	120	113		ng/L		95	70 - 130
Perfluorooctanesulfonic acid (PFOS)	120	109		ng/L		90	70 - 130
Perfluorooctanoic acid (PFOA)	120	109		ng/L		91	70 - 130
Perfluoroundecanoic acid (PFUnA)	120	119		ng/L		99	70 - 130
Perfluorobutanoic acid (PFBA)	120	114		ng/L		95	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	120	119		ng/L		99	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	120	111		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	120	116		ng/L		97	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	120	116		ng/L		97	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	120	117		ng/L		98	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	120	118		ng/L		98	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	120	117		ng/L		97	70 - 130
Perfluoropentanoic acid (PFPeA)	120	115		ng/L		95	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	120	115		ng/L		95	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: LCS 380-219603/22-A**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	
Perfluoropentanesulfonic acid (PFPeS)	120	116		ng/L		97	70 - 130	
<b>LCS LCS</b>								
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>						<b>Limits</b>
13C3 HFPO-DA	107							50 - 200
13C6 PFDA	102							50 - 200
13C5 PFHxA	107							50 - 200
13C4 PFHpA	109							50 - 200
13C8 PFOA	110							50 - 200
13C9 PFNA	107							50 - 200
13C7 PFUnA	105							50 - 200
13C2 PFDoA	102							50 - 200
13C4 PFBA	102							50 - 200
13C5 PFPeA	105							50 - 200
13C3 PFBS	110							50 - 200
13C3 PFHxS	107							50 - 200
13C8 PFOS	110							50 - 200
13C2-4:2-FTS	111							50 - 200
13C2-6:2-FTS	103							50 - 200
13C2-8:2-FTS	101							50 - 200

**Lab Sample ID: MRL 380-219603/21-A**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	2.00	J	ng/L		100	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	2.09	J	ng/L		104	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.11	J	ng/L		105	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	2.09	J	ng/L		104	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	2.01	J	ng/L		100	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.10	J	ng/L		105	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.11	J	ng/L		105	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.04	J	ng/L		102	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	1.94	J	ng/L		97	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	1.98	J	ng/L		99	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.02	J	ng/L		101	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	2.02	J	ng/L		101	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.08	J	ng/L		104	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.08	J	ng/L		104	50 - 150
Perfluorobutanoic acid (PFBA)	2.00	2.17	J	ng/L		108	50 - 150

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: MRL 380-219603/21-A**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.00	2.35	J	ng/L		117	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.00	2.23	J	ng/L		111	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.00	2.17	J	ng/L		108	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.00	2.16	J	ng/L		108	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.00	2.04	J	ng/L		102	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	2.17	J	ng/L		108	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.00	2.00	J	ng/L		100	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	2.09	J	ng/L		104	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.00	1.96	J	ng/L		98	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.00	2.14	J	ng/L		107	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	102		50 - 200
13C6 PFDA	103		50 - 200
13C5 PFHxA	108		50 - 200
13C4 PFHpA	107		50 - 200
13C8 PFOA	107		50 - 200
13C9 PFNA	110		50 - 200
13C7 PFUnA	99		50 - 200
13C2 PFDoA	102		50 - 200
13C4 PFBA	106		50 - 200
13C5 PFPeA	114		50 - 200
13C3 PFBS	114		50 - 200
13C3 PFHxS	110		50 - 200
13C8 PFOS	111		50 - 200
13C2-4:2-FTS	116		50 - 200
13C2-6:2-FTS	109		50 - 200
13C2-8:2-FTS	101		50 - 200

**Lab Sample ID: 380-207282-E-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	108		ng/L		90	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	112		ng/L		93	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	112		ng/L		93	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: 380-207282-E-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		120	114		ng/L		95	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	<2.0		120	115		ng/L		96	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		120	122		ng/L		101	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		120	113		ng/L		93	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		120	115		ng/L		95	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		120	115		ng/L		95	70 - 130
Perfluorohexanoic acid (PFHxA)	<2.0		120	113		ng/L		94	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		120	111		ng/L		92	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		120	111		ng/L		92	70 - 130
Perfluorooctanoic acid (PFOA)	<2.0		120	113		ng/L		94	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		120	115		ng/L		96	70 - 130
Perfluorobutanoic acid (PFBA)	<2.0		120	112		ng/L		93	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	119		ng/L		98	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	114		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	117		ng/L		97	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	117		ng/L		97	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		120	114		ng/L		94	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	116		ng/L		96	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	122		ng/L		101	70 - 130
Perfluoropentanoic acid (PFPeA)	<2.0		120	113		ng/L		94	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	112		ng/L		93	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	115		ng/L		96	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	115		50 - 200
13C6 PFDA	103		50 - 200
13C5 PFHxA	105		50 - 200
13C4 PFHpA	113		50 - 200
13C8 PFOA	111		50 - 200
13C9 PFNA	113		50 - 200
13C7 PFUnA	104		50 - 200
13C2 PFDoA	108		50 - 200
13C4 PFBA	109		50 - 200
13C5 PFPeA	114		50 - 200
13C3 PFBS	112		50 - 200
13C3 PFHxS	108		50 - 200
13C8 PFOS	113		50 - 200

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

**Lab Sample ID: 380-207282-E-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>MS MS Qualifier</i>	<i>Limits</i>
13C2-4:2-FTS	112		50 - 200
13C2-6:2-FTS	103		50 - 200
13C2-8:2-FTS	104		50 - 200

**Lab Sample ID: 380-207282-F-1-A MSD**  
**Matrix: Water**  
**Analysis Batch: 219741**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 219603**

<b>Analyte</b>	<b>Sample Result</b>	<b>Sample Qualifier</b>	<b>Spike Added</b>	<b>MSD Result</b>	<b>MSD Qualifier</b>	<b>Unit</b>	<b>D</b>	<b>%Rec</b>	<b>%Rec Limits</b>	<b>RPD</b>	<b>RPD Limit</b>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		120	110		ng/L		91	70 - 130	1	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		120	111		ng/L		92	70 - 130	1	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		120	121		ng/L		100	70 - 130	8	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		120	116		ng/L		96	70 - 130	1	30
Perfluorobutanesulfonic acid (PFBS)	<2.0		120	113		ng/L		94	70 - 130	2	30
Perfluorodecanoic acid (PFDA)	<2.0		120	124		ng/L		103	70 - 130	2	30
Perfluorododecanoic acid (PFDoA)	<2.0		120	114		ng/L		95	70 - 130	2	30
Perfluoroheptanoic acid (PFHpA)	<2.0		120	120		ng/L		99	70 - 130	4	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		120	114		ng/L		94	70 - 130	1	30
Perfluorohexanoic acid (PFHxA)	<2.0		120	113		ng/L		94	70 - 130	0	30
Perfluorononanoic acid (PFNA)	<2.0		120	112		ng/L		93	70 - 130	1	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		120	111		ng/L		92	70 - 130	0	30
Perfluorooctanoic acid (PFOA)	<2.0		120	112		ng/L		93	70 - 130	0	30
Perfluoroundecanoic acid (PFUnA)	<2.0		120	116		ng/L		96	70 - 130	1	30
Perfluorobutanoic acid (PFBA)	<2.0		120	116		ng/L		96	70 - 130	4	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		120	116		ng/L		96	70 - 130	2	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		120	109		ng/L		91	70 - 130	4	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		120	112		ng/L		93	70 - 130	4	30
Nonfluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		120	105		ng/L		87	70 - 130	11	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	<2.0		120	118		ng/L		98	70 - 130	4	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		120	118		ng/L		98	70 - 130	2	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		120	113		ng/L		94	70 - 130	8	30
Perfluoropentanoic acid (PFPeA)	<2.0		120	115		ng/L		95	70 - 130	2	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		120	114		ng/L		95	70 - 130	2	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		120	113		ng/L		93	70 - 130	2	30

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

<i>Isotope Dilution</i>	<i>MSD</i>	<i>MSD</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
13C3 HFPO-DA	113		50 - 200
13C6 PFDA	100		50 - 200
13C5 PFHxA	111		50 - 200
13C4 PFHpA	107		50 - 200
13C8 PFOA	107		50 - 200
13C9 PFNA	107		50 - 200
13C7 PFUnA	103		50 - 200
13C2 PFDoA	101		50 - 200
13C4 PFBA	103		50 - 200
13C5 PFPeA	115		50 - 200
13C3 PFBS	109		50 - 200
13C3 PFHxS	110		50 - 200
13C8 PFOS	110		50 - 200
13C2-4:2-FTS	106		50 - 200
13C2-6:2-FTS	104		50 - 200
13C2-8:2-FTS	100		50 - 200

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

**Lab Sample ID: MBL 380-219307/21-A**  
**Matrix: Water**  
**Analysis Batch: 219401**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 219307**

<i>Analyte</i>	<i>MBL</i>	<i>MBL</i>	<i>RL</i>	<i>Unit</i>	<i>D</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>Result</i>	<i>Qualifier</i>						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
Perfluorotridecanoic acid (PFTrDA)	<0.36		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		04/11/26 09:51	04/12/26 19:00	1

  

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
	<i>%Recovery</i>	<i>Qualifier</i>				
d5-NEtFOSAA	99		70 - 130	04/11/26 09:51	04/12/26 19:00	1
13C2 PFHxA	98		70 - 130	04/11/26 09:51	04/12/26 19:00	1
13C2 PFDA	102		70 - 130	04/11/26 09:51	04/12/26 19:00	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: MBL 380-219307/21-A**  
**Matrix: Water**  
**Analysis Batch: 219401**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 219307**

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	99	Qualifier	70 - 130	04/11/26 09:51	04/12/26 19:00	1

**Lab Sample ID: LCS 380-219307/23-A**  
**Matrix: Water**  
**Analysis Batch: 219401**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 219307**

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>	<i>Limits</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>					
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	50.0	44.4		ng/L		89		70 - 130
Perfluorooctanesulfonic acid (PFOS)	50.0	50.7		ng/L		101		70 - 130
Perfluoroundecanoic acid (PFUnA)	50.0	48.3		ng/L		97		70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	50.0	47.5		ng/L		95		70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	50.0	46.9		ng/L		94		70 - 130
Perfluorohexanoic acid (PFHxA)	50.0	46.3		ng/L		93		70 - 130
Perfluorododecanoic acid (PFDoA)	50.0	48.2		ng/L		96		70 - 130
Perfluorooctanoic acid (PFOA)	50.0	48.1		ng/L		96		70 - 130
Perfluorodecanoic acid (PFDA)	50.0	49.4		ng/L		99		70 - 130
Perfluorohexanesulfonic acid (PFHxS)	50.0	50.3		ng/L		101		70 - 130
Perfluorobutanesulfonic acid (PFBS)	50.0	51.3		ng/L		103		70 - 130
Perfluoroheptanoic acid (PFHpA)	50.0	47.7		ng/L		95		70 - 130
Perfluorononanoic acid (PFNA)	50.0	49.6		ng/L		99		70 - 130
Perfluorotetradecanoic acid (PFTA)	50.0	39.4		ng/L		79		70 - 130
Perfluorotridecanoic acid (PFTrDA)	50.0	50.2		ng/L		100		70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	50.0	47.4		ng/L		95		70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	50.0	45.8		ng/L		92		70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	50.0	42.5		ng/L		85		70 - 130

<i>Surrogate</i>	<i>LCS</i>	<i>LCS</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
d5-NEtFOSAA	98		70 - 130
13C2 PFHxA	98		70 - 130
13C2 PFDA	103		70 - 130
13C3-GenX	95		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

**Lab Sample ID: MRL 380-219307/22-A**  
**Matrix: Water**  
**Analysis Batch: 219401**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 219307**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	1.81	J	ng/L		90	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	1.94	J	ng/L		97	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.02	J	ng/L		101	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.00	2.10	J	ng/L		105	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.00	1.99	J	ng/L		100	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.02	J	ng/L		101	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.02	J	ng/L		101	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.09	J	ng/L		104	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.12	J	ng/L		106	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	2.13	J	ng/L		107	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	1.96	J	ng/L		98	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.02	J	ng/L		101	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.13	J	ng/L		106	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.00	1.58	J	ng/L		79	50 - 150
Perfluorotridecanoic acid (PFTrDA)	2.00	2.05	J	ng/L		103	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	1.85	J	ng/L		92	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.80	J	ng/L		90	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	1.85	J	ng/L		93	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	97		70 - 130
13C2 PFHxA	98		70 - 130
13C2 PFDA	103		70 - 130
13C3-GenX	96		70 - 130

**Lab Sample ID: 380-207357-A-1-B MS**  
**Matrix: Water**  
**Analysis Batch: 219401**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 219307**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		50.2	46.0		ng/L		92	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		50.2	50.1		ng/L		100	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		50.2	49.2		ng/L		98	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		50.2	48.7		ng/L		97	70 - 130

Eurofins Pomona





# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## LCMS

### Prep Batch: 219307

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-207441-1	Halawa Shaft Viewing Pool	Total/NA	Water	537.1 DW	
380-207441-2	Halawa Shaft Viewing Pool Blank	Total/NA	Water	537.1 DW	
MBL 380-219307/21-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-219307/23-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-219307/22-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-207357-A-1-B MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-207357-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

### Analysis Batch: 219401

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-207441-1	Halawa Shaft Viewing Pool	Total/NA	Water	EPA 537.1 V2	219307
380-207441-2	Halawa Shaft Viewing Pool Blank	Total/NA	Water	EPA 537.1 V2	219307
MBL 380-219307/21-A	Method Blank	Total/NA	Water	EPA 537.1 V2	219307
LCS 380-219307/23-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	219307
MRL 380-219307/22-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	219307
380-207357-A-1-B MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	219307
380-207357-A-1-C MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	219307

### Prep Batch: 219603

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-207441-1	Halawa Shaft Viewing Pool	Total/NA	Water	533	
380-207441-2	Halawa Shaft Viewing Pool Blank	Total/NA	Water	533	
MBL 380-219603/20-A	Method Blank	Total/NA	Water	533	
LCS 380-219603/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-219603/21-A	Lab Control Sample	Total/NA	Water	533	
380-207282-E-1-A MS	Matrix Spike	Total/NA	Water	533	
380-207282-F-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

### Analysis Batch: 219741

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-207441-1	Halawa Shaft Viewing Pool	Total/NA	Water	533	219603
380-207441-2	Halawa Shaft Viewing Pool Blank	Total/NA	Water	533	219603
MBL 380-219603/20-A	Method Blank	Total/NA	Water	533	219603
LCS 380-219603/22-A	Lab Control Sample	Total/NA	Water	533	219603
MRL 380-219603/21-A	Lab Control Sample	Total/NA	Water	533	219603
380-207282-E-1-A MS	Matrix Spike	Total/NA	Water	533	219603
380-207282-F-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	219603

# Lab Chronicle

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Client Sample ID: Halawa Shaft Viewing Pool

Lab Sample ID: 380-207441-1

Date Collected: 04/07/26 09:35

Matrix: Water

Date Received: 04/09/26 10:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			219603	E2HD	EA POM	04/13/26 18:05
Total/NA	Analysis	533		1	219741	SZ9R	EA POM	04/14/26 10:41
Total/NA	Prep	537.1 DW			219307	E9PK	EA POM	04/11/26 09:51
Total/NA	Analysis	EPA 537.1 V2		1	219401	M7ML	EA POM	04/12/26 21:59

## Client Sample ID: Halawa Shaft Viewing Pool Blank

Lab Sample ID: 380-207441-2

Date Collected: 04/07/26 09:35

Matrix: Water

Date Received: 04/09/26 10:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			219603	E2HD	EA POM	04/13/26 18:05
Total/NA	Analysis	533		1	219741	SZ9R	EA POM	04/14/26 10:51
Total/NA	Prep	537.1 DW			219307	E9PK	EA POM	04/11/26 09:51
Total/NA	Analysis	EPA 537.1 V2		1	219401	M7ML	EA POM	04/12/26 22:09

### Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

## Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

# Method Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100



# Sample Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-207441-1  
SDG: PFAS: Halawa Shaft Viewing Pool

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-207441-1	Halawa Shaft Viewing Pool	Water	04/07/26 09:35	04/09/26 10:00	Hawaii
380-207441-2	Halawa Shaft Viewing Pool Blank	Water	04/07/26 09:35	04/09/26 10:00	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17



# Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-207441-1  
SDG Number: PFAS: Halawa Shaft Viewing Pool

**Login Number: 207441**

**List Number: 1**

**Creator: Del Rosario, Michael**

**List Source: Eurofins Pomona**

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	N/A	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

