

# ANALYTICAL REPORT

## PREPARED FOR

Attn: Mr. Erwin Kawata  
City & County of Honolulu  
630 South Beretania Street  
Public Service Bldg. Room 310  
Honolulu, Hawaii 96843

Generated 4/17/2026 3:43:56 PM

## JOB DESCRIPTION

RED-HILL  
Quarterly: Moanalua Wells

## JOB NUMBER

380-206187-1

# Eurofins Pomona

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

## Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

## Authorization



Authorized for release by  
Maria Lopez, Project Manager  
[Maria.Lopez@et.eurofinsus.com](mailto:Maria.Lopez@et.eurofinsus.com)  
(626)386-1100

Generated  
4/17/2026 3:43:56 PM



# Table of Contents

Cover Page . . . . .	1
Table of Contents . . . . .	3
Definitions/Glossary . . . . .	4
Case Narrative . . . . .	6
Detection Summary . . . . .	8
Client Sample Results . . . . .	9
Action Limit Summary . . . . .	19
Surrogate Summary . . . . .	22
QC Sample Results . . . . .	27
QC Association Summary . . . . .	75
Lab Chronicle . . . . .	81
Certification Summary . . . . .	83
Method Summary . . . . .	85
Sample Summary . . . . .	86
Chain of Custody . . . . .	87
Receipt Checklists . . . . .	93

# Definitions/Glossary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Qualifiers

### GC/MS VOA

Qualifier	Qualifier Description
*1	LCS/LCSD RPD exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

### GC/MS VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

### GC/MS Semi VOA

Qualifier	Qualifier Description
*-	LCS and/or LCSD is outside acceptance limits, low biased.
*1	LCS/LCSD RPD exceeds control limits.
F1	MS and/or MSD recovery exceeds control limits.
F2	MS/MSD RPD exceeds control limits
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

### GC/MS Semi VOA TICs

Qualifier	Qualifier Description
J	Indicates an Estimated Value for TICs
N	Presumptive evidence of material.
T	Result is a tentatively identified compound (TIC) and an estimated value.

### GC Semi VOA

Qualifier	Qualifier Description
^3+	Reporting Limit Check Standard is outside acceptance limits, high biased
F1	MS and/or MSD recovery exceeds control limits.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.
p	The %RPD between the primary and confirmation column/detector is >40%. The lower value has been reported.

### HPLC/IC

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

### Metals

Qualifier	Qualifier Description
^+	Continuing Calibration Verification (CCV) is outside acceptance limits, high biased.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

### General Chemistry

Qualifier	Qualifier Description
F1	MS and/or MSD recovery exceeds control limits.
F3	Duplicate RPD exceeds the control limit
HF	Parameter with a holding time of 15 minutes. Test performed by laboratory at client's request. Sample was analyzed outside of hold time.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample

# Definitions/Glossary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Glossary (Continued)

**Abbreviation**      **These commonly used abbreviations may or may not be present in this report.**

DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Case Narrative

Client: City & County of Honolulu  
Project: RED-HILL

Job ID: 380-206187-1

**Job ID: 380-206187-1**

**Eurofins Pomona**

## Job Narrative 380-206187-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

### Receipt

The samples were received on 4/3/2026 10:22 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 3.7°C.

### GC/MS VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### GC/MS Semi VOA

Method 625.1 SIM: The laboratory control sample and/or the laboratory control sample duplicate (LCS/LCSD) for preparation batch 570-719700 and analytical batch 570-722093 recovered outside control limits for the following analyte(s): Aniline and Benzidine. Aniline and Benzidine have been identified as a poor performing analyte when analyzed using this method; therefore, re-extraction/re-analysis was not performed.

Method 625.1 SIM: The RPD of the laboratory control sample (LCS) and laboratory control sample duplicate (LCSD) for preparation batch 570-719700 and analytical batch 570-722093 recovered outside control limits for the following analytes: Aniline. Laboratory control sample / laboratory control sample duplicate (LCS/LCSD) percent recovery is in control for affected analytes.

Method 625.1 SIM: The matrix spike/matrix spike duplicate (MS/MSD) for preparation batch 570-719700 and analytical batch 570-722093 exceeded control limits for the following analyte(s): Benzidine, Note that this analyte is a known poor performer when analyzed using this method.

Method 625.1 SIM: The matrix spike / matrix spike duplicate (MS/MSD) precision for preparation batch 570-719700 and analytical batch 570-722093 was outside control limits. Sample matrix interference and/or non-homogeneity are suspected because the associated laboratory control sample / laboratory control sample duplicate (LCS/LCSD) precision was within acceptance limits.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Gasoline Range Organics

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Diesel Range Organics

Method 8015B: Insufficient sample volume was available to perform a matrix spike/matrix spike duplicate (MS/MSD) associated with preparation batch 570-720612. The laboratory control sample (LCS) was performed in duplicate (LCSD) to provide precision data for this batch.

Method: 8015B\_LL\_CS

Method 8015B: The method reporting limit check (MRL) for Prep Batch 720612 recovered outside control limits for the following analytes C10-C28 These analytes were biased high in the MRL and were not detected in the associated samples; therefore, the data have been reported.

Method: 8015B\_DRO\_LL\_CS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

# Case Narrative

Client: City & County of Honolulu  
Project: RED-HILL

Job ID: 380-206187-1

## Job ID: 380-206187-1 (Continued)

Eurofins Pomona

### GC Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Hydrocarbons

Method 8015B: The matrix spike / matrix spike duplicate (MS/MSD) recoveries for analytical batch 570-723893 were outside control limits for one or more analytes. See QC Sample Results for detail. Sample matrix interference and/or non-homogeneity are suspected because the associated laboratory control sample (LCS) recovery is within acceptance limits.

Method 8015B: The matrix spike / matrix spike duplicate (MS/MSD) recoveries for analytical batch 570-723893 were outside control limits for one or more analytes. See QC Sample Results for detail. Sample matrix interference and/or non-homogeneity are suspected because the associated laboratory control sample (LCS) recovery is within acceptance limits.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Pesticides/PCBs

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### HPLC/IC

Method 300.0: The following sample was diluted for Nitrite as N to prevent detector saturation due to high conductivity: MOANALUA WELLS (331-223-TP202) (380-206187-1). Elevated reporting limits (RLs) are provided.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Metals

Method 200.8: The continuing calibration verification (CCV) associated with batch 380-217861 recovered above the upper control limit for Beryllium. The samples associated with this CCV were non-detects for the affected analytes; therefore, the data have been reported. The associated sample is: MOANALUA WELLS (331-223-TP202) (380-206187-1).

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### General Chemistry

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Eurofins Pomona

# Detection Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**  
**PWSID Number: HI0000331**

**Lab Sample ID: 380-206187-1**

Analyte	Result	Qualifier	RL	Unit	Dil Fac	D	Method	Prep Type
Dieldrin	0.023		0.0098	ug/L	1		525.2	Total/NA
Chlordane (n.o.s.)	0.11		0.099	ug/L	1		505	Total/NA
Bromide	260		5.0	ug/L	1		300.0	Total/NA
Chloride	100		1.0	mg/L	2		300.0	Total/NA
Nitrate as N	0.61		0.10	mg/L	2		300.0	Total/NA
Sulfate	17		0.50	mg/L	2		300.0	Total/NA
Calcium	18		0.10	mg/L	1		200.7 Rev 4.4	Total/NA
Magnesium	17		0.10	mg/L	1		200.7 Rev 4.4	Total/NA
Potassium	2.2		0.20	mg/L	1		200.7 Rev 4.4	Total/NA
Sodium	41		0.10	mg/L	1		200.7 Rev 4.4	Total/NA
Chromium	2.5		0.90	ug/L	1		200.8	Total/NA
Copper	7.2		1.0	ug/L	1		200.8	Total/NA
Alkalinity	61		2.0	mg/L	1		SM 2320B	Total/NA
Bicarbonate Alkalinity as CaCO3	61		2.0	mg/L	1		SM 2320B	Total/NA
Specific Conductance	490		2.0	umhos/cm	1		SM 2510B	Total/NA
Total Dissolved Solids	300		20	mg/L	1		SM 2540C	Total/NA
pH	8.0	HF		SU	1		SM 4500 H+ B	Total/NA

**Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-2**

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

Date Collected: 04/02/26 09:51

Matrix: Drinking Water

Date Received: 04/03/26 10:22

PWSID Number: HI0000331

**Method: EPA-DW 524.2 - Total Trihalomethanes**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Trihalomethanes, Total	<0.50		0.50	ug/L			04/05/26 18:23	1

**Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<0.50		0.50	ug/L			04/05/26 18:23	1
1,1,1-Trichloroethane	<0.50		0.50	ug/L			04/05/26 18:23	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	ug/L			04/05/26 18:23	1
1,1,2-Trichloroethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Tertiary Butyl Alcohol (TBA)	<2.0		2.0	ug/L			04/05/26 18:23	1
1,1-Dichloroethylene	<0.50		0.50	ug/L			04/05/26 18:23	1
1,1-Dichloroethane	<0.50		0.50	ug/L			04/05/26 18:23	1
1,1-Dichloropropene	<0.50		0.50	ug/L			04/05/26 18:23	1
1,2,3-Trichlorobenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
1,2,3-Trichloropropane	<0.50		0.50	ug/L			04/05/26 18:23	1
1,2,4-Trichlorobenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
1,2,4-Trimethylbenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
1,2-Dichloroethane	<0.50		0.50	ug/L			04/05/26 18:23	1
1,2-Dichloropropane	<0.50		0.50	ug/L			04/05/26 18:23	1
1,3,5-Trimethylbenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
1,3-Dichloropropane	<0.50		0.50	ug/L			04/05/26 18:23	1
1,3-Dichloropropene, Total	<0.50		0.50	ug/L			04/05/26 18:23	1
2,2-Dichloropropane	<0.50		0.50	ug/L			04/05/26 18:23	1
2-Butanone (MEK)	<5.0		5.0	ug/L			04/05/26 18:23	1
4-Methyl-2-pentanone (MIBK)	<5.0		5.0	ug/L			04/05/26 18:23	1
Acetone	<500		500	ug/L			04/08/26 00:25	1
Benzene	<0.50		0.50	ug/L			04/05/26 18:23	1
Bromobenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
Bromochloromethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Bromodichloromethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Bromoethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Bromoform	<0.50		0.50	ug/L			04/05/26 18:23	1
Bromomethane (Methyl Bromide)	<0.50		0.50	ug/L			04/05/26 18:23	1
Carbon disulfide	<0.50		0.50	ug/L			04/05/26 18:23	1
Carbon tetrachloride	<0.50		0.50	ug/L			04/05/26 18:23	1
Chlorobenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
Chlorodibromomethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Chloroethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Chloroform (Trichloromethane)	<0.50		0.50	ug/L			04/05/26 18:23	1
Chloromethane (methyl chloride)	<0.50		0.50	ug/L			04/05/26 18:23	1
cis-1,2-Dichloroethylene	<0.50		0.50	ug/L			04/05/26 18:23	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			04/05/26 18:23	1
Dibromomethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Dichlorodifluoromethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Dichloromethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Diisopropyl ether	<3.0		3.0	ug/L			04/05/26 18:23	1
Ethylbenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
Hexachlorobutadiene	<0.50		0.50	ug/L			04/05/26 18:23	1
Isopropylbenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
m,p-Xylenes	<0.50		0.50	ug/L			04/05/26 18:23	1
m-Dichlorobenzene (1,3-DCB)	<0.50		0.50	ug/L			04/05/26 18:23	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

Date Collected: 04/02/26 09:51

Matrix: Drinking Water

Date Received: 04/03/26 10:22

PWSID Number: HI0000331

**Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Methyl-tert-butyl Ether (MTBE)	<0.50		0.50	ug/L			04/05/26 18:23	1
Naphthalene	<0.50		0.50	ug/L			04/05/26 18:23	1
n-Butylbenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
N-Propylbenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
o-Chlorotoluene	<0.50		0.50	ug/L			04/05/26 18:23	1
o-Dichlorobenzene (1,2-DCB)	<0.50		0.50	ug/L			04/05/26 18:23	1
o-Xylene	<0.50		0.50	ug/L			04/05/26 18:23	1
p-Chlorotoluene	<0.50		0.50	ug/L			04/05/26 18:23	1
p-Dichlorobenzene (1,4-DCB)	<0.50		0.50	ug/L			04/05/26 18:23	1
p-Isopropyltoluene	<0.50		0.50	ug/L			04/05/26 18:23	1
sec-Butylbenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
Styrene	<0.50		0.50	ug/L			04/05/26 18:23	1
Tert-amyl methyl ether	<3.0		3.0	ug/L			04/05/26 18:23	1
Tert-butyl ethyl ether	<3.0		3.0	ug/L			04/05/26 18:23	1
tert-Butylbenzene	<0.50		0.50	ug/L			04/05/26 18:23	1
Tetrachloroethene (PCE)	<0.50		0.50	ug/L			04/05/26 18:23	1
Toluene	<0.50		0.50	ug/L			04/05/26 18:23	1
trans-1,2-Dichloroethylene	<0.50		0.50	ug/L			04/05/26 18:23	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			04/05/26 18:23	1
Trichloroethylene (TCE)	<0.50		0.50	ug/L			04/05/26 18:23	1
Trichlorofluoromethane (Freon 11)	<0.50		0.50	ug/L			04/05/26 18:23	1
Trichlorotrifluoroethane	<0.50		0.50	ug/L			04/05/26 18:23	1
Vinyl Chloride (VC)	<0.30		0.30	ug/L			04/05/26 18:23	1
Xylenes, Total	<0.50		0.50	ug/L			04/05/26 18:23	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Unknown	0.52	T J	ug/L		10.37	N/A		04/08/26 00:25	1
Tentatively Identified Compound	None		ug/L			N/A		04/05/26 18:23	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		70 - 130		04/05/26 18:23	1
1,2-Dichloroethane-d4 (Surr)	107		70 - 130		04/08/26 00:25	1
4-Bromofluorobenzene (Surr)	100		70 - 130		04/05/26 18:23	1
4-Bromofluorobenzene (Surr)	95		70 - 130		04/08/26 00:25	1
Toluene-d8 (Surr)	103		70 - 130		04/05/26 18:23	1
Toluene-d8 (Surr)	93		70 - 130		04/08/26 00:25	1
1,2-Dichloroethane-d4 (Surr)	106		70 - 130		04/05/26 18:23	1
1,2-Dichloroethane-d4 (Surr)	107		70 - 130		04/08/26 00:25	1
4-Bromofluorobenzene (Surr)	100		70 - 130		04/05/26 18:23	1
4-Bromofluorobenzene (Surr)	95		70 - 130		04/08/26 00:25	1
Toluene-d8 (Surr)	103		70 - 130		04/05/26 18:23	1
Toluene-d8 (Surr)	93		70 - 130		04/08/26 00:25	1

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
2,4'-DDD	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
2,4'-DDE	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
2,4'-DDT	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
2,4-Dinitrotoluene	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
2,6-Dinitrotoluene	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

Date Collected: 04/02/26 09:51

Matrix: Drinking Water

Date Received: 04/03/26 10:22

PWSID Number: HI0000331

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
4,4'-DDD	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
4,4'-DDE	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
4,4'-DDT	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Acenaphthene	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Acenaphthylene	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Acetochlor	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Alachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
alpha-BHC	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
alpha-Chlordane	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Anthracene	<0.020		0.020	ug/L		04/07/26 10:44	04/08/26 22:31	1
Atrazine	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Benz(a)anthracene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Benzo[a]pyrene	<0.020		0.020	ug/L		04/07/26 10:44	04/08/26 22:31	1
Benzo[b]fluoranthene	<0.020		0.020	ug/L		04/07/26 10:44	04/08/26 22:31	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Benzo[k]fluoranthene	<0.020		0.020	ug/L		04/07/26 10:44	04/08/26 22:31	1
beta-BHC	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Bis(2-ethylhexyl) phthalate	<0.59		0.59	ug/L		04/07/26 10:44	04/08/26 22:31	1
Aldrin	<0.0098		0.0098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Bromacil	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Butachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Butylbenzylphthalate	<0.49		0.49	ug/L		04/07/26 10:44	04/08/26 22:31	1
Chlorobenzilate	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Chloroneb	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Chlorothalonil (Draconil, Bravo)	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Chlorpyrifos	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Chrysene	<0.020		0.020	ug/L		04/07/26 10:44	04/08/26 22:31	1
delta-BHC	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Di(2-ethylhexyl)adipate	<0.59		0.59	ug/L		04/07/26 10:44	04/08/26 22:31	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
<b>Dieldrin</b>	<b>0.023</b>		0.0098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Diethylphthalate	<0.49		0.49	ug/L		04/07/26 10:44	04/08/26 22:31	1
Dimethylphthalate	<0.49		0.49	ug/L		04/07/26 10:44	04/08/26 22:31	1
Di-n-butyl phthalate	<0.98		0.98	ug/L		04/07/26 10:44	04/08/26 22:31	1
Di-n-octyl phthalate	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Endosulfan I (Alpha)	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Endosulfan II (Beta)	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Endosulfan sulfate	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Endrin	<0.0098		0.0098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Endrin aldehyde	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
EPTC	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Fluoranthene	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Fluorene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
gamma-BHC (Lindane)	<0.0098		0.0098	ug/L		04/07/26 10:44	04/08/26 22:31	1
gamma-Chlordane	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Heptachlor	<0.0098		0.0098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Heptachlor epoxide (isomer B)	<0.0098		0.0098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Hexachlorobenzene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

Date Collected: 04/02/26 09:51

Matrix: Drinking Water

Date Received: 04/03/26 10:22

PWSID Number: HI0000331

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Isophorone	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Malathion	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Methoxychlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Metolachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Molinate	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Naphthalene	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Parathion	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Pendimethalin (Penoxaline)	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Phenanthrene	<0.039		0.039	ug/L		04/07/26 10:44	04/08/26 22:31	1
Propachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Pyrene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Simazine	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Terbacil	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Terbutylazine	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Thiobencarb	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
Total Permethrin (mixed isomers)	<0.20		0.20	ug/L		04/07/26 10:44	04/08/26 22:31	1
trans-Nonachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 22:31	1
Trifluralin	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
1-Methylnaphthalene	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1
2-Methylnaphthalene	<0.098		0.098	ug/L		04/07/26 10:44	04/08/26 22:31	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	04/07/26 10:44	04/08/26 22:31	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	99		70 - 130	04/07/26 10:44	04/08/26 22:31	1
Perylene-d12	94		70 - 130	04/07/26 10:44	04/08/26 22:31	1
Triphenylphosphate	98		70 - 130	04/07/26 10:44	04/08/26 22:31	1

**Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
2,4,5-Trichlorophenol	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
2,4,6-Trichlorophenol	<0.96		0.96	ug/L		04/04/26 20:59	04/09/26 20:42	1
2,4-Dichlorophenol	<0.96		0.96	ug/L		04/04/26 20:59	04/09/26 20:42	1
2,4-Dinitrophenol	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
2,6-Dichlorophenol	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
2-Chloronaphthalene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
2-Chlorophenol	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
2-Methylnaphthalene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
2-Methylphenol	<0.96		0.96	ug/L		04/04/26 20:59	04/09/26 20:42	1
2-Nitroaniline	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
2-Nitrophenol	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
3/4-Methylphenol	<1.9		1.9	ug/L		04/04/26 20:59	04/09/26 20:42	1
3-Nitroaniline	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
4,6-Dinitro-2-methylphenol	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
4-Bromophenyl phenyl ether	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
4-Chloro-3-methylphenol	<0.96		0.96	ug/L		04/04/26 20:59	04/09/26 20:42	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

Date Collected: 04/02/26 09:51

Matrix: Drinking Water

Date Received: 04/03/26 10:22

PWSID Number: HI0000331

**Method: EPA 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chloroaniline	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
4-Chlorophenyl phenyl ether	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
4-Nitroaniline	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
4-Nitrophenol	<4.8		4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
Acenaphthene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Acenaphthylene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Aniline	<0.19	*- *1	0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Anthracene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Benzidine	<4.8	*-	4.8	ug/L		04/04/26 20:59	04/09/26 20:42	1
Benzo[a]anthracene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Benzo[a]pyrene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Benzo[b]fluoranthene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Benzo[g,h,i]perylene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Benzo[k]fluoranthene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Benzoic acid	<9.6		9.6	ug/L		04/04/26 20:59	04/09/26 20:42	1
Benzyl alcohol	<0.96		0.96	ug/L		04/04/26 20:59	04/09/26 20:42	1
Bis(2-chloroethoxy)methane	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Bis(2-chloroethyl)ether	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
bis (2-Chloroisopropyl) ether	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Chrysene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Dibenz(a,h)anthracene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Dibenzofuran	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Fluoranthene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Fluorene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Hexachloroethane	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Indeno[1,2,3-cd]pyrene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Naphthalene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Nitrobenzene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
N-Nitrosodi-n-propylamine	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
N-Nitrosodiphenylamine	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Pentachlorophenol	<0.96		0.96	ug/L		04/04/26 20:59	04/09/26 20:42	1
Phenanthrene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1
Phenol	<0.96		0.96	ug/L		04/04/26 20:59	04/09/26 20:42	1
Pyrene	<0.19		0.19	ug/L		04/04/26 20:59	04/09/26 20:42	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	71		28 - 127	04/04/26 20:59	04/09/26 20:42	1
2-Fluorobiphenyl (Surr)	68		31 - 120	04/04/26 20:59	04/09/26 20:42	1
2-Fluorophenol (Surr)	44		17 - 120	04/04/26 20:59	04/09/26 20:42	1
Nitrobenzene-d5 (Surr)	72		27 - 120	04/04/26 20:59	04/09/26 20:42	1
Phenol-d6 (Surr)	28		10 - 120	04/04/26 20:59	04/09/26 20:42	1
p-Terphenyl-d14 (Surr)	69		45 - 120	04/04/26 20:59	04/09/26 20:42	1

**Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS)**

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	04/04/26 20:59	04/14/26 17:27	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	68		33 - 139	04/04/26 20:59	04/14/26 17:27	1
2-Fluorobiphenyl (Surr)	68		33 - 126	04/04/26 20:59	04/14/26 17:27	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

Date Collected: 04/02/26 09:51

Matrix: Drinking Water

Date Received: 04/03/26 10:22

PWSID Number: HI0000331

**Method: EPA 625.1 - Semivolatile Organic Compounds (GC/MS) (Continued)**

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Fluorophenol (Surr)	41		12 - 120	04/04/26 20:59	04/14/26 17:27	1
Nitrobenzene-d5 (Surr)	66		36 - 120	04/04/26 20:59	04/14/26 17:27	1
Phenol-d6 (Surr)	26		10 - 120	04/04/26 20:59	04/14/26 17:27	1
p-Terphenyl-d14 (Surr)	76		47 - 131	04/04/26 20:59	04/14/26 17:27	1

**Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			04/15/26 17:13	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	107		38 - 134		04/15/26 17:13	1

**Method: EPA-DW2 504.1 - EDB, DBCP and 1,2,3-TCP (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,3-Trichloropropane	<0.020		0.020	ug/L		04/07/26 15:15	04/08/26 01:13	1
1,2-Dibromo-3-Chloropropane	<0.0098		0.0098	ug/L		04/07/26 15:15	04/08/26 01:13	1
1,2-Dibromoethane	<0.0098		0.0098	ug/L		04/07/26 15:15	04/08/26 01:13	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dibromopropane (Surr)	112		60 - 140	04/07/26 15:15	04/08/26 01:13	1

**Method: EPA 505 - Organochlorine Pesticides/PCBs (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Toxaphene	<0.50		0.50	ug/L		04/06/26 13:03	04/06/26 17:36	1
Chlordane (n.o.s.)	0.11		0.099	ug/L		04/06/26 13:03	04/06/26 17:36	1
PCB-1016	<0.069		0.069	ug/L		04/06/26 13:03	04/06/26 17:36	1
PCB-1221	<0.099		0.099	ug/L		04/06/26 13:03	04/06/26 17:36	1
PCB-1232	<0.099		0.099	ug/L		04/06/26 13:03	04/06/26 17:36	1
PCB-1242	<0.099		0.099	ug/L		04/06/26 13:03	04/06/26 17:36	1
PCB-1248	<0.099		0.099	ug/L		04/06/26 13:03	04/06/26 17:36	1
PCB-1254	<0.099		0.099	ug/L		04/06/26 13:03	04/06/26 17:36	1
PCB-1260	<0.069		0.069	ug/L		04/06/26 13:03	04/06/26 17:36	1
Polychlorinated biphenyls, Total	<0.099		0.099	ug/L		04/06/26 13:03	04/06/26 17:36	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Tetrachloro-m-xylene	88		70 - 130	04/06/26 13:03	04/06/26 17:36	1

**Method: SW846 8015B - Diesel Range Organics (DRO) (GC) Low Level**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<26		26	ug/L		04/07/26 09:29	04/07/26 23:33	1
Motor Oil Range Organics [C24-C36]	<26		26	ug/L		04/07/26 09:29	04/07/26 23:33	1
C8-C18	<26		26	ug/L		04/07/26 09:29	04/07/26 23:33	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
n-Octacosane (Surr)	112		60 - 130	04/07/26 09:29	04/07/26 23:33	1

**Method: SW846 8015B - Nonhalogenated Organic Compounds - Direct Injection (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Ethanol	<0.10		0.10	mg/L			04/14/26 15:31	1

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

Date Collected: 04/02/26 09:51

Matrix: Drinking Water

Date Received: 04/03/26 10:22

PWSID Number: HI0000331

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
Hexafluoro-2-propanol (Surr)	95		52 - 149		04/14/26 15:31	1

**Method: EPA 300.0 - Anions, Ion Chromatography**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Bromide	260		5.0	ug/L			04/08/26 21:33	1
Chloride	100		1.0	mg/L			04/03/26 22:19	2
Nitrate as N	0.61		0.10	mg/L			04/03/26 22:19	2
Nitrite as N	<0.10		0.10	mg/L			04/03/26 22:19	2
Sulfate	17		0.50	mg/L			04/03/26 22:19	2

**Method: EPA 200.7 Rev 4.4 - Metals (ICP)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Calcium	18		0.10	mg/L			04/06/26 13:33	1
Magnesium	17		0.10	mg/L			04/06/26 13:33	1
Potassium	2.2		0.20	mg/L			04/06/26 13:33	1
Sodium	41		0.10	mg/L			04/06/26 13:33	1

**Method: EPA 200.8 - Mercury (ICP/MS) - Total Recoverable**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.20		0.20	ug/L		04/07/26 09:15	04/08/26 17:52	1

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Antimony	<1.0		1.0	ug/L			04/04/26 13:00	1
Arsenic	<1.0		1.0	ug/L			04/04/26 13:00	1
Beryllium	<0.30	^+	0.30	ug/L			04/04/26 13:00	1
Cadmium	<0.50		0.50	ug/L			04/04/26 13:00	1
Chromium	2.5		0.90	ug/L			04/04/26 13:00	1
Copper	7.2		1.0	ug/L			04/04/26 13:00	1
Lead	<0.50		0.50	ug/L			04/04/26 13:00	1
Nickel	<5.0		5.0	ug/L			04/04/26 13:00	1
Selenium	<2.0		2.0	ug/L			04/04/26 13:00	1
Silver	<0.50		0.50	ug/L			04/04/26 13:00	1
Thallium	<0.30		0.30	ug/L			04/04/26 13:00	1
Zinc	<5.0		5.0	ug/L			04/04/26 13:00	1

**General Chemistry**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Alkalinity (SM 2320B)	61		2.0	mg/L			04/07/26 16:41	1
Bicarbonate Alkalinity as CaCO3 (SM 2320B)	61		2.0	mg/L			04/07/26 16:41	1
Carbonate Alkalinity as CaCO3 (SM 2320B)	<2.0		2.0	mg/L			04/07/26 16:41	1
Specific Conductance (SM 2510B)	490		2.0	umhos/cm			04/07/26 16:41	1
Total Dissolved Solids (SM 2540C)	300		20	mg/L			04/06/26 15:45	1
Fluoride (SM 4500 F C)	<0.050		0.050	mg/L			04/08/26 13:16	1
pH (SM 4500 H+ B)	8.0	HF		SU			04/07/26 16:41	1
Sulfide (SM 4500 S2 D)	<0.050		0.050	mg/L			04/06/26 15:05	1

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-2**

Date Collected: 04/02/26 09:51

Matrix: Water

Date Received: 04/03/26 10:22

**Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Tertiary Butyl Alcohol (TBA)	<2.0		2.0	ug/L			04/05/26 18:45	1
1,1,1-Trichloroethane	<0.50		0.50	ug/L			04/05/26 18:45	1
1,1,1,2,2-Tetrachloroethane	<0.50		0.50	ug/L			04/05/26 18:45	1
1,1,2-Trichloroethane	<0.50		0.50	ug/L			04/05/26 18:45	1
1,1-Dichloroethane	<0.50		0.50	ug/L			04/05/26 18:45	1
1,1-Dichlorethylene	<0.50		0.50	ug/L			04/05/26 18:45	1
1,1-Dichloropropene	<0.50		0.50	ug/L			04/05/26 18:45	1
1,2,3-Trichlorobenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
1,2,3-Trichloropropane	<0.50		0.50	ug/L			04/05/26 18:45	1
1,2,4-Trichlorobenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
1,2,4-Trimethylbenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
1,2-Dichloroethane	<0.50		0.50	ug/L			04/05/26 18:45	1
1,2-Dichloropropane	<0.50		0.50	ug/L			04/05/26 18:45	1
1,3,5-Trimethylbenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
1,3-Dichloropropane	<0.50		0.50	ug/L			04/05/26 18:45	1
2,2-Dichloropropane	<0.50		0.50	ug/L			04/05/26 18:45	1
2-Butanone (MEK)	<5.0		5.0	ug/L			04/05/26 18:45	1
4-Methyl-2-pentanone (MIBK)	<5.0		5.0	ug/L			04/05/26 18:45	1
Acetone	<500	*1	500	ug/L			04/07/26 16:10	1
Benzene	<0.50		0.50	ug/L			04/05/26 18:45	1
Bromobenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
Bromochloromethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Bromodichloromethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Bromoform	<0.50		0.50	ug/L			04/05/26 18:45	1
Bromomethane (Methyl Bromide)	<0.50		0.50	ug/L			04/05/26 18:45	1
Carbon disulfide	<0.50		0.50	ug/L			04/05/26 18:45	1
Carbon tetrachloride	<0.50		0.50	ug/L			04/05/26 18:45	1
Chlorobenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
Chlorodibromomethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Chloroethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Chloroform (Trichloromethane)	<0.50		0.50	ug/L			04/05/26 18:45	1
Dichloromethane	<0.50		0.50	ug/L			04/05/26 18:45	1
cis-1,2-Dichloroethylene	<0.50		0.50	ug/L			04/05/26 18:45	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			04/05/26 18:45	1
Dibromomethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Dichlorodifluoromethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Ethylbenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
Hexachlorobutadiene	<0.50		0.50	ug/L			04/05/26 18:45	1
Isopropylbenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
m,p-Xylenes	<0.50		0.50	ug/L			04/05/26 18:45	1
m-Dichlorobenzene (1,3-DCB)	<0.50		0.50	ug/L			04/05/26 18:45	1
Methyl-tert-butyl Ether (MTBE)	<0.50		0.50	ug/L			04/05/26 18:45	1
Naphthalene	<0.50		0.50	ug/L			04/05/26 18:45	1
n-Butylbenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
N-Propylbenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
o-Dichlorobenzene (1,2-DCB)	<0.50		0.50	ug/L			04/05/26 18:45	1
o-Chlorotoluene	<0.50		0.50	ug/L			04/05/26 18:45	1
o-Xylene	<0.50		0.50	ug/L			04/05/26 18:45	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-2**

Date Collected: 04/02/26 09:51

Matrix: Water

Date Received: 04/03/26 10:22

**Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
p-Chlorotoluene	<0.50		0.50	ug/L			04/05/26 18:45	1
p-Dichlorobenzene (1,4-DCB)	<0.50		0.50	ug/L			04/05/26 18:45	1
p-Isopropyltoluene	<0.50		0.50	ug/L			04/05/26 18:45	1
sec-Butylbenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
Styrene	<0.50		0.50	ug/L			04/05/26 18:45	1
Tert-amyl methyl ether	<3.0		3.0	ug/L			04/05/26 18:45	1
Tert-butyl ethyl ether	<3.0		3.0	ug/L			04/05/26 18:45	1
tert-Butylbenzene	<0.50		0.50	ug/L			04/05/26 18:45	1
Tetrachloroethene (PCE)	<0.50		0.50	ug/L			04/05/26 18:45	1
Toluene	<0.50		0.50	ug/L			04/05/26 18:45	1
1,3-Dichloropropene, Total	<0.50		0.50	ug/L			04/05/26 18:45	1
Xylenes, Total	<0.50		0.50	ug/L			04/05/26 18:45	1
trans-1,2-Dichloroethylene	<0.50		0.50	ug/L			04/05/26 18:45	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			04/05/26 18:45	1
Trichloroethylene (TCE)	<0.50		0.50	ug/L			04/05/26 18:45	1
Trichlorofluoromethane (Freon 11)	<0.50		0.50	ug/L			04/05/26 18:45	1
Vinyl Chloride (VC)	<0.30		0.30	ug/L			04/05/26 18:45	1
Trichlorotrifluoroethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Bromoethane	<0.50		0.50	ug/L			04/05/26 18:45	1
Chloromethane (methyl chloride)	<0.50		0.50	ug/L			04/05/26 18:45	1
Diisopropyl ether	<3.0		3.0	ug/L			04/05/26 18:45	1

Tentatively Identified Compound	Est. Result	Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Acetaldehyde	2.6	T J N	ug/L		1.30	75-07-0		04/07/26 16:10	1
Unknown	10	T J	ug/L		9.02	N/A		04/05/26 18:45	1
Furfural	14	T J N	ug/L		9.46	98-01-1		04/07/26 16:10	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		70 - 130		04/05/26 18:45	1
1,2-Dichloroethane-d4 (Surr)	104		70 - 130		04/05/26 18:45	1
1,2-Dichloroethane-d4 (Surr)	99		70 - 130		04/07/26 16:10	1
1,2-Dichloroethane-d4 (Surr)	99		70 - 130		04/07/26 16:10	1
4-Bromofluorobenzene (Surr)	103		70 - 130		04/05/26 18:45	1
4-Bromofluorobenzene (Surr)	103		70 - 130		04/05/26 18:45	1
4-Bromofluorobenzene (Surr)	103		70 - 130		04/07/26 16:10	1
4-Bromofluorobenzene (Surr)	103		70 - 130		04/07/26 16:10	1
Toluene-d8 (Surr)	104		70 - 130		04/05/26 18:45	1
Toluene-d8 (Surr)	104		70 - 130		04/05/26 18:45	1
Toluene-d8 (Surr)	89		70 - 130		04/07/26 16:10	1
Toluene-d8 (Surr)	89		70 - 130		04/07/26 16:10	1

**Method: SW846 8015B GRO LL - Gasoline Range Organics - (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			04/15/26 16:26	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	103		38 - 134		04/15/26 16:26	1

**Method: EPA-DW2 504.1 - EDB, DBCP and 1,2,3-TCP (GC)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,3-Trichloropropane	<0.020		0.020	ug/L		04/07/26 15:15	04/08/26 01:34	1

Eurofins Pomona

# Client Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-206187-1  
 SDG: Quarterly: Moanalua Wells

**Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-2**

Date Collected: 04/02/26 09:51

Matrix: Water

Date Received: 04/03/26 10:22

**Method: EPA-DW2 504.1 - EDB, DBCP and 1,2,3-TCP (GC) (Continued)**

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,2-Dibromo-3-Chloropropane	<0.0098		0.0098	ug/L		04/07/26 15:15	04/08/26 01:34	1
1,2-Dibromoethane	<0.0098		0.0098	ug/L		04/07/26 15:15	04/08/26 01:34	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
1,2-Dibromopropane (Surr)	105		60 - 140			04/07/26 15:15	04/08/26 01:34	1

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-206187-1

PWSID Number: HI0000331

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	HI Org Limit	EPAMCL Limit	EPAMCL S Limit	Method	Prep Type
Trihalomethanes, Total	<0.50		ug/L		80		524.2	Total/NA
1,1,1-Trichloroethane	<0.50		ug/L	200.0	200		524.2	Total/NA
1,1,2-Trichloroethane	<0.50		ug/L	5.000	5		524.2	Total/NA
1,1-Dichloroethylene	<0.50		ug/L	7.000	7		524.2	Total/NA
1,2,3-Trichloropropane	<0.50		ug/L	0.6000			524.2	Total/NA
1,2,4-Trichlorobenzene	<0.50		ug/L	70.00	70		524.2	Total/NA
1,2-Dichloroethane	<0.50		ug/L	5.000	5		524.2	Total/NA
1,2-Dichloropropane	<0.50		ug/L	5.000	5		524.2	Total/NA
Benzene	<0.50		ug/L	5.000	5		524.2	Total/NA
Bromodichloromethane	<0.50		ug/L		80		524.2	Total/NA
Bromoform	<0.50		ug/L		80		524.2	Total/NA
Carbon tetrachloride	<0.50		ug/L	5.000	5		524.2	Total/NA
Chlorobenzene	<0.50		ug/L	100.0	100		524.2	Total/NA
Chlorodibromomethane	<0.50		ug/L		80		524.2	Total/NA
Chloroform (Trichloromethane)	<0.50		ug/L		80		524.2	Total/NA
cis-1,2-Dichloroethylene	<0.50		ug/L	70.00	70		524.2	Total/NA
Dichloromethane	<0.50		ug/L	5.000	5		524.2	Total/NA
Ethylbenzene	<0.50		ug/L	700.0	700		524.2	Total/NA
o-Dichlorobenzene (1,2-DCB)	<0.50		ug/L	600.0	600		524.2	Total/NA
p-Dichlorobenzene (1,4-DCB)	<0.50		ug/L	75.000	75		524.2	Total/NA
Styrene	<0.50		ug/L	100.0	100		524.2	Total/NA
Tetrachloroethene (PCE)	<0.50		ug/L	5.000	5		524.2	Total/NA
Toluene	<0.50		ug/L	1000	1000		524.2	Total/NA
trans-1,2-Dichloroethylene	<0.50		ug/L	100.0	100		524.2	Total/NA
Trichloroethylene (TCE)	<0.50		ug/L	5.000	5		524.2	Total/NA
Vinyl Chloride (VC)	<0.30		ug/L	2.000	2		524.2	Total/NA
Xylenes, Total	<0.50		ug/L	10000	10000		524.2	Total/NA
Alachlor	<0.049		ug/L		2		525.2	Total/NA
Atrazine	<0.049		ug/L		3		525.2	Total/NA
Benzo[a]pyrene	<0.020		ug/L		0.2		525.2	Total/NA
Bis(2-ethylhexyl) phthalate	<0.59		ug/L		6		525.2	Total/NA
Di(2-ethylhexyl)adipate	<0.59		ug/L		400		525.2	Total/NA
Endrin	<0.0098		ug/L		2		525.2	Total/NA
gamma-BHC (Lindane)	<0.0098		ug/L		0.2		525.2	Total/NA
Heptachlor	<0.0098		ug/L		0.4		525.2	Total/NA
Heptachlor epoxide (isomer B)	<0.0098		ug/L		0.2		525.2	Total/NA
Hexachlorobenzene	<0.049		ug/L		1		525.2	Total/NA
Hexachlorocyclopentadiene	<0.049		ug/L		50		525.2	Total/NA
Methoxychlor	<0.049		ug/L		40		525.2	Total/NA
Simazine	<0.049		ug/L		4		525.2	Total/NA
Benzo[a]pyrene	<0.19		ug/L		0.2		625.1 SIM	Total/NA
Pentachlorophenol	<0.96		ug/L		1		625.1 SIM	Total/NA
1,2,3-Trichloropropane	<0.020		ug/L	0.6000			504.1	Total/NA
1,2-Dibromo-3-Chloropropane	<0.0098		ug/L		0.2		504.1	Total/NA
1,2-Dibromoethane	<0.0098		ug/L		0.05		504.1	Total/NA
Toxaphene	<0.50		ug/L		3		505	Total/NA
Chlordane (n.o.s.)	0.11		ug/L		2		505	Total/NA

Euofins Pomona

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

**(Continued)**

**PWSID Number: HI0000331**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	HI Org	EPAMCL	EPAMCL	Method	Prep Type
				Limit	Limit	S Limit		
Polychlorinated biphenyls, Total	<0.099		ug/L		0.5		505	Total/NA
Chloride	100		mg/L			250	300.0	Total/NA
Nitrate as N	0.61		mg/L		10		300.0	Total/NA
Nitrite as N	<0.10		mg/L		1		300.0	Total/NA
Sulfate	17		mg/L			250	300.0	Total/NA
Antimony	<1.0		ug/L		6		200.8	Total/NA
Arsenic	<1.0		ug/L		10		200.8	Total/NA
Beryllium	<0.30	^+	ug/L		4		200.8	Total/NA
Cadmium	<0.50		ug/L		5		200.8	Total/NA
Chromium	2.5		ug/L		100		200.8	Total/NA
Copper	7.2		ug/L		1300	1000	200.8	Total/NA
Lead	<0.50		ug/L		10.00		200.8	Total/NA
Selenium	<2.0		ug/L		50		200.8	Total/NA
Silver	<0.50		ug/L			100	200.8	Total/NA
Thallium	<0.30		ug/L		2		200.8	Total/NA
Zinc	<5.0		ug/L			5000	200.8	Total/NA
Total Dissolved Solids	300		mg/L			500	SM 2540C	Total/NA
Fluoride	<0.050		mg/L		4	2	SM 4500 F C	Total/NA
pH	8.0	HF	SU			6.5	SM 4500 H+ B	Total/NA

**Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-2**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	HI Org	EPAMCL	RL	Method	Prep Type
				Limit	Limit			
1,1,1-Trichloroethane	<0.50		ug/L	200.0	200	0.50	524.2	Total/NA
1,1,2-Trichloroethane	<0.50		ug/L	5.000	5	0.50	524.2	Total/NA
1,1-Dichloroethylene	<0.50		ug/L	7.000	7	0.50	524.2	Total/NA
1,2,3-Trichloropropane	<0.50		ug/L	0.6000		0.50	524.2	Total/NA
1,2,4-Trichlorobenzene	<0.50		ug/L	70.00	70	0.50	524.2	Total/NA
1,2-Dichloroethane	<0.50		ug/L	5.000	5	0.50	524.2	Total/NA
1,2-Dichloropropane	<0.50		ug/L	5.000	5	0.50	524.2	Total/NA
Benzene	<0.50		ug/L	5.000	5	0.50	524.2	Total/NA
Bromodichloromethane	<0.50		ug/L		80	0.50	524.2	Total/NA
Bromoform	<0.50		ug/L		80	0.50	524.2	Total/NA
Carbon tetrachloride	<0.50		ug/L	5.000	5	0.50	524.2	Total/NA
Chlorobenzene	<0.50		ug/L	100.0	100	0.50	524.2	Total/NA
Chlorodibromomethane	<0.50		ug/L		80	0.50	524.2	Total/NA
Chloroform (Trichloromethane)	<0.50		ug/L		80	0.50	524.2	Total/NA
Dichloromethane	<0.50		ug/L	5.000	5	0.50	524.2	Total/NA
cis-1,2-Dichloroethylene	<0.50		ug/L	70.00	70	0.50	524.2	Total/NA
Ethylbenzene	<0.50		ug/L	700.0	700	0.50	524.2	Total/NA
o-Dichlorobenzene (1,2-DCB)	<0.50		ug/L	600.0	600	0.50	524.2	Total/NA

Eurofins Pomona

# Action Limit Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)**  
**(Continued)**

**Lab Sample ID: 380-206187-2**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	HI Org Limit	EPAMCL Limit	RL	Method	Prep Type
p-Dichlorobenzene (1,4-DCB)	<0.50		ug/L	75.000	75	0.50	524.2	Total/NA
Styrene	<0.50		ug/L	100.0	100	0.50	524.2	Total/NA
Tetrachloroethene (PCE)	<0.50		ug/L	5.000	5	0.50	524.2	Total/NA
Toluene	<0.50		ug/L	1000	1000	0.50	524.2	Total/NA
Xylenes, Total	<0.50		ug/L	10000	10000	0.50	524.2	Total/NA
trans-1,2-Dichloroethylene	<0.50		ug/L	100.0	100	0.50	524.2	Total/NA
Trichloroethylene (TCE)	<0.50		ug/L	5.000	5	0.50	524.2	Total/NA
Vinyl Chloride (VC)	<0.30		ug/L	2.000	2	0.30	524.2	Total/NA
1,2,3-Trichloropropane	<0.020		ug/L	0.6000		0.020	504.1	Total/NA
1,2-Dibromo-3-Chloropropane	<0.0098		ug/L		0.2	0.0098	504.1	Total/NA
1,2-Dibromoethane	<0.0098		ug/L		0.05	0.0098	504.1	Total/NA

# Surrogate Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		DCA (70-130)	DCA (70-130)	BFB (70-130)	BFB (70-130)	TOL (70-130)	TOL (70-130)
380-206187-1	MOANALUA WELLS (331-223-T	106	106	100	100	103	103
380-206187-1	MOANALUA WELLS (331-223-TP202)	107	107	95	95	93	93

**Surrogate Legend**  
DCA = 1,2-Dichloroethane-d4 (Surr)  
BFB = 4-Bromofluorobenzene (Surr)  
TOL = Toluene-d8 (Surr)

## Method: 524.2 - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		DCA (70-130)	DCA (70-130)	BFB (70-130)	BFB (70-130)	TOL (70-130)	TOL (70-130)
380-206028-A-9 MSD	Matrix Spike Duplicate	102	102	96	96	101	101
380-206028-B-9 MS	Matrix Spike	102	102	104	104	100	100
380-206187-2	TB: MOANALUA WELLS (331-223-TP202)	104	104	103	103	104	104
380-206187-2	TB: MOANALUA WELLS (331-223-TP202)	99	99	103	103	89	89
LCS 380-217892/5	Lab Control Sample	102	102	100	100	103	103
LCS 380-218267/11	Lab Control Sample	99	99	103	103	104	104
LCS 380-218352/3	Lab Control Sample	105	105	90	90	99	99
LCSD 380-217892/6	Lab Control Sample Dup	103	103	95	95	101	101
LCSD 380-218267/12	Lab Control Sample Dup	110	110	101	101	90	90
LCSD 380-218352/4	Lab Control Sample Dup	102	102	100	100	98	98
MB 380-217892/8	Method Blank	104	104	98	98	103	103
MB 380-218267/15	Method Blank	112	112	102	102	90	90
MB 380-218352/5	Method Blank	110	110	98	98	88	88
MRL 380-217892/3	Lab Control Sample	105	105	98	98	102	102
MRL 380-217892/4	Lab Control Sample	103	103	101	101	102	102
MRL 380-218267/13	Lab Control Sample	103	103	102	102	92	92
MRL 380-218267/14	Lab Control Sample	102	102	98	98	98	98

**Surrogate Legend**  
DCA = 1,2-Dichloroethane-d4 (Surr)  
BFB = 4-Bromofluorobenzene (Surr)  
TOL = Toluene-d8 (Surr)

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-206187-1	MOANALUA WELLS (331-223-T	99	94	98

**Surrogate Legend**  
2NMX = 2-Nitro-m-xylene  
PRY = Perylene-d12  
TPP = Triphenylphosphate

# Surrogate Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)		
		2NMX (70-130)	PRY (70-130)	TPP (70-130)
380-204992-S-1-A DU	Duplicate	99	94	103
380-206177-S-1-A MS	Matrix Spike	98	97	103
LCS 380-218277/23-A	Lab Control Sample	97	96	105
LCS 380-218277/24-A	Lab Control Sample Dup	99	97	106
MB 380-218277/21-A	Method Blank	99	94	97
MRL 380-218277/22-A	Lab Control Sample	100	95	98

### Surrogate Legend

2NMX = 2-Nitro-m-xylene  
PRY = Perylene-d12  
TPP = Triphenylphosphate

## Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
380-206187-1	MOANALUA WELLS (331-223-T)	68	68	41	66	26	76

### Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)  
FBP = 2-Fluorobiphenyl (Surr)  
2FP = 2-Fluorophenol (Surr)  
NBZ = Nitrobenzene-d5 (Surr)  
PHL6 = Phenol-d6 (Surr)  
TPHd14 = p-Terphenyl-d14 (Surr)

## Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (33-139)	FBP (33-126)	2FP (12-120)	NBZ (36-120)	PHL6 (10-120)	TPHd14 (47-131)
MB 570-719700/1-A	Method Blank	67	69	51	71	30	74

### Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)  
FBP = 2-Fluorobiphenyl (Surr)  
2FP = 2-Fluorophenol (Surr)  
NBZ = Nitrobenzene-d5 (Surr)  
PHL6 = Phenol-d6 (Surr)  
TPHd14 = p-Terphenyl-d14 (Surr)

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-206187-1	MOANALUA WELLS (331-223-T)	71	68	44	72	28	69

### Surrogate Legend

Eurofins Pomona

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-206187-1  
 SDG: Quarterly: Moanalua Wells

TBP = 2,4,6-Tribromophenol (Surr)  
 FBP = 2-Fluorobiphenyl (Surr)  
 2FP = 2-Fluorophenol (Surr)  
 NBZ = Nitrobenzene-d5 (Surr)  
 PHL6 = Phenol-d6 (Surr)  
 TPHd14 = p-Terphenyl-d14 (Surr)

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)					
		TBP (28-127)	FBP (31-120)	2FP (17-120)	NBZ (27-120)	PHL6 (10-120)	TPHd14 (45-120)
380-205929-A-1-A MS	Matrix Spike	69	64	44	59	30	57
380-205929-B-1-A MSD	Matrix Spike Duplicate	79	70	47	62	33	64
LCS 570-719700/2-A	Lab Control Sample	83	85	64	76	42	86
LCSD 570-719700/3-A	Lab Control Sample Dup	69	74	55	66	36	77
MB 570-719700/1-A	Method Blank	72	68	48	75	31	69

### Surrogate Legend

TBP = 2,4,6-Tribromophenol (Surr)  
 FBP = 2-Fluorobiphenyl (Surr)  
 2FP = 2-Fluorophenol (Surr)  
 NBZ = Nitrobenzene-d5 (Surr)  
 PHL6 = Phenol-d6 (Surr)  
 TPHd14 = p-Terphenyl-d14 (Surr)

## Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		BFB1 (38-134)
380-206187-1	MOANALUA WELLS (331-223-T	107

### Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

## Method: 8015B GRO LL - Gasoline Range Organics - (GC)

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)
		BFB1 (38-134)
380-206187-2	TB: MOANALUA WELLS (331-2	103
380-206949-C-1 MS	Matrix Spike	104
380-206949-C-1 MSD	Matrix Spike Duplicate	102
LCS 570-724791/3	Lab Control Sample	109
LCSD 570-724791/4	Lab Control Sample Dup	105
MB 570-724791/6	Method Blank	102
MRL 570-724791/5	Lab Control Sample	102

### Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

# Surrogate Summary

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-206187-1  
 SDG: Quarterly: Moanalua Wells

## Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

Matrix: Drinking Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	DBPP1 (60-140)
380-206187-1	MOANALUA WELLS (331-223-T	112

**Surrogate Legend**

DBPP = 1,2-Dibromopropane (Surr)

## Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

Matrix: Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	DBPP1 (60-140)
380-206187-2	TB: MOANALUA WELLS (331-2	105
380-206204-BV-1-A MS	Matrix Spike	103
380-206332-BQ-1-A DU	Duplicate	110
LCS 380-218306/29-A	Lab Control Sample	106
MBL 380-218306/4-A	Method Blank	105
MRL 380-218306/2-A	Lab Control Sample	105
MRL 380-218306/3-A	Lab Control Sample	103

**Surrogate Legend**

DBPP = 1,2-Dibromopropane (Surr)

## Method: 505 - Organochlorine Pesticides/PCBs (GC)

Matrix: Drinking Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	TCX1 (70-130)
380-206187-1	MOANALUA WELLS (331-223-T	88

**Surrogate Legend**

TCX = Tetrachloro-m-xylene

## Method: 505 - Organochlorine Pesticides/PCBs (GC)

Matrix: Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	TCX1 (70-130)
380-206150-I-1-A MS	Matrix Spike	90
380-206150-J-1-A MS	Matrix Spike	96
LCS 380-218087/28-A	Lab Control Sample	93
LCS 380-218087/29-A	Lab Control Sample	99
LCS 380-218087/31-A	Lab Control Sample	93
LCS 380-218087/30-A	Lab Control Sample Dup	90
MB 380-218087/3-A	Method Blank	94
MRL 380-218087/1-A	Lab Control Sample	90
MRL 380-218087/2-A	Lab Control Sample	85

**Surrogate Legend**

TCX = Tetrachloro-m-xylene

# Surrogate Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Drinking Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
380-206187-1	MOANALUA WELLS (331-223-T	112

#### Surrogate Legend

OTCSN = n-Octacosane (Surr)

## Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

Matrix: Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	OTCSN1 (60-130)
LCS 570-720612/2-A	Lab Control Sample	115
LCSD 570-720612/3-A	Lab Control Sample Dup	111
MB 570-720612/1-A	Method Blank	109
MRL 570-720612/4-A	Lab Control Sample	110

#### Surrogate Legend

OTCSN = n-Octacosane (Surr)

## Method: 8015B - Nonhalogenated Organic Compounds - Direct Injection (GC)

Matrix: Drinking Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HF2PP1 (52-149)
380-206187-1	MOANALUA WELLS (331-223-T	95

#### Surrogate Legend

HF2PP = Hexafluoro-2-propanol (Surr)

## Method: 8015B - Nonhalogenated Organic Compounds - Direct Injection (GC)

Matrix: Water

Prep Type: Total/NA

### Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HF2PP1 (52-149)
380-207013-AB-1 MS	Matrix Spike	97 p
380-207013-AB-1 MSD	Matrix Spike Duplicate	97 p
LCS 570-723893/4	Lab Control Sample	99
LCSD 570-723893/5	Lab Control Sample Dup	101 p
MB 570-723893/3	Method Blank	98 p
MRL 570-723893/6	Lab Control Sample	97

#### Surrogate Legend

HF2PP = Hexafluoro-2-propanol (Surr)

# QC Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-206187-1  
 SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 380-217892/8  
 Matrix: Water  
 Analysis Batch: 217892

Client Sample ID: Method Blank  
 Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Tertiary Butyl Alcohol (TBA)	<2.0		2.0	ug/L			04/05/26 17:27	1
1,1,1-Trichloroethane	<0.50		0.50	ug/L			04/05/26 17:27	1
1,1,2,2-Tetrachloroethane	<0.50		0.50	ug/L			04/05/26 17:27	1
1,1,2-Trichloroethane	<0.50		0.50	ug/L			04/05/26 17:27	1
1,1-Dichloroethane	<0.50		0.50	ug/L			04/05/26 17:27	1
1,1-Dichlorethylene	<0.50		0.50	ug/L			04/05/26 17:27	1
1,1-Dichloropropene	<0.50		0.50	ug/L			04/05/26 17:27	1
1,2,3-Trichlorobenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
1,2,3-Trichloropropane	<0.50		0.50	ug/L			04/05/26 17:27	1
1,2,4-Trichlorobenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
1,2,4-Trimethylbenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
1,2-Dichloroethane	<0.50		0.50	ug/L			04/05/26 17:27	1
1,2-Dichloropropane	<0.50		0.50	ug/L			04/05/26 17:27	1
1,3,5-Trimethylbenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
1,3-Dichloropropane	<0.50		0.50	ug/L			04/05/26 17:27	1
2,2-Dichloropropane	<0.50		0.50	ug/L			04/05/26 17:27	1
2-Butanone (MEK)	<5.0		5.0	ug/L			04/05/26 17:27	1
4-Methyl-2-pentanone (MIBK)	<5.0		5.0	ug/L			04/05/26 17:27	1
Benzene	<0.50		0.50	ug/L			04/05/26 17:27	1
Bromobenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
Bromochloromethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Bromodichloromethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Bromoform	<0.50		0.50	ug/L			04/05/26 17:27	1
Bromomethane (Methyl Bromide)	<0.50		0.50	ug/L			04/05/26 17:27	1
Carbon disulfide	<0.50		0.50	ug/L			04/05/26 17:27	1
Carbon tetrachloride	<0.50		0.50	ug/L			04/05/26 17:27	1
Chlorobenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
Chlorodibromomethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Chloroethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Chloroform (Trichloromethane)	<0.50		0.50	ug/L			04/05/26 17:27	1
cis-1,2-Dichloroethylene	<0.50		0.50	ug/L			04/05/26 17:27	1
cis-1,3-Dichloropropene	<0.50		0.50	ug/L			04/05/26 17:27	1
Dibromomethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Dichlorodifluoromethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Dichloromethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Ethylbenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
Hexachlorobutadiene	<0.50		0.50	ug/L			04/05/26 17:27	1
Isopropylbenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
m,p-Xylenes	<0.50		0.50	ug/L			04/05/26 17:27	1
m-Dichlorobenzene (1,3-DCB)	<0.50		0.50	ug/L			04/05/26 17:27	1
Methyl-tert-butyl Ether (MTBE)	<0.50		0.50	ug/L			04/05/26 17:27	1
Naphthalene	<0.50		0.50	ug/L			04/05/26 17:27	1
n-Butylbenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
N-Propylbenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
o-Chlorotoluene	<0.50		0.50	ug/L			04/05/26 17:27	1
o-Dichlorobenzene (1,2-DCB)	<0.50		0.50	ug/L			04/05/26 17:27	1
o-Xylene	<0.50		0.50	ug/L			04/05/26 17:27	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MB 380-217892/8**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
p-Chlorotoluene	<0.50		0.50	ug/L			04/05/26 17:27	1
p-Dichlorobenzene (1,4-DCB)	<0.50		0.50	ug/L			04/05/26 17:27	1
p-Isopropyltoluene	<0.50		0.50	ug/L			04/05/26 17:27	1
sec-Butylbenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
Styrene	<0.50		0.50	ug/L			04/05/26 17:27	1
Tert-amyl methyl ether	<3.0		3.0	ug/L			04/05/26 17:27	1
1,3-Dichloropropene, Total	<0.50		0.50	ug/L			04/05/26 17:27	1
Tert-butyl ethyl ether	<3.0		3.0	ug/L			04/05/26 17:27	1
tert-Butylbenzene	<0.50		0.50	ug/L			04/05/26 17:27	1
Tetrachloroethene (PCE)	<0.50		0.50	ug/L			04/05/26 17:27	1
Toluene	<0.50		0.50	ug/L			04/05/26 17:27	1
trans-1,2-Dichloroethylene	<0.50		0.50	ug/L			04/05/26 17:27	1
trans-1,3-Dichloropropene	<0.50		0.50	ug/L			04/05/26 17:27	1
Trichloroethylene (TCE)	<0.50		0.50	ug/L			04/05/26 17:27	1
Bromoethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Trichlorofluoromethane (Freon 11)	<0.50		0.50	ug/L			04/05/26 17:27	1
Chloromethane (methyl chloride)	<0.50		0.50	ug/L			04/05/26 17:27	1
Trichlorotrifluoroethane	<0.50		0.50	ug/L			04/05/26 17:27	1
Diisopropyl ether	<3.0		3.0	ug/L			04/05/26 17:27	1
Vinyl Chloride (VC)	<0.30		0.30	ug/L			04/05/26 17:27	1
Xylenes, Total	<0.50		0.50	ug/L			04/05/26 17:27	1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A		04/05/26 17:27	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		70 - 130		04/05/26 17:27	1
4-Bromofluorobenzene (Surr)	98		70 - 130		04/05/26 17:27	1
Toluene-d8 (Surr)	103		70 - 130		04/05/26 17:27	1

**Lab Sample ID: LCS 380-217892/5**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	5.00	4.66		ug/L		93	70 - 130
1,1,1-Trichloroethane	5.00	4.64		ug/L		93	70 - 130
1,1,1,2-Tetrachloroethane	5.00	4.67		ug/L		93	70 - 130
1,1,2-Trichloroethane	5.00	5.03		ug/L		101	70 - 130
1,1-Dichloroethane	5.00	4.73		ug/L		95	70 - 130
1,1-Dichloroethylene	5.00	4.75		ug/L		95	70 - 130
1,1-Dichloropropene	5.00	4.69		ug/L		94	70 - 130
1,2,3-Trichlorobenzene	5.00	4.77		ug/L		95	70 - 130
1,2,3-Trichloropropane	5.00	4.94		ug/L		99	70 - 130
1,2,4-Trichlorobenzene	5.00	4.70		ug/L		94	70 - 130
1,2,4-Trimethylbenzene	5.00	5.07		ug/L		101	70 - 130
1,2-Dichloroethane	5.00	5.04		ug/L		101	70 - 130
1,2-Dichloropropane	5.00	4.88		ug/L		98	70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCS 380-217892/5**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,3,5-Trimethylbenzene	5.00	4.79		ug/L		96	70 - 130
1,3-Dichloropropane	5.00	5.08		ug/L		102	70 - 130
2,2-Dichloropropane	5.00	4.93		ug/L		99	70 - 130
2-Butanone (MEK)	50.0	41.9		ug/L		84	70 - 130
4-Methyl-2-pentanone (MIBK)	50.0	46.5		ug/L		93	70 - 130
Benzene	5.00	4.89		ug/L		98	70 - 130
Bromobenzene	5.00	4.74		ug/L		95	70 - 130
Bromochloromethane	5.00	4.75		ug/L		95	70 - 130
Bromodichloromethane	5.00	4.43		ug/L		89	70 - 130
Bromoform	5.00	4.95		ug/L		99	70 - 130
Bromomethane (Methyl Bromide)	5.00	4.74		ug/L		95	70 - 130
Carbon disulfide	5.00	3.88		ug/L		78	70 - 130
Carbon tetrachloride	5.00	4.47		ug/L		89	70 - 130
Chlorobenzene	5.00	4.88		ug/L		98	70 - 130
Chlorodibromomethane	5.00	5.00		ug/L		100	70 - 130
cis-1,3-Dichloropropene	5.00	4.99		ug/L		100	70 - 130
Dichloromethane	5.00	4.58		ug/L		92	70 - 130
Ethylbenzene	5.00	5.10		ug/L		102	70 - 130
Hexachlorobutadiene	5.00	4.81		ug/L		96	70 - 130
Isopropylbenzene	5.00	4.69		ug/L		94	70 - 130
m,p-Xylenes	10.0	10.1		ug/L		101	70 - 130
m-Dichlorobenzene (1,3-DCB)	5.00	4.84		ug/L		97	70 - 130
Methyl-tert-butyl Ether (MTBE)	5.00	4.12		ug/L		82	70 - 130
Naphthalene	5.00	4.86		ug/L		97	70 - 130
n-Butylbenzene	5.00	4.91		ug/L		98	70 - 130
N-Propylbenzene	5.00	4.75		ug/L		95	70 - 130
o-Chlorotoluene	5.00	4.97		ug/L		99	70 - 130
o-Dichlorobenzene (1,2-DCB)	5.00	4.66		ug/L		93	70 - 130
o-Xylene	5.00	4.87		ug/L		97	70 - 130
p-Chlorotoluene	5.00	4.86		ug/L		97	70 - 130
p-Dichlorobenzene (1,4-DCB)	5.00	4.73		ug/L		95	70 - 130
p-Isopropyltoluene	5.00	4.90		ug/L		98	70 - 130
sec-Butylbenzene	5.00	5.06		ug/L		101	70 - 130
Styrene	5.00	4.98		ug/L		100	70 - 130
Tert-amyl methyl ether	5.00	4.30		ug/L		86	70 - 130
1,3-Dichloropropene, Total	10.0	9.75		ug/L		98	70 - 130
Tert-butyl ethyl ether	5.00	4.50		ug/L		90	70 - 130
tert-Butylbenzene	5.00	4.84		ug/L		97	70 - 130
Tetrachloroethene (PCE)	5.00	4.83		ug/L		97	70 - 130
Toluene	5.00	4.82		ug/L		96	70 - 130
trans-1,2-Dichloroethylene	5.00	4.81		ug/L		96	70 - 130
trans-1,3-Dichloropropene	5.00	4.76		ug/L		95	70 - 130
Trichloroethylene (TCE)	5.00	4.86		ug/L		97	70 - 130
Bromoethane	5.00	4.11		ug/L		82	70 - 130
Trichlorofluoromethane (Freon 11)	5.00	6.47		ug/L		129	70 - 130
Trichlorotrifluoroethane	5.00	4.89		ug/L		98	70 - 130
Diisopropyl ether	5.00	4.10		ug/L		82	70 - 130
Vinyl Chloride (VC)	5.00	4.92		ug/L		98	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCS 380-217892/5**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Xylenes, Total	15.0	15.0		ug/L		100	70 - 130
<b>Surrogate</b>							
	<b>LCS</b>	<b>LCS</b>					<b>Limits</b>
	<b>%Recovery</b>	<b>Qualifier</b>					
1,2-Dichloroethane-d4 (Surr)	102						70 - 130
4-Bromofluorobenzene (Surr)	100						70 - 130
Toluene-d8 (Surr)	103						70 - 130

**Lab Sample ID: LCSD 380-217892/6**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	5.00	4.63		ug/L		93	70 - 130	1	20
1,1,1-Trichloroethane	5.00	4.68		ug/L		94	70 - 130	1	20
1,1,2,2-Tetrachloroethane	5.00	4.68		ug/L		94	70 - 130	0	20
1,1,2-Trichloroethane	5.00	4.91		ug/L		98	70 - 130	2	20
1,1-Dichloroethane	5.00	4.70		ug/L		94	70 - 130	1	20
1,1-Dichlorethylene	5.00	4.76		ug/L		95	70 - 130	0	20
1,1-Dichloropropene	5.00	4.65		ug/L		93	70 - 130	1	20
1,2,3-Trichlorobenzene	5.00	5.08		ug/L		102	70 - 130	6	20
1,2,3-Trichloropropane	5.00	4.84		ug/L		97	70 - 130	2	20
1,2,4-Trichlorobenzene	5.00	4.94		ug/L		99	70 - 130	5	20
1,2,4-Trimethylbenzene	5.00	4.90		ug/L		98	70 - 130	3	20
1,2-Dichloroethane	5.00	4.82		ug/L		96	70 - 130	4	20
1,2-Dichloropropane	5.00	4.87		ug/L		97	70 - 130	0	20
1,3,5-Trimethylbenzene	5.00	4.78		ug/L		96	70 - 130	0	20
1,3-Dichloropropane	5.00	4.91		ug/L		98	70 - 130	3	20
2,2-Dichloropropane	5.00	4.81		ug/L		96	70 - 130	3	20
2-Butanone (MEK)	50.0	43.9		ug/L		88	70 - 130	5	20
4-Methyl-2-pentanone (MIBK)	50.0	48.6		ug/L		97	70 - 130	4	20
Benzene	5.00	4.88		ug/L		98	70 - 130	0	20
Bromobenzene	5.00	4.57		ug/L		91	70 - 130	4	20
Bromochloromethane	5.00	4.80		ug/L		96	70 - 130	1	20
Bromodichloromethane	5.00	4.31		ug/L		86	70 - 130	3	20
Bromoform	5.00	4.85		ug/L		97	70 - 130	2	20
Bromomethane (Methyl Bromide)	5.00	4.38		ug/L		88	70 - 130	8	20
Carbon disulfide	5.00	4.14		ug/L		83	70 - 130	6	20
Carbon tetrachloride	5.00	4.39		ug/L		88	70 - 130	2	20
Chlorobenzene	5.00	4.95		ug/L		99	70 - 130	1	20
Chlorodibromomethane	5.00	4.93		ug/L		99	70 - 130	2	20
cis-1,3-Dichloropropene	5.00	4.91		ug/L		98	70 - 130	2	20
Dichloromethane	5.00	4.68		ug/L		94	70 - 130	2	20
Ethylbenzene	5.00	5.14		ug/L		103	70 - 130	1	20
Hexachlorobutadiene	5.00	5.17		ug/L		103	70 - 130	7	20
Isopropylbenzene	5.00	4.73		ug/L		95	70 - 130	1	20
m,p-Xylenes	10.0	10.1		ug/L		101	70 - 130	0	20
m-Dichlorobenzene (1,3-DCB)	5.00	4.79		ug/L		96	70 - 130	1	20
Methyl-tert-butyl Ether (MTBE)	5.00	4.22		ug/L		84	70 - 130	2	20

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCSD 380-217892/6**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Naphthalene	5.00	5.43		ug/L		109	70 - 130	11	20
n-Butylbenzene	5.00	5.16		ug/L		103	70 - 130	5	20
N-Propylbenzene	5.00	4.74		ug/L		95	70 - 130	0	20
o-Chlorotoluene	5.00	4.89		ug/L		98	70 - 130	2	20
o-Dichlorobenzene (1,2-DCB)	5.00	4.96		ug/L		99	70 - 130	6	20
o-Xylene	5.00	4.88		ug/L		98	70 - 130	0	20
p-Chlorotoluene	5.00	4.74		ug/L		95	70 - 130	2	20
p-Dichlorobenzene (1,4-DCB)	5.00	4.63		ug/L		93	70 - 130	2	20
p-Isopropyltoluene	5.00	4.82		ug/L		96	70 - 130	2	20
sec-Butylbenzene	5.00	4.94		ug/L		99	70 - 130	2	20
Styrene	5.00	4.80		ug/L		96	70 - 130	4	20
Tert-amyl methyl ether	5.00	4.26		ug/L		85	70 - 130	1	20
1,3-Dichloropropene, Total	10.0	9.70		ug/L		97	70 - 130	1	20
Tert-butyl ethyl ether	5.00	4.46		ug/L		89	70 - 130	1	20
tert-Butylbenzene	5.00	4.84		ug/L		97	70 - 130	0	20
Tetrachloroethene (PCE)	5.00	4.83		ug/L		97	70 - 130	0	20
Toluene	5.00	4.84		ug/L		97	70 - 130	1	20
trans-1,2-Dichloroethylene	5.00	4.71		ug/L		94	70 - 130	2	20
trans-1,3-Dichloropropene	5.00	4.79		ug/L		96	70 - 130	1	20
Trichloroethylene (TCE)	5.00	4.81		ug/L		96	70 - 130	1	20
Bromoethane	5.00	4.10		ug/L		82	70 - 130	0	20
Trichlorofluoromethane (Freon 11)	5.00	6.27		ug/L		125	70 - 130	3	20
Trichlorotrifluoroethane	5.00	4.66		ug/L		93	70 - 130	5	20
Diisopropyl ether	5.00	4.15		ug/L		83	70 - 130	1	20
Vinyl Chloride (VC)	5.00	4.59		ug/L		92	70 - 130	7	20
Xylenes, Total	15.0	15.0		ug/L		100	70 - 130	0	20

Surrogate	%Recovery	LCSD Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	103		70 - 130
4-Bromofluorobenzene (Surr)	95		70 - 130
Toluene-d8 (Surr)	101		70 - 130

**Lab Sample ID: MRL 380-217892/3**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
m,p-Xylenes	0.500	0.593		ug/L		119	50 - 150
Vinyl Chloride (VC)	0.250	0.290	J	ug/L		116	50 - 150

Surrogate	%Recovery	MRL Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	105		70 - 130
4-Bromofluorobenzene (Surr)	98		70 - 130
Toluene-d8 (Surr)	102		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MRL 380-217892/4**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	0.500	0.396	J	ug/L		79	50 - 150
1,1,1-Trichloroethane	0.500	0.451	J	ug/L		90	50 - 150
1,1,2,2-Tetrachloroethane	0.500	0.492	J	ug/L		98	50 - 150
1,1,2-Trichloroethane	0.500	0.463	J	ug/L		93	50 - 150
1,1-Dichloroethane	0.500	0.503		ug/L		101	50 - 150
1,1-Dichlorethylene	0.500	0.533		ug/L		107	50 - 150
1,1-Dichloropropene	0.500	0.516		ug/L		103	50 - 150
1,2,3-Trichlorobenzene	0.500	0.538		ug/L		108	50 - 150
1,2,3-Trichloropropane	0.500	0.536		ug/L		107	50 - 150
1,2,4-Trichlorobenzene	0.500	0.477	J	ug/L		95	50 - 150
1,2,4-Trimethylbenzene	0.500	0.494	J	ug/L		99	50 - 150
1,2-Dichloroethane	0.500	0.517		ug/L		103	50 - 150
1,2-Dichloropropane	0.500	0.497	J	ug/L		99	50 - 150
1,3,5-Trimethylbenzene	0.500	0.482	J	ug/L		96	50 - 150
1,3-Dichloropropane	0.500	0.493	J	ug/L		99	50 - 150
2,2-Dichloropropane	0.500	0.471	J	ug/L		94	50 - 150
2-Butanone (MEK)	5.00	3.76	J	ug/L		75	50 - 150
4-Methyl-2-pentanone (MIBK)	5.00	5.29		ug/L		106	50 - 150
Benzene	0.500	0.497	J	ug/L		99	50 - 150
Bromobenzene	0.500	0.483	J	ug/L		97	50 - 150
Bromochloromethane	0.500	0.501		ug/L		100	50 - 150
Bromodichloromethane	0.500	0.402	J	ug/L		80	50 - 150
Bromoform	0.500	0.500		ug/L		100	50 - 150
Bromomethane (Methyl Bromide)	0.500	0.558		ug/L		112	50 - 150
Carbon disulfide	0.500	0.404	J	ug/L		81	50 - 150
Carbon tetrachloride	0.500	0.438	J	ug/L		88	50 - 150
Chlorobenzene	0.500	0.477	J	ug/L		95	50 - 150
Chlorodibromomethane	0.500	0.553		ug/L		111	50 - 150
cis-1,3-Dichloropropene	0.500	0.398	J	ug/L		80	50 - 150
Dichloromethane	0.500	0.497	J	ug/L		99	50 - 150
Ethylbenzene	0.500	0.509		ug/L		102	50 - 150
Hexachlorobutadiene	0.500	0.529		ug/L		106	50 - 150
Isopropylbenzene	0.500	0.502		ug/L		100	50 - 150
m,p-Xylenes	1.00	1.02		ug/L		102	50 - 150
m-Dichlorobenzene (1,3-DCB)	0.500	0.502		ug/L		100	50 - 150
Methyl-tert-butyl Ether (MTBE)	0.500	0.479	J	ug/L		96	50 - 150
Naphthalene	0.500	0.517		ug/L		103	50 - 150
n-Butylbenzene	0.500	0.500		ug/L		100	50 - 150
N-Propylbenzene	0.500	0.518		ug/L		104	50 - 150
o-Chlorotoluene	0.500	0.499	J	ug/L		100	50 - 150
o-Dichlorobenzene (1,2-DCB)	0.500	0.490	J	ug/L		98	50 - 150
o-Xylene	0.500	0.497	J	ug/L		99	50 - 150
p-Chlorotoluene	0.500	0.511		ug/L		102	50 - 150
p-Dichlorobenzene (1,4-DCB)	0.500	0.480	J	ug/L		96	50 - 150
p-Isopropyltoluene	0.500	0.486	J	ug/L		97	50 - 150
sec-Butylbenzene	0.500	0.510		ug/L		102	50 - 150
Styrene	0.500	0.439	J	ug/L		88	50 - 150
Tert-amyl methyl ether	0.500	0.503	J	ug/L		101	50 - 150

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MRL 380-217892/4**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1,3-Dichloropropene, Total	1.00	0.769		ug/L		77	50 - 150
Tert-butyl ethyl ether	0.500	0.493	J	ug/L		99	50 - 150
tert-Butylbenzene	0.500	0.499	J	ug/L		100	50 - 150
Tetrachloroethene (PCE)	0.500	0.495	J	ug/L		99	50 - 150
Toluene	0.500	0.502		ug/L		100	50 - 150
trans-1,2-Dichloroethylene	0.500	0.500		ug/L		100	50 - 150
trans-1,3-Dichloropropene	0.500	0.371	J	ug/L		74	50 - 150
Trichloroethylene (TCE)	0.500	0.472	J	ug/L		94	50 - 150
Bromoethane	0.500	0.473	J	ug/L		95	50 - 150
Trichlorofluoromethane (Freon 11)	0.500	0.552		ug/L		110	50 - 150
Trichlorotrifluoroethane	0.500	0.535		ug/L		107	50 - 150
Diisopropyl ether	0.500	0.512	J	ug/L		102	50 - 150
Vinyl Chloride (VC)	0.500	0.503		ug/L		101	50 - 150
Xylenes, Total	1.50	1.51		ug/L		101	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	103		70 - 130
4-Bromofluorobenzene (Surr)	101		70 - 130
Toluene-d8 (Surr)	102		70 - 130

**Lab Sample ID: 380-206028-A-9 MSD**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	<0.50		10.0	10.3		ug/L		103	70 - 130	8	20
1,1,1-Trichloroethane	<0.50		10.0	10.8		ug/L		108	70 - 130	2	20
1,1,2,2-Tetrachloroethane	<0.50		10.0	9.83		ug/L		98	70 - 130	7	20
1,1,2-Trichloroethane	<0.50		10.0	10.9		ug/L		109	70 - 130	2	20
1,1-Dichloroethane	<0.50		10.0	10.4		ug/L		104	70 - 130	1	20
1,1-Dichloroethylene	<0.50		10.0	10.7		ug/L		107	70 - 130	5	20
1,1-Dichloropropene	<0.50		10.0	10.5		ug/L		105	70 - 130	4	20
1,2,3-Trichlorobenzene	<0.50		10.0	10.9		ug/L		109	70 - 130	2	20
1,2,3-Trichloropropane	<0.50		10.0	10.3		ug/L		103	70 - 130	7	20
1,2,4-Trichlorobenzene	<0.50		10.0	11.0		ug/L		110	70 - 130	4	20
1,2,4-Trimethylbenzene	<0.50		10.0	11.1		ug/L		111	70 - 130	6	20
1,2-Dichloroethane	<0.50		10.0	10.7		ug/L		107	70 - 130	2	20
1,2-Dichloropropane	<0.50		10.0	10.5		ug/L		105	70 - 130	3	20
1,3,5-Trimethylbenzene	<0.50		10.0	10.7		ug/L		107	70 - 130	6	20
1,3-Dichloropropane	<0.50		10.0	10.6		ug/L		106	70 - 130	6	20
2,2-Dichloropropane	<0.50		10.0	10.8		ug/L		108	70 - 130	10	20
2-Butanone (MEK)	<5.0		100	103		ug/L		103	70 - 130	2	20
4-Methyl-2-pentanone (MIBK)	<5.0		100	100		ug/L		100	70 - 130	7	20
Benzene	<0.50		10.0	10.8		ug/L		108	70 - 130	4	20
Bromobenzene	<0.50		10.0	10.2		ug/L		102	70 - 130	5	20
Bromochloromethane	<0.50		10.0	10.5		ug/L		105	70 - 130	4	20
Bromodichloromethane	<0.50		10.0	10.0		ug/L		100	70 - 130	1	20
Bromoform	<0.50		10.0	9.60		ug/L		96	70 - 130	5	20

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-206028-A-9 MSD**  
**Matrix: Water**  
**Analysis Batch: 217892**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Bromomethane (Methyl Bromide)	<0.50		10.0	9.92		ug/L		99	70 - 130	5	20
Carbon disulfide	<0.50		10.0	9.14		ug/L		91	70 - 130	2	20
Carbon tetrachloride	<0.50		10.0	10.6		ug/L		106	70 - 130	3	20
Chlorobenzene	<0.50		10.0	10.6		ug/L		106	70 - 130	5	20
Chlorodibromomethane	<0.50		10.0	10.5		ug/L		105	70 - 130	1	20
cis-1,3-Dichloropropene	<0.50		10.0	11.1		ug/L		111	70 - 130	3	20
Dichloromethane	<0.50		10.0	10.1		ug/L		101	70 - 130	5	20
Ethylbenzene	<0.50		10.0	11.2		ug/L		112	70 - 130	3	20
Hexachlorobutadiene	<0.50		10.0	11.5		ug/L		115	70 - 130	1	20
Isopropylbenzene	<0.50		10.0	10.7		ug/L		107	70 - 130	2	20
m,p-Xylenes	<0.50		20.0	22.4		ug/L		112	70 - 130	3	20
m-Dichlorobenzene (1,3-DCB)	<0.50		10.0	10.2		ug/L		102	70 - 130	6	20
Methyl-tert-butyl Ether (MTBE)	<0.50		10.0	8.81		ug/L		88	70 - 130	5	20
Naphthalene	<0.50		10.0	11.5		ug/L		115	70 - 130	3	20
n-Butylbenzene	<0.50		10.0	11.4		ug/L		114	70 - 130	2	20
N-Propylbenzene	<0.50		10.0	10.5		ug/L		105	70 - 130	6	20
o-Chlorotoluene	<0.50		10.0	10.6		ug/L		106	70 - 130	5	20
o-Dichlorobenzene (1,2-DCB)	<0.50		10.0	10.7		ug/L		107	70 - 130	4	20
o-Xylene	<0.50		10.0	10.7		ug/L		107	70 - 130	4	20
p-Chlorotoluene	<0.50		10.0	10.4		ug/L		104	70 - 130	6	20
p-Dichlorobenzene (1,4-DCB)	<0.50		10.0	10.1		ug/L		101	70 - 130	6	20
p-Isopropyltoluene	<0.50		10.0	10.8		ug/L		108	70 - 130	5	20
sec-Butylbenzene	<0.50		10.0	10.9		ug/L		109	70 - 130	6	20
Styrene	<0.50		10.0	11.4		ug/L		114	70 - 130	2	20
Tert-amyl methyl ether	<3.0		10.0	9.10		ug/L		91	70 - 130	5	20
1,3-Dichloropropene, Total	<0.50		20.0	22.2		ug/L		111	70 - 130	2	20
Tert-butyl ethyl ether	<3.0		10.0	9.51		ug/L		95	70 - 130	5	20
tert-Butylbenzene	<0.50		10.0	10.8		ug/L		108	70 - 130	5	20
Tetrachloroethene (PCE)	<0.50		10.0	11.1		ug/L		111	70 - 130	2	20
Toluene	<0.50		10.0	10.8		ug/L		108	70 - 130	2	20
trans-1,2-Dichloroethylene	<0.50		10.0	10.7		ug/L		107	70 - 130	4	20
trans-1,3-Dichloropropene	<0.50		10.0	11.1		ug/L		111	70 - 130	2	20
Trichloroethylene (TCE)	1.3		10.0	12.3		ug/L		111	70 - 130	4	20
Bromoethane	<0.50		10.0	9.03		ug/L		90	70 - 130	2	20
Trichlorofluoromethane (Freon 11)	<0.50		10.0	11.3		ug/L		113	70 - 130	13	20
Trichlorotrifluoroethane	<0.50		10.0	10.6		ug/L		106	70 - 130	4	20
Diisopropyl ether	<3.0		10.0	8.75		ug/L		87	70 - 130	5	20
Vinyl Chloride (VC)	<0.30		10.0	10.5		ug/L		105	70 - 130	3	20
Xylenes, Total	<0.50		30.0	33.1		ug/L		110	70 - 130	3	20

<b>Surrogate</b>	<b>MSD %Recovery</b>	<b>MSD Qualifier</b>	<b>Limits</b>
1,2-Dichloroethane-d4 (Surr)	102		70 - 130
4-Bromofluorobenzene (Surr)	96		70 - 130
Toluene-d8 (Surr)	101		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-206028-B-9 MS**

**Matrix: Water**

**Analysis Batch: 217892**

**Client Sample ID: Matrix Spike**

**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	<0.50		10.0	11.1		ug/L		111	70 - 130
1,1,1-Trichloroethane	<0.50		10.0	11.0		ug/L		110	70 - 130
1,1,2,2-Tetrachloroethane	<0.50		10.0	10.5		ug/L		105	70 - 130
1,1,2-Trichloroethane	<0.50		10.0	11.1		ug/L		111	70 - 130
1,1-Dichloroethane	<0.50		10.0	10.5		ug/L		105	70 - 130
1,1-Dichlorethylene	<0.50		10.0	11.2		ug/L		112	70 - 130
1,1-Dichloropropene	<0.50		10.0	10.9		ug/L		109	70 - 130
1,2,3-Trichlorobenzene	<0.50		10.0	10.6		ug/L		106	70 - 130
1,2,3-Trichloropropane	<0.50		10.0	11.0		ug/L		110	70 - 130
1,2,4-Trichlorobenzene	<0.50		10.0	10.6		ug/L		106	70 - 130
1,2,4-Trimethylbenzene	<0.50		10.0	11.8		ug/L		118	70 - 130
1,2-Dichloroethane	<0.50		10.0	11.0		ug/L		110	70 - 130
1,2-Dichloropropane	<0.50		10.0	10.9		ug/L		109	70 - 130
1,3,5-Trimethylbenzene	<0.50		10.0	11.4		ug/L		114	70 - 130
1,3-Dichloropropane	<0.50		10.0	11.3		ug/L		113	70 - 130
2,2-Dichloropropane	<0.50		10.0	11.9		ug/L		119	70 - 130
2-Butanone (MEK)	<5.0		100	101		ug/L		101	70 - 130
4-Methyl-2-pentanone (MIBK)	<5.0		100	107		ug/L		107	70 - 130
Benzene	<0.50		10.0	11.2		ug/L		112	70 - 130
Bromobenzene	<0.50		10.0	10.7		ug/L		107	70 - 130
Bromochloromethane	<0.50		10.0	10.9		ug/L		109	70 - 130
Bromodichloromethane	<0.50		10.0	10.1		ug/L		101	70 - 130
Bromoform	<0.50		10.0	10.0		ug/L		100	70 - 130
Bromomethane (Methyl Bromide)	<0.50		10.0	10.4		ug/L		104	70 - 130
Carbon disulfide	<0.50		10.0	9.36		ug/L		94	70 - 130
Carbon tetrachloride	<0.50		10.0	10.9		ug/L		109	70 - 130
Chlorobenzene	<0.50		10.0	11.1		ug/L		111	70 - 130
Chlorodibromomethane	<0.50		10.0	10.6		ug/L		106	70 - 130
cis-1,3-Dichloropropene	<0.50		10.0	11.3		ug/L		113	70 - 130
Dichloromethane	<0.50		10.0	10.6		ug/L		106	70 - 130
Ethylbenzene	<0.50		10.0	11.6		ug/L		116	70 - 130
Hexachlorobutadiene	<0.50		10.0	11.3		ug/L		113	70 - 130
Isopropylbenzene	<0.50		10.0	10.9		ug/L		109	70 - 130
m,p-Xylenes	<0.50		20.0	23.1		ug/L		115	70 - 130
m-Dichlorobenzene (1,3-DCB)	<0.50		10.0	10.9		ug/L		109	70 - 130
Methyl-tert-butyl Ether (MTBE)	<0.50		10.0	9.27		ug/L		93	70 - 130
Naphthalene	<0.50		10.0	11.1		ug/L		111	70 - 130
n-Butylbenzene	<0.50		10.0	11.2		ug/L		112	70 - 130
N-Propylbenzene	<0.50		10.0	11.1		ug/L		111	70 - 130
o-Chlorotoluene	<0.50		10.0	11.1		ug/L		111	70 - 130
o-Dichlorobenzene (1,2-DCB)	<0.50		10.0	10.4		ug/L		104	70 - 130
o-Xylene	<0.50		10.0	11.1		ug/L		111	70 - 130
p-Chlorotoluene	<0.50		10.0	11.0		ug/L		110	70 - 130
p-Dichlorobenzene (1,4-DCB)	<0.50		10.0	10.7		ug/L		107	70 - 130
p-Isopropyltoluene	<0.50		10.0	11.3		ug/L		113	70 - 130
sec-Butylbenzene	<0.50		10.0	11.7		ug/L		117	70 - 130
Styrene	<0.50		10.0	11.7		ug/L		117	70 - 130
Tert-amyl methyl ether	<3.0		10.0	9.54		ug/L		95	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-206028-B-9 MS**

**Matrix: Water**

**Analysis Batch: 217892**

**Client Sample ID: Matrix Spike**

**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1,3-Dichloropropene, Total	<0.50		20.0	22.6		ug/L		113	70 - 130
Tert-butyl ethyl ether	<3.0		10.0	10.0		ug/L		100	70 - 130
tert-Butylbenzene	<0.50		10.0	11.4		ug/L		114	70 - 130
Tetrachloroethene (PCE)	<0.50		10.0	11.2		ug/L		112	70 - 130
Toluene	<0.50		10.0	11.0		ug/L		110	70 - 130
trans-1,2-Dichloroethylene	<0.50		10.0	11.1		ug/L		111	70 - 130
trans-1,3-Dichloropropene	<0.50		10.0	11.3		ug/L		113	70 - 130
Trichloroethylene (TCE)	1.3		10.0	12.8		ug/L		115	70 - 130
Bromoethane	<0.50		10.0	9.24		ug/L		92	70 - 130
Trichlorofluoromethane (Freon 11)	<0.50		10.0	12.9		ug/L		129	70 - 130
Trichlorotrifluoroethane	<0.50		10.0	10.9		ug/L		109	70 - 130
Diisopropyl ether	<3.0		10.0	9.16		ug/L		92	70 - 130
Vinyl Chloride (VC)	<0.30		10.0	10.9		ug/L		109	70 - 130
Xylenes, Total	<0.50		30.0	34.2		ug/L		114	70 - 130

Surrogate	MS %Recovery	MS Qualifier	MS Limits
1,2-Dichloroethane-d4 (Surr)	102		70 - 130
4-Bromofluorobenzene (Surr)	104		70 - 130
Toluene-d8 (Surr)	100		70 - 130

**Lab Sample ID: MB 380-218267/15**

**Matrix: Water**

**Analysis Batch: 218267**

**Client Sample ID: Method Blank**

**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Acetone	<500		500	ug/L			04/07/26 15:23	1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A		04/07/26 15:23	1

Surrogate	MB %Recovery	MB Qualifier	MB Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	112		70 - 130		04/07/26 15:23	1
4-Bromofluorobenzene (Surr)	102		70 - 130		04/07/26 15:23	1
Toluene-d8 (Surr)	90		70 - 130		04/07/26 15:23	1

**Lab Sample ID: LCS 380-218267/11**

**Matrix: Water**

**Analysis Batch: 218267**

**Client Sample ID: Lab Control Sample**

**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Acetone	50.0	57.4	J	ug/L		115	70 - 130

Surrogate	LCS %Recovery	LCS Qualifier	LCS Limits
1,2-Dichloroethane-d4 (Surr)	99		70 - 130
4-Bromofluorobenzene (Surr)	103		70 - 130
Toluene-d8 (Surr)	104		70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCSD 380-218267/12**  
**Matrix: Water**  
**Analysis Batch: 218267**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Acetone	50.0	45.6	J *1	ug/L		91	70 - 130	23	20
<b>LCSD LCSD</b>									
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>						
1,2-Dichloroethane-d4 (Surr)	110		70 - 130						
4-Bromofluorobenzene (Surr)	101		70 - 130						
Toluene-d8 (Surr)	90		70 - 130						

**Lab Sample ID: MRL 380-218267/13**  
**Matrix: Water**  
**Analysis Batch: 218267**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

<b>MRL MRL</b>			
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>
1,2-Dichloroethane-d4 (Surr)	103		70 - 130
4-Bromofluorobenzene (Surr)	102		70 - 130
Toluene-d8 (Surr)	92		70 - 130

**Lab Sample ID: MRL 380-218267/14**  
**Matrix: Water**  
**Analysis Batch: 218267**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits		
Acetone	5.00	5.82	J	ug/L		116	50 - 150		
<b>MRL MRL</b>									
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>						
1,2-Dichloroethane-d4 (Surr)	102		70 - 130						
4-Bromofluorobenzene (Surr)	98		70 - 130						
Toluene-d8 (Surr)	98		70 - 130						

**Lab Sample ID: MB 380-218352/5**  
**Matrix: Water**  
**Analysis Batch: 218352**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac	
Acetone	<500		500	ug/L			04/07/26 23:38	1	
<b>MB MB</b>									
<b>Tentatively Identified Compound</b>	<b>Est. Result</b>	<b>Qualifier</b>	<b>Unit</b>	<b>D</b>	<b>RT</b>	<b>CAS No.</b>	<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
Unknown	0.610	T J	ug/L		1.44	N/A	04/07/26 23:38	1	
<b>MB MB</b>									
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>	<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>			
1,2-Dichloroethane-d4 (Surr)	110		70 - 130		04/07/26 23:38	1			
4-Bromofluorobenzene (Surr)	98		70 - 130		04/07/26 23:38	1			
Toluene-d8 (Surr)	88		70 - 130		04/07/26 23:38	1			

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCS 380-218352/3**  
**Matrix: Water**  
**Analysis Batch: 218352**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Acetone	50.0	48.9	J	ug/L		98	70 - 130
<b>LCS LCS</b>							
Surrogate	%Recovery	Qualifier	Limits				
1,2-Dichloroethane-d4 (Surr)	105		70 - 130				
4-Bromofluorobenzene (Surr)	90		70 - 130				
Toluene-d8 (Surr)	99		70 - 130				

**Lab Sample ID: LCSD 380-218352/4**  
**Matrix: Water**  
**Analysis Batch: 218352**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Acetone	50.0	47.2	J	ug/L		94	70 - 130	4	20
<b>LCSD LCSD</b>									
Surrogate	%Recovery	Qualifier	Limits						
1,2-Dichloroethane-d4 (Surr)	102		70 - 130						
4-Bromofluorobenzene (Surr)	100		70 - 130						
Toluene-d8 (Surr)	98		70 - 130						

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS)

**Lab Sample ID: MB 380-218277/21-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
2,4'-DDD	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
2,4'-DDE	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
2,4'-DDT	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
2,4-Dinitrotoluene	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
2,6-Dinitrotoluene	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
4,4'-DDD	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
4,4'-DDE	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
4,4'-DDT	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Acenaphthene	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Acenaphthylene	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Acetochlor	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Alachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
alpha-BHC	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
alpha-Chlordane	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Anthracene	<0.019		0.019	ug/L		04/07/26 10:44	04/08/26 14:01	1
Atrazine	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Benz(a)anthracene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Benzo[a]pyrene	<0.019		0.019	ug/L		04/07/26 10:44	04/08/26 14:01	1
Benzo[b]fluoranthene	<0.019		0.019	ug/L		04/07/26 10:44	04/08/26 14:01	1
Benzo[g,h,i]perylene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Benzo[k]fluoranthene	<0.019		0.019	ug/L		04/07/26 10:44	04/08/26 14:01	1
beta-BHC	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-206187-1  
 SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MB 380-218277/21-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Bis(2-ethylhexyl) phthalate	<0.58		0.58	ug/L		04/07/26 10:44	04/08/26 14:01	1
Aldrin	<0.0097		0.0097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Bromacil	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Butachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Butylbenzylphthalate	<0.49		0.49	ug/L		04/07/26 10:44	04/08/26 14:01	1
Chlorobenzilate	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Chloroneb	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Chlorothalonil (Draconil, Bravo)	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Chlorpyrifos	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Chrysene	<0.019		0.019	ug/L		04/07/26 10:44	04/08/26 14:01	1
delta-BHC	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Di(2-ethylhexyl)adipate	<0.58		0.58	ug/L		04/07/26 10:44	04/08/26 14:01	1
Dibenz(a,h)anthracene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Diclorvos (DDVP)	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Dieldrin	<0.0097		0.0097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Diethylphthalate	<0.49		0.49	ug/L		04/07/26 10:44	04/08/26 14:01	1
Dimethylphthalate	<0.49		0.49	ug/L		04/07/26 10:44	04/08/26 14:01	1
Di-n-butyl phthalate	<0.97		0.97	ug/L		04/07/26 10:44	04/08/26 14:01	1
Di-n-octyl phthalate	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Endosulfan I (Alpha)	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Endosulfan II (Beta)	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Endosulfan sulfate	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Endrin	<0.0097		0.0097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Endrin aldehyde	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
EPTC	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Fluoranthene	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Fluorene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
gamma-BHC (Lindane)	<0.0097		0.0097	ug/L		04/07/26 10:44	04/08/26 14:01	1
gamma-Chlordane	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Heptachlor	<0.0097		0.0097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Heptachlor epoxide (isomer B)	<0.0097		0.0097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Hexachlorobenzene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Hexachlorocyclopentadiene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Indeno[1,2,3-cd]pyrene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Isophorone	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Malathion	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Methoxychlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Metolachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Molinate	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Naphthalene	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Parathion	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Pendimethalin (Penoxaline)	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Phenanthrene	<0.039		0.039	ug/L		04/07/26 10:44	04/08/26 14:01	1
Propachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Pyrene	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Simazine	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Terbacil	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Terbutylazine	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
Thiobencarb	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MB 380-218277/21-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Total Permethrin (mixed isomers)	<0.19		0.19	ug/L		04/07/26 10:44	04/08/26 14:01	1
trans-Nonachlor	<0.049		0.049	ug/L		04/07/26 10:44	04/08/26 14:01	1
Trifluralin	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
1-Methylnaphthalene	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1
2-Methylnaphthalene	<0.097		0.097	ug/L		04/07/26 10:44	04/08/26 14:01	1

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Undecane	5.09	T J N	ug/L		3.13	1120-21-4	04/07/26 10:44	04/08/26 14:01	1
Cyclohexasiloxane, dodecamethyl-	0.615	T J N	ug/L		3.88	540-97-6	04/07/26 10:44	04/08/26 14:01	1
9-Octadecenamamide, (Z)-	1.38	T J N	ug/L		7.90	301-02-0	04/07/26 10:44	04/08/26 14:01	1
13-Docosenamamide, (Z)-	0.934	T J N	ug/L		10.44	112-84-5	04/07/26 10:44	04/08/26 14:01	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	99		70 - 130	04/07/26 10:44	04/08/26 14:01	1
Perylene-d12	94		70 - 130	04/07/26 10:44	04/08/26 14:01	1
Triphenylphosphate	97		70 - 130	04/07/26 10:44	04/08/26 14:01	1

**Lab Sample ID: LCS 380-218277/23-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
2,4'-DDD	1.95	2.10		ug/L		108	70 - 130
2,4'-DDE	1.95	2.12		ug/L		108	70 - 130
2,4'-DDT	1.95	2.04		ug/L		104	70 - 130
2,4-Dinitrotoluene	1.95	2.10		ug/L		108	70 - 130
2,6-Dinitrotoluene	1.95	2.00		ug/L		103	70 - 130
4,4'-DDD	1.95	2.22		ug/L		114	70 - 130
4,4'-DDE	1.95	1.84		ug/L		94	70 - 130
4,4'-DDT	1.95	2.26		ug/L		116	70 - 130
Acenaphthene	1.95	1.91		ug/L		98	70 - 130
Acenaphthylene	1.95	2.08		ug/L		106	70 - 130
Acetochlor	1.95	2.21		ug/L		114	70 - 130
Alachlor	1.95	2.26		ug/L		116	70 - 130
alpha-BHC	1.95	1.96		ug/L		101	70 - 130
alpha-Chlordane	1.95	2.03		ug/L		104	70 - 130
Anthracene	1.95	2.06		ug/L		106	70 - 130
Atrazine	1.95	2.15		ug/L		110	70 - 130
Benz(a)anthracene	1.95	2.07		ug/L		106	70 - 130
Benzo[a]pyrene	1.95	2.10		ug/L		108	70 - 130
Benzo[b]fluoranthene	1.95	2.17		ug/L		111	70 - 130
Benzo[g,h,i]perylene	1.95	1.91		ug/L		98	70 - 130
Benzo[k]fluoranthene	1.95	1.97		ug/L		101	70 - 130
beta-BHC	1.95	2.07		ug/L		106	70 - 130
Bis(2-ethylhexyl) phthalate	1.95	1.99		ug/L		102	70 - 130
Aldrin	1.95	1.93		ug/L		99	70 - 130
Bromacil	1.95	2.01		ug/L		103	70 - 130
Butachlor	1.95	2.31		ug/L		118	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCS 380-218277/23-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Butylbenzylphthalate	1.95	2.22		ug/L		114	70 - 130
Chlorobenzilate	1.95	2.17		ug/L		111	70 - 130
Chloroneb	1.95	2.00		ug/L		103	70 - 130
Chlorothalonil (Draconil, Bravo)	1.95	2.02		ug/L		104	70 - 130
Chlorpyrifos	1.95	2.29		ug/L		117	70 - 130
Chrysene	1.95	2.19		ug/L		112	70 - 130
delta-BHC	1.95	1.97		ug/L		101	70 - 130
Di(2-ethylhexyl)adipate	1.95	2.12		ug/L		109	70 - 130
Dibenz(a,h)anthracene	1.95	1.92		ug/L		98	70 - 130
Diclorvos (DDVP)	1.95	2.12		ug/L		109	70 - 130
Dieldrin	1.95	2.11		ug/L		108	70 - 130
Diethylphthalate	1.95	2.21		ug/L		113	70 - 130
Dimethylphthalate	1.95	2.08		ug/L		107	70 - 130
Di-n-butyl phthalate	3.90	4.15		ug/L		106	70 - 130
Di-n-octyl phthalate	1.95	1.96		ug/L		100	70 - 130
Endosulfan I (Alpha)	1.95	2.07		ug/L		106	70 - 130
Endosulfan II (Beta)	1.95	2.05		ug/L		105	70 - 130
Endosulfan sulfate	1.95	1.98		ug/L		101	70 - 130
Endrin	1.95	2.34		ug/L		120	70 - 130
Endrin aldehyde	1.95	2.06		ug/L		105	60 - 130
EPTC	1.95	2.12		ug/L		109	70 - 130
Fluoranthene	1.95	2.18		ug/L		112	70 - 130
Fluorene	1.95	2.04		ug/L		104	70 - 130
gamma-BHC (Lindane)	1.95	2.22		ug/L		114	70 - 130
gamma-Chlordane	1.95	2.11		ug/L		108	70 - 130
Heptachlor	1.95	1.97		ug/L		101	70 - 130
Heptachlor epoxide (isomer B)	1.95	1.98		ug/L		102	70 - 130
Hexachlorobenzene	1.95	1.86		ug/L		95	70 - 130
Hexachlorocyclopentadiene	1.95	1.85		ug/L		95	70 - 130
Indeno[1,2,3-cd]pyrene	1.95	1.97		ug/L		101	70 - 130
Isophorone	1.95	2.03		ug/L		104	70 - 130
Malathion	1.95	2.10		ug/L		108	70 - 130
Methoxychlor	1.95	2.28		ug/L		117	70 - 130
Metolachlor	1.95	2.27		ug/L		116	70 - 130
Molinate	1.95	2.18		ug/L		112	70 - 130
Naphthalene	1.95	2.01		ug/L		103	70 - 130
Parathion	1.95	2.29		ug/L		117	70 - 130
Pendimethalin (Penoxaline)	1.95	2.15		ug/L		110	70 - 130
Phenanthrene	1.95	1.95		ug/L		100	70 - 130
Propachlor	1.95	2.26		ug/L		116	70 - 130
Pyrene	1.95	2.25		ug/L		115	70 - 130
Simazine	1.95	2.05		ug/L		105	70 - 130
Terbacil	1.95	2.10		ug/L		108	70 - 130
Terbutylazine	1.95	2.13		ug/L		109	70 - 130
Thiobencarb	1.95	2.22		ug/L		114	70 - 130
trans-Nonachlor	1.95	2.00		ug/L		103	70 - 130
Trifluralin	1.95	1.93		ug/L		99	70 - 130
1-Methylnaphthalene	1.95	1.86		ug/L		95	70 - 130
2-Methylnaphthalene	1.95	1.95		ug/L		100	70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
2-Nitro-m-xylene	97		70 - 130
Perylene-d12	96		70 - 130
Triphenylphosphate	105		70 - 130

**Lab Sample ID: LCSD 380-218277/24-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	Limit
							Limits	RPD		
2,4'-DDD	1.95	2.13		ug/L		109	70 - 130	1		20
2,4'-DDE	1.95	2.14		ug/L		110	70 - 130	1		20
2,4'-DDT	1.95	2.05		ug/L		105	70 - 130	1		20
2,4-Dinitrotoluene	1.95	2.04		ug/L		105	70 - 130	3		20
2,6-Dinitrotoluene	1.95	2.01		ug/L		103	70 - 130	1		20
4,4'-DDD	1.95	2.24		ug/L		115	70 - 130	1		20
4,4'-DDE	1.95	1.86		ug/L		95	70 - 130	1		20
4,4'-DDT	1.95	2.24		ug/L		115	70 - 130	1		20
Acenaphthene	1.95	1.92		ug/L		99	70 - 130	0		20
Acenaphthylene	1.95	2.04		ug/L		105	70 - 130	2		20
Acetochlor	1.95	2.27		ug/L		116	70 - 130	2		20
Alachlor	1.95	2.30		ug/L		118	70 - 130	2		20
alpha-BHC	1.95	2.00		ug/L		102	70 - 130	2		20
alpha-Chlordane	1.95	2.12		ug/L		109	70 - 130	4		20
Anthracene	1.95	2.03		ug/L		104	70 - 130	1		20
Atrazine	1.95	2.17		ug/L		111	70 - 130	1		20
Benz(a)anthracene	1.95	2.06		ug/L		106	70 - 130	1		20
Benzo[a]pyrene	1.95	2.13		ug/L		109	70 - 130	1		20
Benzo[b]fluoranthene	1.95	2.16		ug/L		111	70 - 130	1		20
Benzo[g,h,i]perylene	1.95	2.00		ug/L		103	70 - 130	5		20
Benzo[k]fluoranthene	1.95	2.00		ug/L		103	70 - 130	2		20
beta-BHC	1.95	2.13		ug/L		109	70 - 130	3		20
Bis(2-ethylhexyl) phthalate	1.95	2.00		ug/L		103	70 - 130	1		20
Aldrin	1.95	1.96		ug/L		100	70 - 130	2		20
Bromacil	1.95	1.97		ug/L		101	70 - 130	2		20
Butachlor	1.95	2.39		ug/L		122	70 - 130	3		20
Butylbenzylphthalate	1.95	2.24		ug/L		115	70 - 130	1		20
Chlorobenzilate	1.95	2.20		ug/L		113	70 - 130	2		20
Chloroneb	1.95	2.04		ug/L		105	70 - 130	2		20
Chlorothalonil (Draconil, Bravo)	1.95	2.11		ug/L		108	70 - 130	4		20
Chlorpyrifos	1.95	2.35		ug/L		121	70 - 130	3		20
Chrysene	1.95	2.18		ug/L		112	70 - 130	0		20
delta-BHC	1.95	1.98		ug/L		102	70 - 130	1		20
Di(2-ethylhexyl)adipate	1.95	2.13		ug/L		109	70 - 130	1		20
Dibenz(a,h)anthracene	1.95	1.98		ug/L		102	70 - 130	3		20
Diclorvos (DDVP)	1.95	2.11		ug/L		108	70 - 130	0		20
Dieldrin	1.95	2.21		ug/L		113	70 - 130	5		20
Diethylphthalate	1.95	2.24		ug/L		115	70 - 130	2		20
Dimethylphthalate	1.95	2.11		ug/L		108	70 - 130	1		20
Di-n-butyl phthalate	3.90	4.22		ug/L		108	70 - 130	2		20
Di-n-octyl phthalate	1.95	2.00		ug/L		102	70 - 130	2		20
Endosulfan I (Alpha)	1.95	2.13		ug/L		109	70 - 130	3		20

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: LCSD 380-218277/24-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	Limit
							Limits	RPD		
Endosulfan II (Beta)	1.95	2.09		ug/L		107	70 - 130	2	20	
Endosulfan sulfate	1.95	2.03		ug/L		104	70 - 130	3	20	
Endrin	1.95	2.36		ug/L		121	70 - 130	1	20	
Endrin aldehyde	1.95	2.10		ug/L		108	60 - 130	2	20	
EPTC	1.95	2.19		ug/L		112	70 - 130	3	20	
Fluoranthene	1.95	2.21		ug/L		113	70 - 130	1	20	
Fluorene	1.95	2.04		ug/L		104	70 - 130	0	20	
gamma-BHC (Lindane)	1.95	2.25		ug/L		115	70 - 130	1	20	
gamma-Chlordane	1.95	2.19		ug/L		112	70 - 130	4	20	
Heptachlor	1.95	2.00		ug/L		103	70 - 130	2	20	
Heptachlor epoxide (isomer B)	1.95	2.08		ug/L		107	70 - 130	5	20	
Hexachlorobenzene	1.95	1.87		ug/L		96	70 - 130	1	20	
Hexachlorocyclopentadiene	1.95	1.80		ug/L		93	70 - 130	3	20	
Indeno[1,2,3-cd]pyrene	1.95	2.03		ug/L		104	70 - 130	3	20	
Isophorone	1.95	2.12		ug/L		109	70 - 130	4	20	
Malathion	1.95	2.16		ug/L		111	70 - 130	3	20	
Methoxychlor	1.95	2.24		ug/L		115	70 - 130	2	20	
Metolachlor	1.95	2.35		ug/L		120	70 - 130	4	20	
Molinate	1.95	2.22		ug/L		114	70 - 130	2	20	
Naphthalene	1.95	2.06		ug/L		105	70 - 130	2	20	
Parathion	1.95	2.31		ug/L		119	70 - 130	1	20	
Pendimethalin (Penoxaline)	1.95	2.16		ug/L		111	70 - 130	0	20	
Phenanthrene	1.95	1.94		ug/L		100	70 - 130	0	20	
Propachlor	1.95	2.33		ug/L		119	70 - 130	3	20	
Pyrene	1.95	2.28		ug/L		117	70 - 130	1	20	
Simazine	1.95	2.04		ug/L		105	70 - 130	1	20	
Terbacil	1.95	2.03		ug/L		104	70 - 130	4	20	
Terbutylazine	1.95	2.16		ug/L		111	70 - 130	1	20	
Thiobencarb	1.95	2.26		ug/L		116	70 - 130	2	20	
trans-Nonachlor	1.95	2.08		ug/L		107	70 - 130	4	20	
Trifluralin	1.95	1.99		ug/L		102	70 - 130	3	20	
1-Methylnaphthalene	1.95	1.89		ug/L		97	70 - 130	2	20	
2-Methylnaphthalene	1.95	1.97		ug/L		101	70 - 130	1	20	

Surrogate	LCSD		Limits
	%Recovery	Qualifier	
2-Nitro-m-xylene	99		70 - 130
Perylene-d12	97		70 - 130
Triphenylphosphate	106		70 - 130

**Lab Sample ID: MRL 380-218277/22-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec	
							Limits	RPD
2,4'-DDD	0.0975	0.0922	J	ug/L		95	50 - 150	
2,4'-DDE	0.0975	0.0976	J	ug/L		100	50 - 150	
2,4'-DDT	0.0975	0.109		ug/L		111	50 - 150	
2,4-Dinitrotoluene	0.0975	0.112		ug/L		115	50 - 150	

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MRL 380-218277/22-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
2,6-Dinitrotoluene	0.0975	0.114		ug/L		116	50 - 150
4,4'-DDD	0.0975	0.110		ug/L		113	50 - 150
4,4'-DDE	0.0975	0.0922	J	ug/L		95	50 - 150
4,4'-DDT	0.0975	0.119		ug/L		122	50 - 150
Acenaphthene	0.0975	0.0984		ug/L		101	50 - 150
Acenaphthylene	0.0975	0.0907	J	ug/L		93	50 - 150
Acetochlor	0.0975	0.109		ug/L		112	50 - 150
Alachlor	0.0488	0.0518		ug/L		106	50 - 150
alpha-BHC	0.0975	0.0930	J	ug/L		95	50 - 150
alpha-Chlordane	0.0244	<0.028		ug/L		96	50 - 150
Anthracene	0.0195	0.0213		ug/L		109	50 - 150
Atrazine	0.0488	0.0530		ug/L		109	50 - 150
Benz(a)anthracene	0.0488	0.0500		ug/L		103	50 - 150
Benzo[a]pyrene	0.0195	0.0233		ug/L		120	50 - 150
Benzo[b]fluoranthene	0.0195	0.0256		ug/L		131	50 - 150
Benzo[g,h,i]perylene	0.0488	0.0495		ug/L		101	50 - 150
Benzo[k]fluoranthene	0.0195	0.0234		ug/L		120	50 - 150
beta-BHC	0.0975	0.103		ug/L		106	50 - 150
Bis(2-ethylhexyl) phthalate	0.585	0.605		ug/L		103	50 - 150
Aldrin	0.00975	<0.0098		ug/L		90	50 - 150
Bromacil	0.0975	0.111		ug/L		114	50 - 150
Butachlor	0.0488	0.0560		ug/L		115	50 - 150
Butylbenzylphthalate	0.488	0.537		ug/L		110	50 - 150
Chlorobenzilate	0.0975	0.100		ug/L		103	50 - 150
Chloroneb	0.0975	0.0958	J	ug/L		98	50 - 150
Chlorothalonil (Draconil, Bravo)	0.0975	0.103		ug/L		106	50 - 150
Chlorpyrifos	0.0488	0.0472	J	ug/L		97	50 - 150
Chrysene	0.0195	0.0221		ug/L		113	50 - 150
delta-BHC	0.0975	0.0954	J	ug/L		98	50 - 150
Di(2-ethylhexyl)adipate	0.585	0.601		ug/L		103	50 - 150
Dibenz(a,h)anthracene	0.0488	0.0503		ug/L		103	50 - 150
Diclorvos (DDVP)	0.0488	0.0602		ug/L		124	50 - 150
Dieldrin	0.00975	0.0115		ug/L		117	50 - 150
Diethylphthalate	0.488	0.525		ug/L		108	50 - 150
Dimethylphthalate	0.488	0.506		ug/L		104	50 - 150
Di-n-butyl phthalate	0.488	0.507	J	ug/L		104	49 - 243
Di-n-octyl phthalate	0.0975	0.101		ug/L		104	50 - 150
Endosulfan I (Alpha)	0.0975	0.0885	J	ug/L		91	50 - 150
Endosulfan II (Beta)	0.0975	0.106		ug/L		108	50 - 150
Endosulfan sulfate	0.0975	0.107		ug/L		110	50 - 150
Endrin	0.00975	0.0121		ug/L		124	50 - 150
Endrin aldehyde	0.0975	0.106		ug/L		109	50 - 150
EPTC	0.0975	0.0933	J	ug/L		96	50 - 150
Fluoranthene	0.0975	0.0867	J	ug/L		89	50 - 150
Fluorene	0.0488	0.0490		ug/L		100	50 - 150
gamma-BHC (Lindane)	0.00975	0.0134		ug/L		137	50 - 150
gamma-Chlordane	0.0244	0.0260	J	ug/L		107	50 - 150
Heptachlor	0.00975	0.0122		ug/L		125	50 - 150
Heptachlor epoxide (isomer B)	0.00975	0.00961	J	ug/L		99	50 - 150

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: MRL 380-218277/22-A**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Hexachlorobenzene	0.0488	0.0434	J	ug/L		89	50 - 150
Hexachlorocyclopentadiene	0.0488	0.0541		ug/L		111	50 - 150
Indeno[1,2,3-cd]pyrene	0.0488	0.0546		ug/L		112	50 - 150
Isophorone	0.0975	0.116		ug/L		119	50 - 150
Malathion	0.0975	0.101		ug/L		104	50 - 150
Methoxychlor	0.0488	0.0604		ug/L		124	50 - 150
Metolachlor	0.0488	0.0571		ug/L		117	50 - 150
Molinate	0.0975	0.101		ug/L		104	50 - 150
Naphthalene	0.0975	0.0964	J	ug/L		99	50 - 150
Parathion	0.0975	0.102		ug/L		105	50 - 150
Pendimethalin (Penoxaline)	0.0975	0.106		ug/L		108	50 - 150
Phenanthrene	0.0390	0.0412		ug/L		106	50 - 150
Propachlor	0.0488	0.0526		ug/L		108	50 - 150
Pyrene	0.0488	0.0442	J	ug/L		91	50 - 150
Simazine	0.0488	0.0513		ug/L		105	50 - 150
Terbacil	0.0975	0.112		ug/L		115	50 - 150
Terbutylazine	0.0975	0.0992		ug/L		102	50 - 150
Thiobencarb	0.0975	0.108		ug/L		111	50 - 150
trans-Nonachlor	0.0244	0.0289	J	ug/L		118	50 - 150
Trifluralin	0.0975	0.102		ug/L		104	50 - 150
1-Methylnaphthalene	0.0975	0.119		ug/L		122	50 - 150
2-Methylnaphthalene	0.0975	0.110		ug/L		113	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
2-Nitro-m-xylene	100		70 - 130
Perylene-d12	95		70 - 130
Triphenylphosphate	98		70 - 130

**Lab Sample ID: 380-206177-S-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
2,4'-DDD	<0.099		1.94	2.05		ug/L		106	70 - 130
2,4'-DDE	<0.099		1.94	2.03		ug/L		104	70 - 130
2,4'-DDT	<0.099		1.94	1.88		ug/L		97	70 - 130
2,4-Dinitrotoluene	<0.099		1.94	2.04		ug/L		105	70 - 130
2,6-Dinitrotoluene	<0.099		1.94	1.99		ug/L		103	70 - 130
4,4'-DDD	<0.099		1.94	2.17		ug/L		112	70 - 130
4,4'-DDE	<0.099		1.94	1.68		ug/L		86	70 - 130
4,4'-DDT	<0.099		1.94	2.04		ug/L		105	70 - 130
Acenaphthene	<0.099		1.94	1.92		ug/L		99	70 - 130
Acenaphthylene	<0.099		1.94	2.00		ug/L		103	70 - 130
Acetochlor	<0.099		1.94	2.24		ug/L		115	70 - 130
Alachlor	<0.049		1.94	2.25		ug/L		116	70 - 130
alpha-BHC	<0.099		1.94	1.99		ug/L		102	70 - 130
alpha-Chlordane	<0.049		1.94	2.05		ug/L		104	70 - 130
Anthracene	<0.020		1.94	1.99		ug/L		103	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-206177-S-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Atrazine	<0.049		1.94	2.17		ug/L		111	70 - 130
Benz(a)anthracene	<0.049		1.94	2.01		ug/L		103	70 - 130
Benzo[a]pyrene	<0.020		1.94	2.09		ug/L		108	70 - 130
Benzo[b]fluoranthene	<0.020		1.94	2.11		ug/L		109	70 - 130
Benzo[g,h,i]perylene	<0.049		1.94	1.91		ug/L		98	70 - 130
Benzo[k]fluoranthene	<0.020		1.94	1.96		ug/L		101	70 - 130
beta-BHC	<0.099		1.94	2.09		ug/L		108	70 - 130
Bis(2-ethylhexyl) phthalate	<0.59		1.94	1.64		ug/L		84	70 - 130
Aldrin	<0.0099		1.94	1.96		ug/L		101	70 - 130
Bromacil	<0.099		1.94	2.09		ug/L		108	70 - 130
Butachlor	<0.049		1.94	2.31		ug/L		119	70 - 130
Butylbenzylphthalate	<0.49		1.94	2.18		ug/L		112	70 - 130
Chlorobenzilate	<0.099		1.94	2.16		ug/L		111	70 - 130
Chloroneb	<0.099		1.94	2.05		ug/L		106	70 - 130
Chlorothalonil (Draconil, Bravo)	<0.099		1.94	2.07		ug/L		107	70 - 130
Chlorpyrifos	<0.049		1.94	2.29		ug/L		118	70 - 130
Chrysene	<0.020		1.94	2.19		ug/L		113	70 - 130
delta-BHC	<0.099		1.94	1.96		ug/L		101	70 - 130
Di(2-ethylhexyl)adipate	<0.59		1.94	1.77		ug/L		91	70 - 130
Dibenz(a,h)anthracene	<0.049		1.94	1.87		ug/L		96	70 - 130
Diclorvos (DDVP)	<0.049		1.94	2.07		ug/L		107	70 - 130
Dieldrin	0.038		1.94	2.21		ug/L		112	70 - 130
Diethylphthalate	<0.49		1.94	2.24		ug/L		115	70 - 130
Dimethylphthalate	<0.49		1.94	2.10		ug/L		108	70 - 130
Di-n-butyl phthalate	<0.99		3.89	4.19		ug/L		108	70 - 130
Di-n-octyl phthalate	<0.099		1.94	1.60		ug/L		82	70 - 130
Endosulfan I (Alpha)	<0.099		1.94	2.10		ug/L		108	70 - 130
Endosulfan II (Beta)	<0.099		1.94	2.03		ug/L		105	70 - 130
Endosulfan sulfate	<0.099		1.94	2.00		ug/L		103	70 - 130
Endrin	<0.0099		1.94	2.32		ug/L		120	70 - 130
Endrin aldehyde	<0.099		1.94	2.00		ug/L		103	60 - 130
EPTC	<0.099		1.94	2.14		ug/L		110	70 - 130
Fluoranthene	<0.099		1.94	2.18		ug/L		112	70 - 130
Fluorene	<0.049		1.94	2.03		ug/L		105	70 - 130
gamma-BHC (Lindane)	<0.0099		1.94	2.25		ug/L		116	70 - 130
gamma-Chlordane	<0.049		1.94	2.12		ug/L		108	70 - 130
Heptachlor	<0.0099		1.94	1.97		ug/L		101	70 - 130
Heptachlor epoxide (isomer B)	0.012		1.94	2.01		ug/L		103	70 - 130
Hexachlorobenzene	<0.049		1.94	1.85		ug/L		95	70 - 130
Hexachlorocyclopentadiene	<0.049		1.94	1.82		ug/L		94	70 - 130
Indeno[1,2,3-cd]pyrene	<0.049		1.94	1.96		ug/L		101	70 - 130
Isophorone	<0.099		1.94	2.08		ug/L		107	70 - 130
Malathion	<0.099		1.94	2.10		ug/L		108	70 - 130
Methoxychlor	<0.049		1.94	2.28		ug/L		117	70 - 130
Metolachlor	<0.049		1.94	2.29		ug/L		118	70 - 130
Molinate	<0.099		1.94	2.18		ug/L		112	70 - 130
Naphthalene	<0.099		1.94	2.06		ug/L		106	70 - 130
Parathion	<0.099		1.94	2.23		ug/L		115	70 - 130
Pendimethalin (Penoxaline)	<0.099		1.94	2.09		ug/L		108	70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-206177-S-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
Phenanthrene	<0.039		1.94	1.92		ug/L		99	70 - 130
Propachlor	<0.049		1.94	2.30		ug/L		118	70 - 130
Pyrene	<0.049		1.94	2.25		ug/L		116	70 - 130
Simazine	<0.049		1.94	2.03		ug/L		105	70 - 130
Terbacil	<0.099		1.94	2.00		ug/L		103	70 - 130
Terbutylazine	<0.099		1.94	2.13		ug/L		110	70 - 130
Thiobencarb	<0.099		1.94	2.20		ug/L		113	70 - 130
trans-Nonachlor	<0.049		1.94	1.97		ug/L		100	70 - 130
Trifluralin	<0.099		1.94	1.95		ug/L		100	70 - 130
1-Methylnaphthalene	<0.099		1.94	1.90		ug/L		96	70 - 130
2-Methylnaphthalene	<0.099		1.94	1.95		ug/L		99	70 - 130
		<b>MS</b>	<b>MS</b>						
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>						
2-Nitro-m-xylene	98		70 - 130						
Perylene-d12	97		70 - 130						
Triphenylphosphate	103		70 - 130						

**Lab Sample ID: 380-204992-S-1-A DU**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Sample	Sample	DU	DU	Unit	D	RPD	RPD Limit
	Result	Qualifier	Result	Qualifier				
2,4'-DDD	<0.096		<0.096		ug/L		NC	20
2,4'-DDE	<0.096		<0.096		ug/L		NC	20
2,4'-DDT	<0.096		<0.096		ug/L		NC	20
2,4-Dinitrotoluene	<0.096		<0.096		ug/L		NC	20
2,6-Dinitrotoluene	<0.096		<0.096		ug/L		NC	20
4,4'-DDD	<0.096		<0.096		ug/L		NC	20
4,4'-DDE	<0.096		<0.096		ug/L		NC	20
4,4'-DDT	<0.096		<0.096		ug/L		NC	20
Acenaphthene	<0.096		<0.096		ug/L		NC	20
Acenaphthylene	<0.096		<0.096		ug/L		NC	20
Acetochlor	<0.096		<0.096		ug/L		NC	20
Alachlor	<0.048		<0.048		ug/L		NC	20
alpha-BHC	<0.096		<0.096		ug/L		NC	20
alpha-Chlordane	<0.048		<0.048		ug/L		NC	20
Anthracene	<0.019		<0.019		ug/L		NC	20
Atrazine	<0.048		<0.048		ug/L		NC	20
Benz(a)anthracene	<0.048		<0.048		ug/L		NC	20
Benzo[a]pyrene	<0.019		<0.019		ug/L		NC	20
Benzo[b]fluoranthene	<0.019		<0.019		ug/L		NC	20
Benzo[g,h,i]perylene	<0.048		<0.048		ug/L		NC	20
Benzo[k]fluoranthene	<0.019		<0.019		ug/L		NC	20
beta-BHC	<0.096		<0.096		ug/L		NC	20
Bis(2-ethylhexyl) phthalate	<0.58		<0.58		ug/L		NC	20
Aldrin	<0.0096		<0.0096		ug/L		NC	20
Bromacil	<0.096		<0.096		ug/L		NC	20
Butachlor	<0.048		<0.048		ug/L		NC	20

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-204992-S-1-A DU**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
Butylbenzylphthalate	<0.48		<0.48		ug/L		NC	20
Chlorobenzilate	<0.096		<0.096		ug/L		NC	20
Chloroneb	<0.096		<0.096		ug/L		NC	20
Chlorothalonil (Draconil, Bravo)	<0.096		<0.096		ug/L		NC	20
Chlorpyrifos	<0.048		<0.048		ug/L		NC	20
Chrysene	<0.019		<0.019		ug/L		NC	20
delta-BHC	<0.096		<0.096		ug/L		NC	20
Di(2-ethylhexyl)adipate	<0.58		<0.58		ug/L		NC	20
Dibenz(a,h)anthracene	<0.048		<0.048		ug/L		NC	20
Diclorvos (DDVP)	<0.048		<0.048		ug/L		NC	20
Dieldrin	<0.0096		<0.0096		ug/L		NC	20
Diethylphthalate	<0.48		<0.48		ug/L		NC	20
Dimethylphthalate	<0.48		<0.48		ug/L		NC	20
Di-n-butyl phthalate	<0.96		<0.96		ug/L		NC	20
Di-n-octyl phthalate	<0.096		<0.096		ug/L		NC	20
Endosulfan I (Alpha)	<0.096		<0.096		ug/L		NC	20
Endosulfan II (Beta)	<0.096		<0.096		ug/L		NC	20
Endosulfan sulfate	<0.096		<0.096		ug/L		NC	20
Endrin	<0.0096		<0.0096		ug/L		NC	20
Endrin aldehyde	<0.096		<0.096		ug/L		NC	20
EPTC	<0.096		<0.096		ug/L		NC	20
Fluoranthene	<0.096		<0.096		ug/L		NC	20
Fluorene	<0.048		<0.048		ug/L		NC	20
gamma-BHC (Lindane)	<0.0096		<0.0096		ug/L		NC	20
gamma-Chlordane	<0.048		<0.048		ug/L		NC	20
Heptachlor	<0.0096		<0.0096		ug/L		NC	20
Heptachlor epoxide (isomer B)	<0.0096		<0.0096		ug/L		NC	20
Hexachlorobenzene	<0.048		<0.048		ug/L		NC	20
Hexachlorocyclopentadiene	<0.048		<0.048		ug/L		NC	20
Indeno[1,2,3-cd]pyrene	<0.048		<0.048		ug/L		NC	20
Isophorone	<0.096		<0.096		ug/L		NC	20
Malathion	<0.096		<0.096		ug/L		NC	20
Methoxychlor	<0.048		<0.048		ug/L		NC	20
Metolachlor	<0.048		<0.048		ug/L		NC	20
Molinate	<0.096		<0.096		ug/L		NC	20
Naphthalene	<0.096		<0.096		ug/L		NC	20
Parathion	<0.096		<0.096		ug/L		NC	20
Pendimethalin (Penoxaline)	<0.096		<0.096		ug/L		NC	20
Phenanthrene	<0.039		<0.038		ug/L		NC	20
Propachlor	<0.048		<0.048		ug/L		NC	20
Pyrene	<0.048		<0.048		ug/L		NC	20
Simazine	<0.048		<0.048		ug/L		NC	20
Terbacil	<0.096		<0.096		ug/L		NC	20
Terbutylazine	<0.096		<0.096		ug/L		NC	20
Thiobencarb	<0.096		<0.096		ug/L		NC	20
Total Permethrin (mixed isomers)	<0.19		<0.19		ug/L		NC	20
trans-Nonachlor	<0.048		<0.048		ug/L		NC	20
Trifluralin	<0.096		<0.096		ug/L		NC	20
1-Methylnaphthalene	<0.096		<0.096		ug/L		NC	20

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

**Lab Sample ID: 380-204992-S-1-A DU**  
**Matrix: Water**  
**Analysis Batch: 218602**

**Client Sample ID: Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 218277**

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
2-Methylnaphthalene	<0.096		<0.096		ug/L		NC	20

Surrogate	DU %Recovery	DU Qualifier	Limits
2-Nitro-m-xylene	99		70 - 130
Perylene d12	94		70 - 130
Triphenylphosphate	103		70 - 130

## Method: 625.1 - Semivolatile Organic Compounds (GC/MS)

**Lab Sample ID: MB 570-719700/1-A**  
**Matrix: Water**  
**Analysis Batch: 724152**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Tentatively Identified Compound	MB Est. Result	MB Qualifier	Unit	D	RT	CAS No.	Prepared	Analyzed	Dil Fac
Tentatively Identified Compound	None		ug/L			N/A	04/04/26 20:53	04/14/26 13:24	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	67		33 - 139	04/04/26 20:53	04/14/26 13:24	1
2-Fluorobiphenyl (Surr)	69		33 - 126	04/04/26 20:53	04/14/26 13:24	1
2-Fluorophenol (Surr)	51		12 - 120	04/04/26 20:53	04/14/26 13:24	1
Nitrobenzene-d5 (Surr)	71		36 - 120	04/04/26 20:53	04/14/26 13:24	1
Phenol-d6 (Surr)	30		10 - 120	04/04/26 20:53	04/14/26 13:24	1
p-Terphenyl-d14 (Surr)	74		47 - 131	04/04/26 20:53	04/14/26 13:24	1

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM)

**Lab Sample ID: MB 570-719700/1-A**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1-Methylnaphthalene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
2,4,5-Trichlorophenol	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
2,4,6-Trichlorophenol	<1.0		1.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
2,4-Dichlorophenol	<1.0		1.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
2,4-Dinitrophenol	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
2,6-Dichlorophenol	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
2-Chloronaphthalene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
2-Chlorophenol	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
2-Methylnaphthalene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
2-Methylphenol	<1.0		1.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
2-Nitroaniline	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
2-Nitrophenol	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
3/4-Methylphenol	<2.0		2.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
3-Nitroaniline	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
4,6-Dinitro-2-methylphenol	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
4-Bromophenyl phenyl ether	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
4-Chloro-3-methylphenol	<1.0		1.0	ug/L		04/04/26 20:53	04/09/26 15:36	1

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

**Lab Sample ID: MB 570-719700/1-A**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
4-Chloroaniline	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
4-Chlorophenyl phenyl ether	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
4-Nitroaniline	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
4-Nitrophenol	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
Acenaphthene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Acenaphthylene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Aniline	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Anthracene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Benzidine	<5.0		5.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
Benzo[a]anthracene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Benzo[a]pyrene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Benzo[b]fluoranthene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Benzo[g,h,i]perylene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Benzo[k]fluoranthene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Benzoic acid	<10		10	ug/L		04/04/26 20:53	04/09/26 15:36	1
Benzyl alcohol	<1.0		1.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
Bis(2-chloroethoxy)methane	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Bis(2-chloroethyl)ether	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
bis (2-Chloroisopropyl) ether	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Chrysene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Dibenz(a,h)anthracene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Dibenzofuran	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Fluoranthene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Fluorene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Hexachloroethane	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Indeno[1,2,3-cd]pyrene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Naphthalene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Nitrobenzene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
N-Nitrosodi-n-propylamine	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
N-Nitrosodiphenylamine	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Pentachlorophenol	<1.0		1.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
Phenanthrene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Phenol	<1.0		1.0	ug/L		04/04/26 20:53	04/09/26 15:36	1
Pyrene	<0.20		0.20	ug/L		04/04/26 20:53	04/09/26 15:36	1
Surrogate	MB %Recovery	MB Qualifier	Limits			Prepared	Analyzed	Dil Fac
2,4,6-Tribromophenol (Surr)	72		28 - 127			04/04/26 20:53	04/09/26 15:36	1
2-Fluorobiphenyl (Surr)	68		31 - 120			04/04/26 20:53	04/09/26 15:36	1
2-Fluorophenol (Surr)	48		17 - 120			04/04/26 20:53	04/09/26 15:36	1
Nitrobenzene-d5 (Surr)	75		27 - 120			04/04/26 20:53	04/09/26 15:36	1
Phenol-d6 (Surr)	31		10 - 120			04/04/26 20:53	04/09/26 15:36	1
p-Terphenyl-d14 (Surr)	69		45 - 120			04/04/26 20:53	04/09/26 15:36	1

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

**Lab Sample ID: LCS 570-719700/2-A**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1-Methylnaphthalene	20.0	14.9		ug/L		75	47 - 120
2,4,5-Trichlorophenol	20.0	18.9		ug/L		95	57 - 120
2,4,6-Trichlorophenol	20.0	17.5		ug/L		87	52 - 129
2,4-Dichlorophenol	20.0	15.8		ug/L		79	53 - 122
2,4-Dinitrophenol	20.0	18.3		ug/L		92	1 - 173
2,6-Dichlorophenol	20.0	15.6		ug/L		78	50 - 120
2-Chloronaphthalene	20.0	17.6		ug/L		88	65 - 120
2-Chlorophenol	20.0	18.6		ug/L		93	36 - 120
2-Methylnaphthalene	20.0	14.3		ug/L		72	43 - 120
2-Methylphenol	20.0	17.0		ug/L		85	46 - 120
2-Nitroaniline	20.0	19.1		ug/L		96	51 - 125
2-Nitrophenol	20.0	15.4		ug/L		77	45 - 167
3/4-Methylphenol	40.0	30.4		ug/L		76	29 - 120
3-Nitroaniline	20.0	18.1		ug/L		91	62 - 129
4,6-Dinitro-2-methylphenol	20.0	17.6		ug/L		88	53 - 130
4-Bromophenyl phenyl ether	20.0	16.0		ug/L		80	65 - 120
4-Chloro-3-methylphenol	20.0	15.8		ug/L		79	41 - 128
4-Chloroaniline	20.0	13.4		ug/L		67	51 - 120
4-Chlorophenyl phenyl ether	20.0	17.3		ug/L		87	38 - 145
4-Nitroaniline	20.0	18.7		ug/L		94	64 - 129
4-Nitrophenol	20.0	9.53		ug/L		48	13 - 129
Acenaphthene	20.0	17.1		ug/L		85	60 - 132
Acenaphthylene	20.0	17.4		ug/L		87	54 - 126
Aniline	20.0	9.29	*-	ug/L		46	52 - 121
Anthracene	20.0	16.8		ug/L		84	43 - 120
Benzidine	20.0	2.47	J *	ug/L		12	20 - 164
Benzo[a]anthracene	20.0	17.8		ug/L		89	42 - 133
Benzo[a]pyrene	20.0	18.7		ug/L		94	32 - 148
Benzo[b]fluoranthene	20.0	18.3		ug/L		92	42 - 140
Benzo[g,h,i]perylene	20.0	17.7		ug/L		88	1 - 195
Benzo[k]fluoranthene	20.0	17.7		ug/L		89	25 - 146
Benzoic acid	20.0	8.05	J	ug/L		40	20 - 120
Benzyl alcohol	20.0	17.1		ug/L		85	44 - 122
Bis(2-chloroethoxy)methane	20.0	15.8		ug/L		79	49 - 165
Bis(2-chloroethyl)ether	20.0	16.2		ug/L		81	43 - 126
bis (2-Chloroisopropyl) ether	20.0	18.1		ug/L		90	63 - 139
Chrysene	20.0	17.1		ug/L		86	44 - 140
Dibenz(a,h)anthracene	20.0	18.2		ug/L		91	1 - 200
Dibenzofuran	20.0	18.1		ug/L		91	48 - 120
Fluoranthene	20.0	18.1		ug/L		91	43 - 121
Fluorene	20.0	17.5		ug/L		88	70 - 120
Hexachloroethane	20.0	15.2		ug/L		76	55 - 120
Indeno[1,2,3-cd]pyrene	20.0	18.0		ug/L		90	1 - 151
Naphthalene	20.0	14.4		ug/L		72	36 - 120
Nitrobenzene	20.0	16.2		ug/L		81	54 - 158
N-Nitrosodi-n-propylamine	20.0	17.6		ug/L		88	14 - 198
N-Nitrosodiphenylamine	20.0	21.5		ug/L		108	65 - 133
Pentachlorophenol	20.0	16.3		ug/L		82	38 - 152

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

**Lab Sample ID: LCS 570-719700/2-A**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Phenanthrene	20.0	17.1		ug/L		85	65 - 120
Phenol	20.0	9.25		ug/L		46	17 - 120
Pyrene	20.0	17.7		ug/L		88	70 - 120

Surrogate	LCS %Recovery	LCS Qualifier	Limits
2,4,6-Tribromophenol (Surr)	83		28 - 127
2-Fluorobiphenyl (Surr)	85		31 - 120
2-Fluorophenol (Surr)	64		17 - 120
Nitrobenzene-d5 (Surr)	76		27 - 120
Phenol-d6 (Surr)	42		10 - 120
p-Terphenyl-d14 (Surr)	86		45 - 120

**Lab Sample ID: LCSD 570-719700/3-A**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1-Methylnaphthalene	20.0	12.9		ug/L		65	47 - 120	14	20
2,4,5-Trichlorophenol	20.0	16.7		ug/L		84	57 - 120	12	20
2,4,6-Trichlorophenol	20.0	15.1		ug/L		76	52 - 129	14	35
2,4-Dichlorophenol	20.0	13.9		ug/L		70	53 - 122	13	30
2,4-Dinitrophenol	20.0	16.0		ug/L		80	1 - 173	14	79
2,6-Dichlorophenol	20.0	13.8		ug/L		69	50 - 120	13	20
2-Chloronaphthalene	20.0	15.4		ug/L		77	65 - 120	13	15
2-Chlorophenol	20.0	16.0		ug/L		80	36 - 120	15	37
2-Methylnaphthalene	20.0	12.5		ug/L		63	43 - 120	13	20
2-Methylphenol	20.0	14.9		ug/L		74	46 - 120	13	20
2-Nitroaniline	20.0	16.9		ug/L		85	51 - 125	12	20
2-Nitrophenol	20.0	13.3		ug/L		66	45 - 167	15	33
3/4-Methylphenol	40.0	26.8		ug/L		67	29 - 120	13	20
3-Nitroaniline	20.0	17.0		ug/L		85	62 - 129	7	20
4,6-Dinitro-2-methylphenol	20.0	15.3		ug/L		77	53 - 130	14	122
4-Bromophenyl phenyl ether	20.0	14.0		ug/L		70	65 - 120	13	26
4-Chloro-3-methylphenol	20.0	13.8		ug/L		69	41 - 128	14	44
4-Chloroaniline	20.0	14.7		ug/L		74	51 - 120	9	20
4-Chlorophenyl phenyl ether	20.0	15.1		ug/L		75	38 - 145	14	36
4-Nitroaniline	20.0	16.9		ug/L		85	64 - 129	10	20
4-Nitrophenol	20.0	8.78		ug/L		44	13 - 129	8	79
Acenaphthene	20.0	14.9		ug/L		75	60 - 132	13	29
Acenaphthylene	20.0	15.3		ug/L		77	54 - 126	13	45
Aniline	20.0	14.8	*1	ug/L		74	52 - 121	46	21
Anthracene	20.0	15.0		ug/L		75	43 - 120	11	40
Benzidine	20.0	2.42	J *	ug/L		12	20 - 164	2	30
Benzo[a]anthracene	20.0	15.6		ug/L		78	42 - 133	13	32
Benzo[a]pyrene	20.0	16.9		ug/L		84	32 - 148	11	43
Benzo[b]fluoranthene	20.0	16.4		ug/L		82	42 - 140	11	43
Benzo[g,h,i]perylene	20.0	15.6		ug/L		78	1 - 195	12	61
Benzo[k]fluoranthene	20.0	16.2		ug/L		81	25 - 146	9	38

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

**Lab Sample ID: LCSD 570-719700/3-A**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec		RPD	RPD Limit
							Limits	RPD		
Benzoic acid	20.0	7.78	J	ug/L		39	20 - 120	3	30	
Benzyl alcohol	20.0	15.4		ug/L		77	44 - 122	10	20	
Bis(2-chloroethoxy)methane	20.0	13.8		ug/L		69	49 - 165	13	32	
Bis(2-chloroethyl)ether	20.0	13.8		ug/L		69	43 - 126	16	65	
bis (2-Chloroisopropyl) ether	20.0	15.5		ug/L		77	63 - 139	16	46	
Chrysene	20.0	15.1		ug/L		75	44 - 140	13	53	
Dibenz(a,h)anthracene	20.0	16.2		ug/L		81	1 - 200	11	75	
Dibenzofuran	20.0	15.6		ug/L		78	48 - 120	15	20	
Fluoranthene	20.0	15.4		ug/L		77	43 - 121	16	40	
Fluorene	20.0	15.3		ug/L		76	70 - 120	14	23	
Hexachloroethane	20.0	13.3		ug/L		66	55 - 120	14	32	
Indeno[1,2,3-cd]pyrene	20.0	16.1		ug/L		81	1 - 151	11	60	
Naphthalene	20.0	12.7		ug/L		63	36 - 120	13	39	
Nitrobenzene	20.0	14.3		ug/L		71	54 - 158	13	37	
N-Nitrosodi-n-propylamine	20.0	14.9		ug/L		75	14 - 198	16	52	
N-Nitrosodiphenylamine	20.0	18.6		ug/L		93	65 - 133	15	20	
Pentachlorophenol	20.0	14.1		ug/L		70	38 - 152	15	52	
Phenanthrene	20.0	15.0		ug/L		75	65 - 120	13	24	
Phenol	20.0	8.19		ug/L		41	17 - 120	12	39	
Pyrene	20.0	15.3		ug/L		77	70 - 120	14	30	

Surrogate	LCSD		Limits
	%Recovery	Qualifier	
2,4,6-Tribromophenol (Surr)	69		28 - 127
2-Fluorobiphenyl (Surr)	74		31 - 120
2-Fluorophenol (Surr)	55		17 - 120
Nitrobenzene-d5 (Surr)	66		27 - 120
Phenol-d6 (Surr)	36		10 - 120
p-Terphenyl-d14 (Surr)	77		45 - 120

**Lab Sample ID: 380-205929-A-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS		Unit	D	%Rec	%Rec	
				Result	Qualifier				Limits	RPD
1-Methylnaphthalene	<0.20		20.3	12.7		ug/L		63	36 - 120	
2,4,5-Trichlorophenol	<5.1		20.3	15.8		ug/L		78	21 - 145	
2,4,6-Trichlorophenol	<1.0		20.3	14.4		ug/L		71	37 - 144	
2,4-Dichlorophenol	<1.0		20.3	13.7		ug/L		68	39 - 135	
2,4-Dinitrophenol	<5.1		20.3	16.3		ug/L		80	1 - 191	
2,6-Dichlorophenol	<5.1		20.3	13.5		ug/L		67	24 - 134	
2-Chloronaphthalene	<0.20		20.3	14.0		ug/L		69	60 - 120	
2-Chlorophenol	<0.20		20.3	14.5		ug/L		71	23 - 143	
2-Methylnaphthalene	<0.20		20.3	12.2		ug/L		60	32 - 124	
2-Methylphenol	<1.0		20.3	13.1		ug/L		65	10 - 135	
2-Nitroaniline	<5.1		20.3	15.6		ug/L		77	10 - 147	
2-Nitrophenol	<5.1		20.3	12.2		ug/L		60	29 - 182	
3/4-Methylphenol	<2.0		40.6	23.9		ug/L		59	10 - 118	
3-Nitroaniline	<5.1	F2	20.3	8.71		ug/L		43	10 - 153	

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
 Project/Site: RED-HILL

Job ID: 380-206187-1  
 SDG: Quarterly: Moanalua Wells

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

**Lab Sample ID: 380-205929-A-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec Limits
	Result	Qualifier	Added	Result	Qualifier				
4,6-Dinitro-2-methylphenol	<5.1		20.3	14.6		ug/L		72	1 - 181
4-Bromophenyl phenyl ether	<0.20		20.3	13.1		ug/L		64	53 - 127
4-Chloro-3-methylphenol	<1.0		20.3	14.1		ug/L		69	22 - 147
4-Chloroaniline	<5.1	F2	20.3	<5.1		ug/L		24	10 - 131
4-Chlorophenyl phenyl ether	<0.20		20.3	13.9		ug/L		69	25 - 158
4-Nitroaniline	<5.1	F2	20.3	10.9		ug/L		54	10 - 180
4-Nitrophenol	<5.1		20.3	8.51		ug/L		42	1 - 132
Acenaphthene	<0.20		20.3	13.9		ug/L		68	47 - 145
Acenaphthylene	<0.20		20.3	13.6		ug/L		67	33 - 145
Aniline	<0.20	*- *1 F2	20.3	2.19		ug/L		10	10 - 113
Anthracene	<0.20		20.3	13.1		ug/L		65	27 - 133
Benzidine	<5.1	*- F1	20.3	<5.1		ug/L		12	10 - 57
Benzo[a]anthracene	<0.20		20.3	13.9		ug/L		68	33 - 143
Benzo[a]pyrene	<0.20		20.3	13.6		ug/L		67	17 - 163
Benzo[b]fluoranthene	<0.20		20.3	14.0		ug/L		69	24 - 159
Benzo[g,h,i]perylene	<0.20		20.3	13.5		ug/L		67	1 - 219
Benzo[k]fluoranthene	<0.20		20.3	13.2		ug/L		65	11 - 162
Benzoic acid	<10		20.3	<10		ug/L		30	10 - 97
Benzyl alcohol	<1.0		20.3	14.0		ug/L		67	10 - 122
Bis(2-chloroethoxy)methane	<0.20		20.3	12.8		ug/L		63	33 - 184
Bis(2-chloroethyl)ether	<0.20		20.3	12.9		ug/L		64	12 - 158
bis (2-Chloroisopropyl) ether	<0.20		20.3	13.7		ug/L		68	36 - 166
Chrysene	<0.20		20.3	13.4		ug/L		66	17 - 168
Dibenz(a,h)anthracene	<0.20		20.3	14.3		ug/L		70	1 - 227
Dibenzofuran	<0.20		20.3	14.6		ug/L		72	42 - 111
Fluoranthene	<0.20		20.3	14.8		ug/L		73	26 - 137
Fluorene	<0.20		20.3	14.1		ug/L		69	59 - 121
Hexachloroethane	<0.20		20.3	11.8		ug/L		58	40 - 120
Indeno[1,2,3-cd]pyrene	<0.20		20.3	14.0		ug/L		69	1 - 171
Naphthalene	<0.20		20.3	12.0		ug/L		59	21 - 133
Nitrobenzene	<0.20		20.3	13.0		ug/L		64	35 - 180
N-Nitrosodi-n-propylamine	<0.20		20.3	13.6		ug/L		67	1 - 230
N-Nitrosodiphenylamine	<0.20		20.3	17.5		ug/L		86	10 - 179
Pentachlorophenol	<1.0		20.3	15.7		ug/L		77	14 - 176
Phenanthrene	<0.20		20.3	14.4		ug/L		71	54 - 120
Phenol	<1.0		20.3	6.97		ug/L		34	5 - 120
Pyrene	<0.20		20.3	14.1		ug/L		69	52 - 120

Surrogate	MS MS		Limits
	%Recovery	Qualifier	
2,4,6-Tribromophenol (Surr)	69		28 - 127
2-Fluorobiphenyl (Surr)	64		31 - 120
2-Fluorophenol (Surr)	44		17 - 120
Nitrobenzene-d5 (Surr)	59		27 - 120
Phenol-d6 (Surr)	30		10 - 120
p-Terphenyl-d14 (Surr)	57		45 - 120

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

**Lab Sample ID: 380-205929-B-1-A MSD**

**Matrix: Water**

**Analysis Batch: 722093**

**Client Sample ID: Matrix Spike Duplicate**

**Prep Type: Total/NA**

**Prep Batch: 719700**

Analyte	Sample	Sample Qualifier	Spike Added	MSD	MSD Qualifier	Unit	D	%Rec	%Rec	RPD	RPD
	Result			Result					Limits		Limit
1-Methylnaphthalene	<0.20		20.4	13.5		ug/L		66	36 - 120	6	30
2,4,5-Trichlorophenol	<5.1		20.4	18.1		ug/L		89	21 - 145	14	30
2,4,6-Trichlorophenol	<1.0		20.4	16.5		ug/L		81	37 - 144	14	58
2,4-Dichlorophenol	<1.0		20.4	14.8		ug/L		72	39 - 135	8	50
2,4-Dinitrophenol	<5.1		20.4	19.0		ug/L		93	1 - 191	15	132
2,6-Dichlorophenol	<5.1		20.4	14.2		ug/L		70	24 - 134	5	30
2-Chloronaphthalene	<0.20		20.4	15.6		ug/L		76	60 - 120	11	24
2-Chlorophenol	<0.20		20.4	15.7		ug/L		77	23 - 143	8	61
2-Methylnaphthalene	<0.20		20.4	13.1		ug/L		64	32 - 124	8	30
2-Methylphenol	<1.0		20.4	14.5		ug/L		71	10 - 135	10	30
2-Nitroaniline	<5.1		20.4	17.6		ug/L		86	10 - 147	12	30
2-Nitrophenol	<5.1		20.4	13.2		ug/L		65	29 - 182	7	55
3/4-Methylphenol	<2.0		40.8	26.3		ug/L		64	10 - 118	9	30
3-Nitroaniline	<5.1	F2	20.4	14.8	F2	ug/L		72	10 - 153	52	30
4,6-Dinitro-2-methylphenol	<5.1		20.4	17.0		ug/L		83	1 - 181	15	203
4-Bromophenyl phenyl ether	<0.20		20.4	14.6		ug/L		72	53 - 127	11	43
4-Chloro-3-methylphenol	<1.0		20.4	15.7		ug/L		77	22 - 147	11	73
4-Chloroaniline	<5.1	F2	20.4	10.7	F2	ug/L		52	10 - 131	76	30
4-Chlorophenyl phenyl ether	<0.20		20.4	15.5		ug/L		76	25 - 158	11	61
4-Nitroaniline	<5.1	F2	20.4	15.2	F2	ug/L		74	10 - 180	33	30
4-Nitrophenol	<5.1		20.4	9.96		ug/L		49	1 - 132	16	131
Acenaphthene	<0.20		20.4	15.3		ug/L		75	47 - 145	10	48
Acenaphthylene	<0.20		20.4	15.6		ug/L		76	33 - 145	13	74
Aniline	<0.20	*- *1 F2	20.4	6.94	F2	ug/L		34	10 - 113	104	30
Anthracene	<0.20		20.4	15.1		ug/L		74	27 - 133	14	66
Benzidine	<5.1	*- F1	20.4	<5.1	F1	ug/L		0	10 - 57	NC	30
Benzo[a]anthracene	<0.20		20.4	16.0		ug/L		78	33 - 143	14	53
Benzo[a]pyrene	<0.20		20.4	15.8		ug/L		77	17 - 163	15	72
Benzo[b]fluoranthene	<0.20		20.4	16.0		ug/L		78	24 - 159	13	71
Benzo[g,h,i]perylene	<0.20		20.4	15.4		ug/L		75	1 - 219	13	97
Benzo[k]fluoranthene	<0.20		20.4	15.2		ug/L		74	11 - 162	14	63
Benzoic acid	<10		20.4	10.1		ug/L		34	10 - 97	10	30
Benzyl alcohol	<1.0		20.4	14.8		ug/L		71	10 - 122	6	30
Bis(2-chloroethoxy)methane	<0.20		20.4	13.6		ug/L		67	33 - 184	6	54
Bis(2-chloroethyl)ether	<0.20		20.4	13.4		ug/L		66	12 - 158	3	108
bis (2-Chloroisopropyl) ether	<0.20		20.4	14.6		ug/L		72	36 - 166	6	76
Chrysene	<0.20		20.4	15.0		ug/L		74	17 - 168	12	87
Dibenz(a,h)anthracene	<0.20		20.4	16.3		ug/L		80	1 - 227	13	126
Dibenzofuran	<0.20		20.4	16.3		ug/L		80	42 - 111	11	30
Fluoranthene	<0.20		20.4	16.5		ug/L		81	26 - 137	11	66
Fluorene	<0.20		20.4	15.8		ug/L		77	59 - 121	11	38
Hexachloroethane	<0.20		20.4	12.9		ug/L		63	40 - 120	9	52
Indeno[1,2,3-cd]pyrene	<0.20		20.4	15.8		ug/L		77	1 - 171	12	99
Naphthalene	<0.20		20.4	12.3		ug/L		60	21 - 133	2	65
Nitrobenzene	<0.20		20.4	13.7		ug/L		67	35 - 180	5	62
N-Nitrosodi-n-propylamine	<0.20		20.4	14.0		ug/L		68	1 - 230	2	87
N-Nitrosodiphenylamine	<0.20		20.4	19.0		ug/L		93	10 - 179	8	30
Pentachlorophenol	<1.0		20.4	18.2		ug/L		89	14 - 176	15	86

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 625.1 SIM - Semivolatile Organic Compounds GC/MS (SIM) (Continued)

**Lab Sample ID: 380-205929-B-1-A MSD**  
**Matrix: Water**  
**Analysis Batch: 722093**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 719700**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Phenanthrene	<0.20		20.4	15.9		ug/L		78	54 - 120	10	39
Phenol	<1.0		20.4	7.52		ug/L		37	5 - 120	8	64
Pyrene	<0.20		20.4	15.9		ug/L		78	52 - 120	12	49
<b>MSD MSD</b>											
Surrogate	%Recovery	Qualifier	Limits								
2,4,6-Tribromophenol (Surr)	79		28 - 127								
2-Fluorobiphenyl (Surr)	70		31 - 120								
2-Fluorophenol (Surr)	47		17 - 120								
Nitrobenzene-d5 (Surr)	62		27 - 120								
Phenol-d6 (Surr)	33		10 - 120								
p-Terphenyl-d14 (Surr)	64		45 - 120								

## Method: 8015B GRO LL - Gasoline Range Organics - (GC)

**Lab Sample ID: MB 570-724791/6**  
**Matrix: Water**  
**Analysis Batch: 724791**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
GRO (C6-C10)	<10		10	ug/L			04/15/26 14:25	1
<b>MB MB</b>								
Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac		
4-Bromofluorobenzene (Surr)	102		38 - 134		04/15/26 14:25	1		

**Lab Sample ID: LCS 570-724791/3**  
**Matrix: Water**  
**Analysis Batch: 724791**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Gasoline Range Organics (C4-C13)	400	411		ug/L		103	78 - 120		
<b>LCS LCS</b>									
Surrogate	%Recovery	Qualifier	Limits						
4-Bromofluorobenzene (Surr)	109		38 - 134						

**Lab Sample ID: LCSD 570-724791/4**  
**Matrix: Water**  
**Analysis Batch: 724791**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	400	404		ug/L		101	78 - 120	2	10
<b>LCSD LCSD</b>									
Surrogate	%Recovery	Qualifier	Limits						
4-Bromofluorobenzene (Surr)	105		38 - 134						

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 8015B GRO LL - Gasoline Range Organics - (GC) (Continued)

**Lab Sample ID: MRL 570-724791/5**  
**Matrix: Water**  
**Analysis Batch: 724791**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	10.0	11.8		ug/L		118	50 - 150
<b>Surrogate</b>		<b>MRL %Recovery</b>	<b>MRL Qualifier</b>				<b>Limits</b>
4-Bromofluorobenzene (Surr)		102					38 - 134

**Lab Sample ID: 380-206949-C-1 MS**  
**Matrix: Water**  
**Analysis Batch: 724791**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Gasoline Range Organics (C4-C13)	<10		400	420		ug/L		105	68 - 122
<b>Surrogate</b>		<b>MS %Recovery</b>		<b>MS Qualifier</b>					<b>Limits</b>
4-Bromofluorobenzene (Surr)		104							38 - 134

**Lab Sample ID: 380-206949-C-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 724791**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Gasoline Range Organics (C4-C13)	<10		400	414		ug/L		103	68 - 122	1	18
<b>Surrogate</b>		<b>MSD %Recovery</b>		<b>MSD Qualifier</b>					<b>Limits</b>		
4-Bromofluorobenzene (Surr)		102							38 - 134		

## Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

**Lab Sample ID: MBL 380-218306/4-A**  
**Matrix: Water**  
**Analysis Batch: 218526**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 218306**

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,3-Trichloropropane	<0.0040		0.020	ug/L		04/07/26 15:15	04/07/26 18:09	1
1,2-Dibromo-3-Chloropropane	<0.0020		0.010	ug/L		04/07/26 15:15	04/07/26 18:09	1
1,2-Dibromoethane	<0.0040		0.010	ug/L		04/07/26 15:15	04/07/26 18:09	1
<b>Surrogate</b>		<b>MBL %Recovery</b>	<b>MBL Qualifier</b>			<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
1,2-Dibromopropane (Surr)		105				04/07/26 15:15	04/07/26 18:09	1

**Lab Sample ID: LCS 380-218306/29-A**  
**Matrix: Water**  
**Analysis Batch: 218526**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218306**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,2,3-Trichloropropane	0.200	0.207		ug/L		103	70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC) (Continued)

**Lab Sample ID: LCS 380-218306/29-A**  
**Matrix: Water**  
**Analysis Batch: 218526**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218306**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,2-Dibromo-3-Chloropropane	0.200	0.207		ug/L		104	70 - 130
1,2-Dibromoethane	0.200	0.216		ug/L		108	70 - 130
<b>Surrogate</b>		<b>LCS %Recovery</b>	<b>LCS Qualifier</b>				<b>Limits</b>
1,2-Dibromopropane (Surr)		106					60 - 140

**Lab Sample ID: MRL 380-218306/2-A**  
**Matrix: Water**  
**Analysis Batch: 218526**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218306**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1,2,3-Trichloropropane	0.0200	0.0195	J	ug/L		98	60 - 140
<b>Surrogate</b>		<b>MRL %Recovery</b>	<b>MRL Qualifier</b>				<b>Limits</b>
1,2-Dibromopropane (Surr)		105					60 - 140

**Lab Sample ID: MRL 380-218306/3-A**  
**Matrix: Water**  
**Analysis Batch: 218526**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218306**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1,2,3-Trichloropropane	0.0500	0.0578		ug/L		116	60 - 140
1,2-Dibromo-3-Chloropropane	0.0100	0.0104		ug/L		104	60 - 140
1,2-Dibromoethane	0.0100	0.00974	J	ug/L		97	60 - 140
<b>Surrogate</b>		<b>MRL %Recovery</b>	<b>MRL Qualifier</b>				<b>Limits</b>
1,2-Dibromopropane (Surr)		103					60 - 140

**Lab Sample ID: 380-206204-BV-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 218526**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 218306**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
1,2,3-Trichloropropane	<0.020		1.25	1.37		ug/L		110	65 - 135
1,2-Dibromo-3-Chloropropane	<0.010		0.251	0.271		ug/L		108	65 - 135
1,2-Dibromoethane	<0.010		0.251	0.275		ug/L		110	65 - 135
<b>Surrogate</b>		<b>MS %Recovery</b>	<b>MS Qualifier</b>						<b>Limits</b>
1,2-Dibromopropane (Surr)		103							60 - 140

**Lab Sample ID: 380-206332-BQ-1-A DU**  
**Matrix: Water**  
**Analysis Batch: 218526**

**Client Sample ID: Duplicate**  
**Prep Type: Total/NA**  
**Prep Batch: 218306**

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	Limit
1,2,3-Trichloropropane	<0.020		<0.020		ug/L		NC	20
1,2-Dibromo-3-Chloropropane	<0.010		<0.010		ug/L		NC	20
1,2-Dibromoethane	<0.010		<0.010		ug/L		NC	20

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC) (Continued)

Surrogate	DU DU		Limits
	%Recovery	Qualifier	
1,2-Dibromopropane (Surr)	110		60 - 140

## Method: 505 - Organochlorine Pesticides/PCBs (GC)

**Lab Sample ID: MB 380-218087/3-A**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte	MB MB		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Toxaphene	<0.50		0.50	ug/L		04/06/26 13:03	04/06/26 15:27	1
Chlordane (n.o.s.)	<0.10		0.10	ug/L		04/06/26 13:03	04/06/26 15:27	1
PCB-1016	<0.070		0.070	ug/L		04/06/26 13:03	04/06/26 15:27	1
PCB-1221	<0.10		0.10	ug/L		04/06/26 13:03	04/06/26 15:27	1
PCB-1232	<0.10		0.10	ug/L		04/06/26 13:03	04/06/26 15:27	1
PCB-1242	<0.10		0.10	ug/L		04/06/26 13:03	04/06/26 15:27	1
PCB-1248	<0.10		0.10	ug/L		04/06/26 13:03	04/06/26 15:27	1
PCB-1254	<0.10		0.10	ug/L		04/06/26 13:03	04/06/26 15:27	1
PCB-1260	<0.070		0.070	ug/L		04/06/26 13:03	04/06/26 15:27	1
Polychlorinated biphenyls, Total	<0.10		0.10	ug/L		04/06/26 13:03	04/06/26 15:27	1

Surrogate	MB MB		Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
Tetrachloro-m-xylene	94		70 - 130	04/06/26 13:03	04/06/26 15:27	1

**Lab Sample ID: LCS 380-218087/28-A**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
Tetrachloro-m-xylene	93		70 - 130

**Lab Sample ID: LCS 380-218087/29-A**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits

Surrogate	LCS LCS		Limits
	%Recovery	Qualifier	
Tetrachloro-m-xylene	99		70 - 130

**Lab Sample ID: LCS 380-218087/31-A**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 505 - Organochlorine Pesticides/PCBs (GC) (Continued)

**Lab Sample ID: LCS 380-218087/31-A**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

	LCS	LCS	
Surrogate	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene	93		70 - 130

**Lab Sample ID: LCSD 380-218087/30-A**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte			Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	Limit
Chlordane (n.o.s.)			0.500	0.487		ug/L		97	70 - 130	2	20

	LCSD	LCSD	
Surrogate	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene	90		70 - 130

**Lab Sample ID: MRL 380-218087/1-A**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Toxaphene			0.500	0.416	J	ug/L		83	50 - 150

	MRL	MRL	
Surrogate	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene	90		70 - 130

**Lab Sample ID: MRL 380-218087/2-A**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte			Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Chlordane (n.o.s.)			0.100	0.105		ug/L		105	50 - 150

	MRL	MRL	
Surrogate	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene	85		70 - 130

**Lab Sample ID: 380-206150-I-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Toxaphene	<0.49		2.48	2.33		ug/L		94	65 - 135

	MS	MS	
Surrogate	%Recovery	Qualifier	Limits
Tetrachloro-m-xylene	90		70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 505 - Organochlorine Pesticides/PCBs (GC) (Continued)

**Lab Sample ID: 380-206150-J-1-A MS**  
**Matrix: Water**  
**Analysis Batch: 218244**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**  
**Prep Batch: 218087**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chlordane (n.o.s.)	<0.099		0.485	0.492		ug/L		101	65 - 135
<b>Surrogate</b>	<b>%Recovery</b>	<b>MS Qualifier</b>	<b>MS Limits</b>						
<i>Tetrachloro-m-xylene</i>	96		70 - 130						

## Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level

**Lab Sample ID: MB 570-720612/1-A**  
**Matrix: Water**  
**Analysis Batch: 720996**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**  
**Prep Batch: 720612**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Diesel Range Organics (C10-C24)	<25		25	ug/L		04/07/26 09:29	04/07/26 21:24	1
Motor Oil Range Organics [C24-C36]	<25		25	ug/L		04/07/26 09:29	04/07/26 21:24	1
C8-C18	<25		25	ug/L		04/07/26 09:29	04/07/26 21:24	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>MB Qualifier</b>	<b>MB Limits</b>	<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>		
<i>n-Octacosane (Surr)</i>	109		60 - 130	04/07/26 09:29	04/07/26 21:24	1		

**Lab Sample ID: LCS 570-720612/2-A**  
**Matrix: Water**  
**Analysis Batch: 720996**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 720612**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
C10-C28	1600	1640		ug/L		102	56 - 127
<b>Surrogate</b>	<b>LCS %Recovery</b>	<b>LCS Qualifier</b>	<b>LCS Limits</b>				
<i>n-Octacosane (Surr)</i>	115		60 - 130				

**Lab Sample ID: LCSD 570-720612/3-A**  
**Matrix: Water**  
**Analysis Batch: 720996**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**  
**Prep Batch: 720612**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
C10-C28	1600	1590		ug/L		99	56 - 127	3	23
<b>Surrogate</b>	<b>LCSD %Recovery</b>	<b>LCSD Qualifier</b>	<b>LCSD Limits</b>						
<i>n-Octacosane (Surr)</i>	111		60 - 130						

**Lab Sample ID: MRL 570-720612/4-A**  
**Matrix: Water**  
**Analysis Batch: 720996**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 720612**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
C10-C28	0.0200	0.0332	^3+	mg/L		166	50 - 150

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 8015B - Diesel Range Organics (DRO) (GC) Low Level (Continued)

**Lab Sample ID: MRL 570-720612/4-A**  
**Matrix: Water**  
**Analysis Batch: 720996**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**  
**Prep Batch: 720612**

Surrogate	%Recovery	MRL Qualifier	MRL Limits
<i>n</i> -Octacosane (Surr)	110		60 - 130

## Method: 8015B - Nonhalogenated Organic Compounds - Direct Injection (GC)

**Lab Sample ID: MB 570-723893/3**  
**Matrix: Water**  
**Analysis Batch: 723893**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Ethanol	<0.10		0.10	mg/L			04/14/26 05:39	1
Surrogate	%Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac		
Hexafluoro-2-propanol (Surr)	98	p	52 - 149		04/14/26 05:39	1		

**Lab Sample ID: LCS 570-723893/4**  
**Matrix: Water**  
**Analysis Batch: 723893**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Ethanol	2.00	1.93		mg/L		97	59 - 153
Surrogate	%Recovery	LCS Qualifier	Limits				
Hexafluoro-2-propanol (Surr)	99	p	52 - 149				

**Lab Sample ID: LCSD 570-723893/5**  
**Matrix: Water**  
**Analysis Batch: 723893**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Ethanol	2.00	2.17		mg/L		108	59 - 153	11	30
Surrogate	%Recovery	LCSD Qualifier	Limits						
Hexafluoro-2-propanol (Surr)	101	p	52 - 149						

**Lab Sample ID: MRL 570-723893/6**  
**Matrix: Water**  
**Analysis Batch: 723893**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Ethanol	0.100	0.0859	J	mg/L		86	50 - 150
Surrogate	%Recovery	MRL Qualifier	Limits				
Hexafluoro-2-propanol (Surr)	97		52 - 149				

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 8015B - Nonhalogenated Organic Compounds - Direct Injection (GC) (Continued)

**Lab Sample ID: 380-207013-AB-1 MS**  
**Matrix: Water**  
**Analysis Batch: 723893**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample	Sample	Spike	MS	MS	Unit	D	%Rec	%Rec	Limits
	Result	Qualifier	Added	Result	Qualifier					
Ethanol	<0.10	F1	2000	2.19	F1	mg/L		0.1		61 - 150
<b>Surrogate</b>	<b>%Recovery</b>	<b>MS Qualifier</b>	<b>MS Limits</b>							
Hexafluoro-2-propanol (Surr)	97	p	52 - 149							

**Lab Sample ID: 380-207013-AB-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 723893**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample	Sample	Spike	MSD	MSD	Unit	D	%Rec	%Rec	Limits	RPD	Limit
	Result	Qualifier	Added	Result	Qualifier							
Ethanol	<0.10	F1	2000	2.33	F1	mg/L		0.1		61 - 150	6	36
<b>Surrogate</b>	<b>%Recovery</b>	<b>MSD Qualifier</b>	<b>MSD Limits</b>									
Hexafluoro-2-propanol (Surr)	97	p	52 - 149									

## Method: 300.0 - Anions, Ion Chromatography

**Lab Sample ID: MB 380-217761/38**  
**Matrix: Water**  
**Analysis Batch: 217761**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB	MB	RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Nitrate as N	<0.050		0.050	mg/L			04/03/26 16:32	1
Nitrite as N	<0.050		0.050	mg/L			04/03/26 16:32	1

**Lab Sample ID: LCS 380-217761/40**  
**Matrix: Water**  
**Analysis Batch: 217761**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec	Limits
Nitrate as N	2.50	2.57		mg/L		103		90 - 110
Nitrite as N	1.00	1.04		mg/L		104		90 - 110

**Lab Sample ID: LCSD 380-217761/41**  
**Matrix: Water**  
**Analysis Batch: 217761**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD	LCSD	Unit	D	%Rec	%Rec	Limits	RPD	Limit
Nitrate as N	2.50	2.55		mg/L		102		90 - 110	1	20
Nitrite as N	1.00	1.04		mg/L		104		90 - 110	0	20

**Lab Sample ID: MRL 380-217761/39**  
**Matrix: Water**  
**Analysis Batch: 217761**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL	MRL	Unit	D	%Rec	%Rec	Limits
Nitrate as N	0.0500	0.0459	J	mg/L		92		50 - 150
Nitrite as N	0.0500	0.0500		mg/L		100		50 - 150

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 300.0 - Anions, Ion Chromatography (Continued)

**Lab Sample ID: 380-206184-K-1 MS**  
**Matrix: Water**  
**Analysis Batch: 217761**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Nitrate as N	0.42		1.25	1.73		mg/L		105	80 - 120
Nitrite as N	<0.050		0.500	0.488		mg/L		98	80 - 120

**Lab Sample ID: 380-206184-K-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 217761**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Nitrate as N	0.42		1.25	1.72		mg/L		104	80 - 120	0	20
Nitrite as N	<0.050		0.500	0.484		mg/L		97	80 - 120	1	20

**Lab Sample ID: MB 380-217762/38**  
**Matrix: Water**  
**Analysis Batch: 217762**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<0.50		0.50	mg/L			04/03/26 16:32	1
Sulfate	<0.25		0.25	mg/L			04/03/26 16:32	1

**Lab Sample ID: LCS 380-217762/40**  
**Matrix: Water**  
**Analysis Batch: 217762**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	25.0	26.2		mg/L		105	90 - 110
Sulfate	50.0	51.9		mg/L		104	90 - 110

**Lab Sample ID: LCSD 380-217762/41**  
**Matrix: Water**  
**Analysis Batch: 217762**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Chloride	25.0	26.2		mg/L		105	90 - 110	0	20
Sulfate	50.0	51.8		mg/L		104	90 - 110	0	20

**Lab Sample ID: MRL 380-217762/39**  
**Matrix: Water**  
**Analysis Batch: 217762**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	0.500	0.438	J	mg/L		88	50 - 150
Sulfate	0.250	0.239	J	mg/L		96	50 - 150

**Lab Sample ID: 380-206184-K-1 MS**  
**Matrix: Water**  
**Analysis Batch: 217762**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	9.3		12.5	22.9		mg/L		108	80 - 120
Sulfate	4.5		25.0	30.4		mg/L		103	80 - 120

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 300.0 - Anions, Ion Chromatography

**Lab Sample ID: 380-206184-K-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 217762**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Chloride	9.3		12.5	22.8		mg/L		108	80 - 120	0	20
Sulfate	4.5		25.0	30.2		mg/L		103	80 - 120	1	20

**Lab Sample ID: MB 380-218702/6**  
**Matrix: Water**  
**Analysis Batch: 218702**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Bromide	<5.0		5.0	ug/L			04/08/26 17:33	1

**Lab Sample ID: LCS 380-218702/7**  
**Matrix: Water**  
**Analysis Batch: 218702**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Bromide	100	98.9		ug/L		99	90 - 110

**Lab Sample ID: LCSD 380-218702/8**  
**Matrix: Water**  
**Analysis Batch: 218702**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Bromide	100	99.6		ug/L		100	90 - 110	1	10

**Lab Sample ID: MRL 380-218702/5**  
**Matrix: Water**  
**Analysis Batch: 218702**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Bromide	5.00	4.53	J	ug/L		91	75 - 125

**Lab Sample ID: 380-206332-BI-1 MS**  
**Matrix: Water**  
**Analysis Batch: 218702**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Bromide	<5.0		50.0	48.9		ug/L		98	80 - 120

**Lab Sample ID: 380-206332-BI-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 218702**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Bromide	<5.0		50.0	49.8		ug/L		100	80 - 120	2	20

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 200.7 Rev 4.4 - Metals (ICP)

**Lab Sample ID: MBL 380-218116/50**  
**Matrix: Water**  
**Analysis Batch: 218116**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Calcium	<0.031		0.10	mg/L			04/06/26 12:39	1
Magnesium	<0.0099		0.10	mg/L			04/06/26 12:39	1
Potassium	<0.044		0.20	mg/L			04/06/26 12:39	1
Sodium	<0.019		0.10	mg/L			04/06/26 12:39	1

**Lab Sample ID: LCS 380-218116/52**  
**Matrix: Water**  
**Analysis Batch: 218116**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Calcium	50.0	50.4		mg/L		101	85 - 115
Magnesium	20.0	20.1		mg/L		101	85 - 115
Potassium	20.0	20.0		mg/L		100	85 - 115
Sodium	50.0	49.9		mg/L		100	85 - 115

**Lab Sample ID: LCSD 380-218116/53**  
**Matrix: Water**  
**Analysis Batch: 218116**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Calcium	50.0	51.0		mg/L		102	85 - 115	1	20
Magnesium	20.0	20.3		mg/L		102	85 - 115	1	20
Potassium	20.0	20.2		mg/L		101	85 - 115	1	20
Sodium	50.0	50.2		mg/L		100	85 - 115	1	20

**Lab Sample ID: LLCS 380-218116/51**  
**Matrix: Water**  
**Analysis Batch: 218116**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Calcium	0.100	0.103		mg/L		103	50 - 150
Magnesium	0.100	0.0970	J	mg/L		97	50 - 150
Potassium	0.100	0.126	J	mg/L		126	50 - 150
Sodium	0.100	0.0987	J	mg/L		99	50 - 150

**Lab Sample ID: 380-206177-H-1 MS**  
**Matrix: Water**  
**Analysis Batch: 218116**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Calcium	31		50.0	76.1		mg/L		91	70 - 130
Magnesium	28		20.0	46.0		mg/L		89	70 - 130
Potassium	3.6		20.0	22.2		mg/L		93	70 - 130
Sodium	68		50.0	112		mg/L		88	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 200.7 Rev 4.4 - Metals (ICP) (Continued)

**Lab Sample ID: 380-206177-H-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 218116**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Calcium	31		50.0	77.0		mg/L		93	70 - 130	1	20
Magnesium	28		20.0	46.5		mg/L		91	70 - 130	1	20
Potassium	3.6		20.0	22.6		mg/L		95	70 - 130	2	20
Sodium	68		50.0	113		mg/L		90	70 - 130	1	20

## Method: 200.8 - Metals (ICP/MS)

**Lab Sample ID: MBL 380-217861/75**  
**Matrix: Water**  
**Analysis Batch: 217861**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Antimony	<0.48		1.0	ug/L			04/04/26 12:33	1
Arsenic	<0.25		1.0	ug/L			04/04/26 12:33	1
Beryllium	<0.12		0.30	ug/L			04/04/26 12:33	1
Cadmium	<0.081		0.50	ug/L			04/04/26 12:33	1
Chromium	<0.33		0.90	ug/L			04/04/26 12:33	1
Copper	<0.28		1.0	ug/L			04/04/26 12:33	1
Lead	<0.084		0.50	ug/L			04/04/26 12:33	1
Nickel	<0.38		5.0	ug/L			04/04/26 12:33	1
Selenium	<0.25		2.0	ug/L			04/04/26 12:33	1
Silver	<0.30		0.50	ug/L			04/04/26 12:33	1
Thallium	<0.10		0.30	ug/L			04/04/26 12:33	1
Zinc	<1.3		5.0	ug/L			04/04/26 12:33	1

**Lab Sample ID: LCS 380-217861/77**  
**Matrix: Water**  
**Analysis Batch: 217861**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Antimony	50.0	50.9		ug/L		102	85 - 115
Arsenic	50.0	51.8		ug/L		104	85 - 115
Beryllium	50.0	54.8		ug/L		110	85 - 115
Cadmium	50.0	51.1		ug/L		102	85 - 115
Chromium	50.0	50.7		ug/L		101	85 - 115
Copper	50.0	51.7		ug/L		103	85 - 115
Lead	50.0	50.9		ug/L		102	85 - 115
Nickel	50.0	50.1		ug/L		100	85 - 115
Selenium	50.0	49.9		ug/L		100	85 - 115
Silver	50.0	51.3		ug/L		103	85 - 115
Thallium	50.0	50.2		ug/L		100	85 - 115
Zinc	50.0	50.0		ug/L		100	85 - 115

**Lab Sample ID: LCSD 380-217861/78**  
**Matrix: Water**  
**Analysis Batch: 217861**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Antimony	50.0	50.4		ug/L		101	85 - 115	1	20

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 200.8 - Metals (ICP/MS) (Continued)

**Lab Sample ID: LCSD 380-217861/78**  
**Matrix: Water**  
**Analysis Batch: 217861**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Arsenic	50.0	51.1		ug/L		102	85 - 115	1	20
Beryllium	50.0	54.5		ug/L		109	85 - 115	1	20
Cadmium	50.0	50.1		ug/L		100	85 - 115	2	20
Chromium	50.0	49.8		ug/L		100	85 - 115	2	20
Copper	50.0	51.1		ug/L		102	85 - 115	1	20
Lead	50.0	49.5		ug/L		99	85 - 115	3	20
Nickel	50.0	49.4		ug/L		99	85 - 115	1	20
Selenium	50.0	50.0		ug/L		100	85 - 115	0	20
Silver	50.0	50.6		ug/L		101	85 - 115	1	20
Thallium	50.0	49.4		ug/L		99	85 - 115	1	20
Zinc	50.0	48.4		ug/L		97	85 - 115	3	20

**Lab Sample ID: LLCS 380-217861/76**  
**Matrix: Water**  
**Analysis Batch: 217861**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Antimony	1.00	1.02		ug/L		102	50 - 150
Arsenic	1.00	1.23		ug/L		123	50 - 150
Beryllium	0.300	0.327		ug/L		109	50 - 150
Cadmium	0.500	0.477	J	ug/L		95	50 - 150
Chromium	0.900	1.20		ug/L		133	50 - 150
Copper	1.00	1.03		ug/L		103	50 - 150
Lead	0.500	0.493	J	ug/L		99	50 - 150
Nickel	1.00	1.04	J	ug/L		104	50 - 150
Selenium	2.00	2.01		ug/L		101	50 - 150
Silver	0.500	0.513		ug/L		103	50 - 150
Thallium	0.300	0.299	J	ug/L		100	50 - 150
Zinc	5.00	5.04		ug/L		101	50 - 150

**Lab Sample ID: 380-206165-A-1 MS**  
**Matrix: Water**  
**Analysis Batch: 217861**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Antimony	<1.0		50.0	51.3		ug/L		103	70 - 130
Arsenic	<1.0		50.0	53.7		ug/L		107	70 - 130
Beryllium	<0.30		50.0	52.1		ug/L		104	70 - 130
Cadmium	<0.50		50.0	51.2		ug/L		102	70 - 130
Chromium	7.3		50.0	49.4		ug/L		84	70 - 130
Copper	3.5		50.0	51.4		ug/L		96	70 - 130
Lead	<0.50		50.0	47.3		ug/L		94	70 - 130
Nickel	<5.0		50.0	46.6		ug/L		85	70 - 130
Selenium	<2.0		50.0	58.5		ug/L		117	70 - 130
Silver	<0.50		50.0	43.3		ug/L		87	70 - 130
Thallium	<0.30		50.0	47.6		ug/L		95	70 - 130
Zinc	6.2		50.0	58.6		ug/L		105	70 - 130

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 200.8 - Metals (ICP/MS) (Continued)

**Lab Sample ID: 380-206165-A-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 217861**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Antimony	<1.0		50.0	51.4		ug/L		103	70 - 130	0	20
Arsenic	<1.0		50.0	53.6		ug/L		107	70 - 130	0	20
Beryllium	<0.30		50.0	52.1		ug/L		104	70 - 130	0	20
Cadmium	<0.50		50.0	50.9		ug/L		102	70 - 130	1	20
Chromium	7.3		50.0	49.4		ug/L		84	70 - 130	0	20
Copper	3.5		50.0	51.2		ug/L		95	70 - 130	0	20
Lead	<0.50		50.0	48.2		ug/L		96	70 - 130	2	20
Nickel	<5.0		50.0	46.6		ug/L		85	70 - 130	0	20
Selenium	<2.0		50.0	58.8		ug/L		118	70 - 130	1	20
Silver	<0.50		50.0	37.5		ug/L		75	70 - 130	14	20
Thallium	<0.30		50.0	48.3		ug/L		97	70 - 130	2	20
Zinc	6.2		50.0	58.0		ug/L		104	70 - 130	1	20

## Method: 200.8 - Mercury (ICP/MS)

**Lab Sample ID: MBL 380-218250/1-A**  
**Matrix: Water**  
**Analysis Batch: 218823**

**Client Sample ID: Method Blank**  
**Prep Type: Total Recoverable**  
**Prep Batch: 218250**

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Mercury	<0.079		0.20	ug/L		04/07/26 09:15	04/08/26 17:25	1

**Lab Sample ID: LCS 380-218250/3-A**  
**Matrix: Water**  
**Analysis Batch: 218823**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total Recoverable**  
**Prep Batch: 218250**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Mercury	1.00	0.935		ug/L		94	85 - 115

**Lab Sample ID: LCSD 380-218250/4-A**  
**Matrix: Water**  
**Analysis Batch: 218823**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total Recoverable**  
**Prep Batch: 218250**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Mercury	1.00	0.985		ug/L		99	85 - 115	5	20

**Lab Sample ID: LLCS 380-218250/2-A**  
**Matrix: Water**  
**Analysis Batch: 218823**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total Recoverable**  
**Prep Batch: 218250**

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Mercury	0.200	0.198	J	ug/L		99	50 - 150

**Lab Sample ID: 380-206403-C-1-B MS**  
**Matrix: Water**  
**Analysis Batch: 218823**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total Recoverable**  
**Prep Batch: 218250**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Mercury	<0.20		1.00	0.929		ug/L		93	70 - 130

Eurofins Pomona

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: 200.8 - Mercury (ICP/MS) (Continued)

**Lab Sample ID: 380-206403-C-1-C MSD**  
**Matrix: Water**  
**Analysis Batch: 218823**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total Recoverable**  
**Prep Batch: 218250**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Mercury	<0.20		1.00	0.936		ug/L		94	70 - 130	1	20

## Method: SM 2320B - Alkalinity

**Lab Sample ID: MB 380-218544/1**  
**Matrix: Water**  
**Analysis Batch: 218544**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Alkalinity	<2.0		2.0	mg/L			04/07/26 14:30	1
Bicarbonate Alkalinity as CaCO3	<2.0		2.0	mg/L			04/07/26 14:30	1
Carbonate Alkalinity as CaCO3	<2.0		2.0	mg/L			04/07/26 14:30	1

**Lab Sample ID: LCS 380-218544/3**  
**Matrix: Water**  
**Analysis Batch: 218544**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Alkalinity	100	97.0		mg/L		97	90 - 110

**Lab Sample ID: LCSD 380-218544/18**  
**Matrix: Water**  
**Analysis Batch: 218544**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Alkalinity	100	99.4		mg/L		99	90 - 110	2	20

**Lab Sample ID: LLCS 380-218544/4**  
**Matrix: Water**  
**Analysis Batch: 218544**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Alkalinity	20.0	19.7		mg/L		98	90 - 110

**Lab Sample ID: MRL 380-218544/2**  
**Matrix: Water**  
**Analysis Batch: 218544**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Alkalinity	2.00	1.67	J	mg/L		84	50 - 150

**Lab Sample ID: 380-205941-E-1 MS**  
**Matrix: Water**  
**Analysis Batch: 218544**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Alkalinity	33		100	127		mg/L		94	80 - 120

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: SM 2320B - Alkalinity (Continued)

**Lab Sample ID: 380-205941-E-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 218544**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Alkalinity	33		100	127		mg/L		94	80 - 120	0	20

**Lab Sample ID: 380-205941-E-1 DU**  
**Matrix: Water**  
**Analysis Batch: 218544**

**Client Sample ID: Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Alkalinity	33		32.5		mg/L		2	20
Bicarbonate Alkalinity as CaCO3	28		25.2		mg/L		10	20
Carbonate Alkalinity as CaCO3	5.2		7.38	F3	mg/L		34	20

## Method: SM 2510B - Conductivity, Specific Conductance

**Lab Sample ID: MB 380-218547/3**  
**Matrix: Water**  
**Analysis Batch: 218547**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Specific Conductance	<2.0		2.0	umhos/cm			04/07/26 14:30	1

**Lab Sample ID: LCS 380-218547/5**  
**Matrix: Water**  
**Analysis Batch: 218547**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Specific Conductance	1000	1010		umhos/cm		101	90 - 110

**Lab Sample ID: LCSD 380-218547/17**  
**Matrix: Water**  
**Analysis Batch: 218547**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Specific Conductance	1000	997		umhos/cm		100	90 - 110	1	10

**Lab Sample ID: MRL 380-218547/4**  
**Matrix: Water**  
**Analysis Batch: 218547**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Specific Conductance	2.00	2.00		umhos/cm		100	50 - 150

**Lab Sample ID: 380-205941-E-1 DU**  
**Matrix: Water**  
**Analysis Batch: 218547**

**Client Sample ID: Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Specific Conductance	110		108		umhos/cm		0.4	20

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: SM 2540C - Solids, Total Dissolved (TDS)

**Lab Sample ID: MB 380-218134/1**  
**Matrix: Water**  
**Analysis Batch: 218134**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids	<10		10	mg/L			04/06/26 15:45	1

**Lab Sample ID: HLCS 380-218134/4**  
**Matrix: Water**  
**Analysis Batch: 218134**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	HLCS Result	HLCS Qualifier	Unit	D	%Rec	%Rec Limits
Total Dissolved Solids	700	720		mg/L		103	80 - 114

**Lab Sample ID: LCS 380-218134/3**  
**Matrix: Water**  
**Analysis Batch: 218134**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Total Dissolved Solids	175	186		mg/L		106	80 - 114

**Lab Sample ID: MRL 380-218134/2**  
**Matrix: Water**  
**Analysis Batch: 218134**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Total Dissolved Solids	10.0	11.0		mg/L		110	50 - 150

**Lab Sample ID: 380-206198-I-1 DU**  
**Matrix: Water**  
**Analysis Batch: 218134**

**Client Sample ID: Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Total Dissolved Solids	160		164		mg/L		0	10

## Method: SM 4500 F C - Fluoride

**Lab Sample ID: MB 380-218802/6**  
**Matrix: Water**  
**Analysis Batch: 218802**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Fluoride	<0.050		0.050	mg/L			04/08/26 11:47	1

**Lab Sample ID: LCS 380-218802/8**  
**Matrix: Water**  
**Analysis Batch: 218802**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Fluoride	1.00	1.05		mg/L		105	90 - 110

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: SM 4500 F C - Fluoride (Continued)

**Lab Sample ID: LCSD 380-218802/9**  
**Matrix: Water**  
**Analysis Batch: 218802**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Fluoride	1.00	1.04		mg/L		104	90 - 110	0	10

**Lab Sample ID: MRL 380-218802/7**  
**Matrix: Water**  
**Analysis Batch: 218802**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Fluoride	0.0500	0.0538		mg/L		108	50 - 150		

**Lab Sample ID: 380-206043-A-10 MS**  
**Matrix: Water**  
**Analysis Batch: 218802**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Fluoride	<0.050		1.00	1.08		mg/L		104	80 - 120		

**Lab Sample ID: 380-206043-A-10 MSD**  
**Matrix: Water**  
**Analysis Batch: 218802**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Fluoride	<0.050		1.00	1.08		mg/L		105	80 - 120	0	20

## Method: SM 4500 H+ B - pH

**Lab Sample ID: MB 380-218549/5**  
**Matrix: Water**  
**Analysis Batch: 218549**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
pH	5.8			SU			04/07/26 14:30	1

**Lab Sample ID: LCS 380-218549/6**  
**Matrix: Water**  
**Analysis Batch: 218549**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
pH	6.00	6.0		SU		100	98 - 102		

**Lab Sample ID: LCSD 380-218549/18**  
**Matrix: Water**  
**Analysis Batch: 218549**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
pH	6.00	6.0		SU		100	98 - 102	0	2

# QC Sample Results

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Method: SM 4500 H+ B - pH (Continued)

**Lab Sample ID: 380-205941-E-1 DU**  
**Matrix: Water**  
**Analysis Batch: 218549**

**Client Sample ID: Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
pH	9.1		9.3		SU		2	2

## Method: SM 4500 S2 D - Sulfide, Total

**Lab Sample ID: MB 380-218103/3**  
**Matrix: Water**  
**Analysis Batch: 218103**

**Client Sample ID: Method Blank**  
**Prep Type: Total/NA**

Analyte	MB Result	MB Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Sulfide	<0.050		0.050	mg/L			04/06/26 15:05	1

**Lab Sample ID: LCS 380-218103/5**  
**Matrix: Water**  
**Analysis Batch: 218103**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Sulfide	0.250	0.273		mg/L		109	90 - 110

**Lab Sample ID: LCSD 380-218103/6**  
**Matrix: Water**  
**Analysis Batch: 218103**

**Client Sample ID: Lab Control Sample Dup**  
**Prep Type: Total/NA**

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Sulfide	0.250	0.275		mg/L		110	90 - 110	1	20

**Lab Sample ID: MRL 380-218103/4**  
**Matrix: Water**  
**Analysis Batch: 218103**

**Client Sample ID: Lab Control Sample**  
**Prep Type: Total/NA**

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
Sulfide	0.0500	0.0558		mg/L		112	50 - 150

**Lab Sample ID: 380-206177-J-1 MS**  
**Matrix: Water**  
**Analysis Batch: 218103**

**Client Sample ID: Matrix Spike**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Sulfide	<0.050	F1	0.250	<0.050	F1	mg/L		0	80 - 120

**Lab Sample ID: 380-206177-J-1 MSD**  
**Matrix: Water**  
**Analysis Batch: 218103**

**Client Sample ID: Matrix Spike Duplicate**  
**Prep Type: Total/NA**

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Sulfide	<0.050	F1	0.250	<0.050	F1	mg/L		0	80 - 120	NC	20

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## GC/MS VOA

### Analysis Batch: 217892

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	524.2	
380-206187-2	TB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	524.2	
MB 380-217892/8	Method Blank	Total/NA	Water	524.2	
LCS 380-217892/5	Lab Control Sample	Total/NA	Water	524.2	
LCSD 380-217892/6	Lab Control Sample Dup	Total/NA	Water	524.2	
MRL 380-217892/3	Lab Control Sample	Total/NA	Water	524.2	
MRL 380-217892/4	Lab Control Sample	Total/NA	Water	524.2	
380-206028-A-9 MSD	Matrix Spike Duplicate	Total/NA	Water	524.2	
380-206028-B-9 MS	Matrix Spike	Total/NA	Water	524.2	

### Analysis Batch: 218229

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	524.2	

### Analysis Batch: 218267

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-2	TB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	524.2	
MB 380-218267/15	Method Blank	Total/NA	Water	524.2	
LCS 380-218267/11	Lab Control Sample	Total/NA	Water	524.2	
LCSD 380-218267/12	Lab Control Sample Dup	Total/NA	Water	524.2	
MRL 380-218267/13	Lab Control Sample	Total/NA	Water	524.2	
MRL 380-218267/14	Lab Control Sample	Total/NA	Water	524.2	

### Analysis Batch: 218352

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	524.2	
MB 380-218352/5	Method Blank	Total/NA	Water	524.2	
LCS 380-218352/3	Lab Control Sample	Total/NA	Water	524.2	
LCSD 380-218352/4	Lab Control Sample Dup	Total/NA	Water	524.2	

## GC/MS Semi VOA

### Prep Batch: 218277

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	525.2	
MB 380-218277/21-A	Method Blank	Total/NA	Water	525.2	
LCS 380-218277/23-A	Lab Control Sample	Total/NA	Water	525.2	
LCSD 380-218277/24-A	Lab Control Sample Dup	Total/NA	Water	525.2	
MRL 380-218277/22-A	Lab Control Sample	Total/NA	Water	525.2	
380-206177-S-1-A MS	Matrix Spike	Total/NA	Water	525.2	
380-204992-S-1-A DU	Duplicate	Total/NA	Water	525.2	

### Analysis Batch: 218602

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	525.2	218277
MB 380-218277/21-A	Method Blank	Total/NA	Water	525.2	218277
LCS 380-218277/23-A	Lab Control Sample	Total/NA	Water	525.2	218277
LCSD 380-218277/24-A	Lab Control Sample Dup	Total/NA	Water	525.2	218277
MRL 380-218277/22-A	Lab Control Sample	Total/NA	Water	525.2	218277
380-206177-S-1-A MS	Matrix Spike	Total/NA	Water	525.2	218277
380-204992-S-1-A DU	Duplicate	Total/NA	Water	525.2	218277

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## GC/MS Semi VOA

### Prep Batch: 719700

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	625.1	
MB 570-719700/1-A	Method Blank	Total/NA	Water	625.1	
LCS 570-719700/2-A	Lab Control Sample	Total/NA	Water	625.1	
LCSD 570-719700/3-A	Lab Control Sample Dup	Total/NA	Water	625.1	
380-205929-A-1-A MS	Matrix Spike	Total/NA	Water	625.1	
380-205929-B-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	625.1	

### Analysis Batch: 722093

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	625.1 SIM	719700
MB 570-719700/1-A	Method Blank	Total/NA	Water	625.1 SIM	719700
LCS 570-719700/2-A	Lab Control Sample	Total/NA	Water	625.1 SIM	719700
LCSD 570-719700/3-A	Lab Control Sample Dup	Total/NA	Water	625.1 SIM	719700
380-205929-A-1-A MS	Matrix Spike	Total/NA	Water	625.1 SIM	719700
380-205929-B-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	625.1 SIM	719700

### Analysis Batch: 724152

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	625.1	719700
MB 570-719700/1-A	Method Blank	Total/NA	Water	625.1	719700

## GC VOA

### Analysis Batch: 724791

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	8015B GRO LL	
380-206187-2	TB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	8015B GRO LL	
MB 570-724791/6	Method Blank	Total/NA	Water	8015B GRO LL	
LCS 570-724791/3	Lab Control Sample	Total/NA	Water	8015B GRO LL	
LCSD 570-724791/4	Lab Control Sample Dup	Total/NA	Water	8015B GRO LL	
MRL 570-724791/5	Lab Control Sample	Total/NA	Water	8015B GRO LL	
380-206949-C-1 MS	Matrix Spike	Total/NA	Water	8015B GRO LL	
380-206949-C-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B GRO LL	

## GC Semi VOA

### Prep Batch: 218087

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	505	
MB 380-218087/3-A	Method Blank	Total/NA	Water	505	
LCS 380-218087/28-A	Lab Control Sample	Total/NA	Water	505	
LCS 380-218087/29-A	Lab Control Sample	Total/NA	Water	505	
LCS 380-218087/31-A	Lab Control Sample	Total/NA	Water	505	
LCSD 380-218087/30-A	Lab Control Sample Dup	Total/NA	Water	505	
MRL 380-218087/1-A	Lab Control Sample	Total/NA	Water	505	
MRL 380-218087/2-A	Lab Control Sample	Total/NA	Water	505	
380-206150-I-1-A MS	Matrix Spike	Total/NA	Water	505	
380-206150-J-1-A MS	Matrix Spike	Total/NA	Water	505	

### Analysis Batch: 218244

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	505	218087

Eurofins Pomona

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## GC Semi VOA (Continued)

### Analysis Batch: 218244 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 380-218087/3-A	Method Blank	Total/NA	Water	505	218087
LCS 380-218087/28-A	Lab Control Sample	Total/NA	Water	505	218087
LCS 380-218087/29-A	Lab Control Sample	Total/NA	Water	505	218087
LCS 380-218087/31-A	Lab Control Sample	Total/NA	Water	505	218087
LCSD 380-218087/30-A	Lab Control Sample Dup	Total/NA	Water	505	218087
MRL 380-218087/1-A	Lab Control Sample	Total/NA	Water	505	218087
MRL 380-218087/2-A	Lab Control Sample	Total/NA	Water	505	218087
380-206150-I-1-A MS	Matrix Spike	Total/NA	Water	505	218087
380-206150-J-1-A MS	Matrix Spike	Total/NA	Water	505	218087

### Prep Batch: 218306

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	504.1	
380-206187-2	TB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	504.1	
MBL 380-218306/4-A	Method Blank	Total/NA	Water	504.1	
LCS 380-218306/29-A	Lab Control Sample	Total/NA	Water	504.1	
MRL 380-218306/2-A	Lab Control Sample	Total/NA	Water	504.1	
MRL 380-218306/3-A	Lab Control Sample	Total/NA	Water	504.1	
380-206204-BV-1-A MS	Matrix Spike	Total/NA	Water	504.1	
380-206332-BQ-1-A DU	Duplicate	Total/NA	Water	504.1	

### Analysis Batch: 218526

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	504.1	218306
380-206187-2	TB: MOANALUA WELLS (331-223-TP202)	Total/NA	Water	504.1	218306
MBL 380-218306/4-A	Method Blank	Total/NA	Water	504.1	218306
LCS 380-218306/29-A	Lab Control Sample	Total/NA	Water	504.1	218306
MRL 380-218306/2-A	Lab Control Sample	Total/NA	Water	504.1	218306
MRL 380-218306/3-A	Lab Control Sample	Total/NA	Water	504.1	218306
380-206204-BV-1-A MS	Matrix Spike	Total/NA	Water	504.1	218306
380-206332-BQ-1-A DU	Duplicate	Total/NA	Water	504.1	218306

### Prep Batch: 720612

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	3510C	
MB 570-720612/1-A	Method Blank	Total/NA	Water	3510C	
LCS 570-720612/2-A	Lab Control Sample	Total/NA	Water	3510C	
LCSD 570-720612/3-A	Lab Control Sample Dup	Total/NA	Water	3510C	
MRL 570-720612/4-A	Lab Control Sample	Total/NA	Water	3510C	

### Analysis Batch: 720996

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	8015B	720612
MB 570-720612/1-A	Method Blank	Total/NA	Water	8015B	720612
LCS 570-720612/2-A	Lab Control Sample	Total/NA	Water	8015B	720612
LCSD 570-720612/3-A	Lab Control Sample Dup	Total/NA	Water	8015B	720612
MRL 570-720612/4-A	Lab Control Sample	Total/NA	Water	8015B	720612

### Analysis Batch: 723893

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	8015B	

Eurofins Pomona

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## GC Semi VOA (Continued)

### Analysis Batch: 723893 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 570-723893/3	Method Blank	Total/NA	Water	8015B	
LCS 570-723893/4	Lab Control Sample	Total/NA	Water	8015B	
LCSD 570-723893/5	Lab Control Sample Dup	Total/NA	Water	8015B	
MRL 570-723893/6	Lab Control Sample	Total/NA	Water	8015B	
380-207013-AB-1 MS	Matrix Spike	Total/NA	Water	8015B	
380-207013-AB-1 MSD	Matrix Spike Duplicate	Total/NA	Water	8015B	

## HPLC/IC

### Analysis Batch: 217761

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	300.0	
MB 380-217761/38	Method Blank	Total/NA	Water	300.0	
LCS 380-217761/40	Lab Control Sample	Total/NA	Water	300.0	
LCSD 380-217761/41	Lab Control Sample Dup	Total/NA	Water	300.0	
MRL 380-217761/39	Lab Control Sample	Total/NA	Water	300.0	
380-206184-K-1 MS	Matrix Spike	Total/NA	Water	300.0	
380-206184-K-1 MSD	Matrix Spike Duplicate	Total/NA	Water	300.0	

### Analysis Batch: 217762

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	300.0	
MB 380-217762/38	Method Blank	Total/NA	Water	300.0	
LCS 380-217762/40	Lab Control Sample	Total/NA	Water	300.0	
LCSD 380-217762/41	Lab Control Sample Dup	Total/NA	Water	300.0	
MRL 380-217762/39	Lab Control Sample	Total/NA	Water	300.0	
380-206184-K-1 MS	Matrix Spike	Total/NA	Water	300.0	
380-206184-K-1 MSD	Matrix Spike Duplicate	Total/NA	Water	300.0	

### Analysis Batch: 218702

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	300.0	
MB 380-218702/6	Method Blank	Total/NA	Water	300.0	
LCS 380-218702/7	Lab Control Sample	Total/NA	Water	300.0	
LCSD 380-218702/8	Lab Control Sample Dup	Total/NA	Water	300.0	
MRL 380-218702/5	Lab Control Sample	Total/NA	Water	300.0	
380-206332-BI-1 MS	Matrix Spike	Total/NA	Water	300.0	
380-206332-BI-1 MSD	Matrix Spike Duplicate	Total/NA	Water	300.0	

## Metals

### Analysis Batch: 217861

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	200.8	
MBL 380-217861/75	Method Blank	Total/NA	Water	200.8	
LCS 380-217861/77	Lab Control Sample	Total/NA	Water	200.8	
LCSD 380-217861/78	Lab Control Sample Dup	Total/NA	Water	200.8	
LLCS 380-217861/76	Lab Control Sample	Total/NA	Water	200.8	
380-206165-A-1 MS	Matrix Spike	Total/NA	Water	200.8	
380-206165-A-1 MSD	Matrix Spike Duplicate	Total/NA	Water	200.8	

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Metals

### Analysis Batch: 218116

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	200.7 Rev 4.4	
MBL 380-218116/50	Method Blank	Total/NA	Water	200.7 Rev 4.4	
LCS 380-218116/52	Lab Control Sample	Total/NA	Water	200.7 Rev 4.4	
LCSD 380-218116/53	Lab Control Sample Dup	Total/NA	Water	200.7 Rev 4.4	
LLCS 380-218116/51	Lab Control Sample	Total/NA	Water	200.7 Rev 4.4	
380-206177-H-1 MS	Matrix Spike	Total/NA	Water	200.7 Rev 4.4	
380-206177-H-1 MSD	Matrix Spike Duplicate	Total/NA	Water	200.7 Rev 4.4	

### Prep Batch: 218250

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total Recoverable	Drinking Water	200.8	
MBL 380-218250/1-A	Method Blank	Total Recoverable	Water	200.8	
LCS 380-218250/3-A	Lab Control Sample	Total Recoverable	Water	200.8	
LCSD 380-218250/4-A	Lab Control Sample Dup	Total Recoverable	Water	200.8	
LLCS 380-218250/2-A	Lab Control Sample	Total Recoverable	Water	200.8	
380-206403-C-1-B MS	Matrix Spike	Total Recoverable	Water	200.8	
380-206403-C-1-C MSD	Matrix Spike Duplicate	Total Recoverable	Water	200.8	

### Analysis Batch: 218823

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total Recoverable	Drinking Water	200.8	218250
MBL 380-218250/1-A	Method Blank	Total Recoverable	Water	200.8	218250
LCS 380-218250/3-A	Lab Control Sample	Total Recoverable	Water	200.8	218250
LCSD 380-218250/4-A	Lab Control Sample Dup	Total Recoverable	Water	200.8	218250
LLCS 380-218250/2-A	Lab Control Sample	Total Recoverable	Water	200.8	218250
380-206403-C-1-B MS	Matrix Spike	Total Recoverable	Water	200.8	218250
380-206403-C-1-C MSD	Matrix Spike Duplicate	Total Recoverable	Water	200.8	218250

## General Chemistry

### Analysis Batch: 218103

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	SM 4500 S2 D	
MB 380-218103/3	Method Blank	Total/NA	Water	SM 4500 S2 D	
LCS 380-218103/5	Lab Control Sample	Total/NA	Water	SM 4500 S2 D	
LCSD 380-218103/6	Lab Control Sample Dup	Total/NA	Water	SM 4500 S2 D	
MRL 380-218103/4	Lab Control Sample	Total/NA	Water	SM 4500 S2 D	
380-206177-J-1 MS	Matrix Spike	Total/NA	Water	SM 4500 S2 D	
380-206177-J-1 MSD	Matrix Spike Duplicate	Total/NA	Water	SM 4500 S2 D	

### Analysis Batch: 218134

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	SM 2540C	
MB 380-218134/1	Method Blank	Total/NA	Water	SM 2540C	
HLCS 380-218134/4	Lab Control Sample	Total/NA	Water	SM 2540C	
LCS 380-218134/3	Lab Control Sample	Total/NA	Water	SM 2540C	
MRL 380-218134/2	Lab Control Sample	Total/NA	Water	SM 2540C	
380-206198-I-1 DU	Duplicate	Total/NA	Water	SM 2540C	

# QC Association Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## General Chemistry

### Analysis Batch: 218544

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	SM 2320B	
MB 380-218544/1	Method Blank	Total/NA	Water	SM 2320B	
LCS 380-218544/3	Lab Control Sample	Total/NA	Water	SM 2320B	
LCSD 380-218544/18	Lab Control Sample Dup	Total/NA	Water	SM 2320B	
LLCS 380-218544/4	Lab Control Sample	Total/NA	Water	SM 2320B	
MRL 380-218544/2	Lab Control Sample	Total/NA	Water	SM 2320B	
380-205941-E-1 MS	Matrix Spike	Total/NA	Water	SM 2320B	
380-205941-E-1 MSD	Matrix Spike Duplicate	Total/NA	Water	SM 2320B	
380-205941-E-1 DU	Duplicate	Total/NA	Water	SM 2320B	

### Analysis Batch: 218547

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	SM 2510B	
MB 380-218547/3	Method Blank	Total/NA	Water	SM 2510B	
LCS 380-218547/5	Lab Control Sample	Total/NA	Water	SM 2510B	
LCSD 380-218547/17	Lab Control Sample Dup	Total/NA	Water	SM 2510B	
MRL 380-218547/4	Lab Control Sample	Total/NA	Water	SM 2510B	
380-205941-E-1 DU	Duplicate	Total/NA	Water	SM 2510B	

### Analysis Batch: 218549

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	SM 4500 H+ B	
MB 380-218549/5	Method Blank	Total/NA	Water	SM 4500 H+ B	
LCS 380-218549/6	Lab Control Sample	Total/NA	Water	SM 4500 H+ B	
LCSD 380-218549/18	Lab Control Sample Dup	Total/NA	Water	SM 4500 H+ B	
380-205941-E-1 DU	Duplicate	Total/NA	Water	SM 4500 H+ B	

### Analysis Batch: 218802

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-206187-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	SM 4500 F C	
MB 380-218802/6	Method Blank	Total/NA	Water	SM 4500 F C	
LCS 380-218802/8	Lab Control Sample	Total/NA	Water	SM 4500 F C	
LCSD 380-218802/9	Lab Control Sample Dup	Total/NA	Water	SM 4500 F C	
MRL 380-218802/7	Lab Control Sample	Total/NA	Water	SM 4500 F C	
380-206043-A-10 MS	Matrix Spike	Total/NA	Water	SM 4500 F C	
380-206043-A-10 MSD	Matrix Spike Duplicate	Total/NA	Water	SM 4500 F C	

# Lab Chronicle

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Client Sample ID: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-1**

**Date Collected: 04/02/26 09:51**

**Matrix: Drinking Water**

**Date Received: 04/03/26 10:22**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	218229	C4WQ	EA POM	04/05/26 18:23
Total/NA	Analysis	524.2		1	217892	Q6AD	EA POM	04/05/26 18:23
Total/NA	Analysis	524.2		1	218352	YNB8	EA POM	04/08/26 00:25
Total/NA	Prep	525.2			218277	KRD3	EA POM	04/07/26 10:44
Total/NA	Analysis	525.2		1	218602	Q8LA	EA POM	04/08/26 22:31
Total/NA	Prep	625.1			719700	BN8X	EET CAL 4	04/04/26 20:59
Total/NA	Analysis	625.1		1	724152	PQS1	EET CAL 4	04/14/26 17:27
Total/NA	Prep	625.1			719700	BN8X	EET CAL 4	04/04/26 20:59
Total/NA	Analysis	625.1 SIM		1	722093	PQS1	EET CAL 4	04/09/26 20:42
Total/NA	Analysis	8015B GRO LL		1	724791	A9VE	EET CAL 4	04/15/26 17:13
Total/NA	Prep	504.1			218306	X5FS	EA POM	04/07/26 15:15 - 04/07/26 16:08 <sup>1</sup>
Total/NA	Analysis	504.1		1	218526	X5FS	EA POM	04/08/26 01:13
Total/NA	Prep	505			218087	DR5R	EA POM	04/06/26 13:03 - 04/06/26 14:38 <sup>1</sup>
Total/NA	Analysis	505		1	218244	DR5R	EA POM	04/06/26 17:36
Total/NA	Prep	3510C			720612	TVD6	EET CAL 4	04/07/26 09:29
Total/NA	Analysis	8015B		1	720996	TR8L	EET CAL 4	04/07/26 23:33
Total/NA	Analysis	8015B		1	723893	UJ3K	EET CAL 4	04/14/26 15:31
Total/NA	Analysis	300.0		2	217761	BG6L	EA POM	04/03/26 22:19
Total/NA	Analysis	300.0		2	217762	BG6L	EA POM	04/03/26 22:19
Total/NA	Analysis	300.0		1	218702	UNJR	EA POM	04/08/26 21:33
Total/NA	Analysis	200.7 Rev 4.4		1	218116	MF7S	EA POM	04/06/26 13:33
Total Recoverable	Prep	200.8			218250	Z45W	EA POM	04/07/26 09:15
Total Recoverable	Analysis	200.8		1	218823	T8BB	EA POM	04/08/26 17:52
Total/NA	Analysis	200.8		1	217861	T8BB	EA POM	04/04/26 13:00
Total/NA	Analysis	SM 2320B		1	218544	PK4Q	EA POM	04/07/26 16:41
Total/NA	Analysis	SM 2510B		1	218547	PK4Q	EA POM	04/07/26 16:41
Total/NA	Analysis	SM 2540C		1	218134	UJRF	EA POM	04/06/26 15:45
Total/NA	Analysis	SM 4500 F C		1	218802	PK4Q	EA POM	04/08/26 13:16
Total/NA	Analysis	SM 4500 H+ B		1	218549	PK4Q	EA POM	04/07/26 16:41
Total/NA	Analysis	SM 4500 S2 D		1	218103	MQP5	EA POM	04/06/26 15:05

**Client Sample ID: TB: MOANALUA WELLS (331-223-TP202)**

**Lab Sample ID: 380-206187-2**

**Date Collected: 04/02/26 09:51**

**Matrix: Water**

**Date Received: 04/03/26 10:22**

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	217892	Q6AD	EA POM	04/05/26 18:45
Total/NA	Analysis	524.2		1	218267	YNB8	EA POM	04/07/26 16:10
Total/NA	Analysis	8015B GRO LL		1	724791	A9VE	EET CAL 4	04/15/26 16:26
Total/NA	Prep	504.1			218306	X5FS	EA POM	04/07/26 15:15 - 04/07/26 16:08 <sup>1</sup>
Total/NA	Analysis	504.1		1	218526	X5FS	EA POM	04/08/26 01:34

<sup>1</sup> This procedure uses a method stipulated length of time for the process. Both start and end times are displayed.

# Lab Chronicle

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

**Laboratory References:**

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Laboratory: Eurofins Pomona

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
505	505	Drinking Water	Polychlorinated biphenyls, Total
524.2		Drinking Water	1,3-Dichloropropene, Total
524.2		Drinking Water	2-Butanone (MEK)
524.2		Drinking Water	Acetone
524.2		Drinking Water	Bromodichloromethane
524.2		Drinking Water	Bromoethane
524.2		Drinking Water	Bromoform
524.2		Drinking Water	Chlorodibromomethane
524.2		Drinking Water	Chloroform (Trichloromethane)
524.2		Drinking Water	m,p Xylenes
524.2		Drinking Water	o-Xylene
524.2		Water	1,3-Dichloropropene, Total
524.2		Water	2-Butanone (MEK)
524.2		Water	Acetone
524.2		Water	Bromodichloromethane
524.2		Water	Bromoethane
524.2		Water	Bromoform
524.2		Water	Chlorodibromomethane
524.2		Water	Chloroform (Trichloromethane)
524.2		Water	m,p-Xylenes
524.2		Water	o-Xylene
525.2	525.2	Drinking Water	1-Methylnaphthalene
525.2	525.2	Drinking Water	2,4'-DDD
525.2	525.2	Drinking Water	2,4'-DDE
525.2	525.2	Drinking Water	2,4'-DDT
525.2	525.2	Drinking Water	2,4-Dinitrotoluene
525.2	525.2	Drinking Water	2,6-Dinitrotoluene
525.2	525.2	Drinking Water	2-Methylnaphthalene
525.2	525.2	Drinking Water	4,4'-DDD
525.2	525.2	Drinking Water	4,4'-DDE
525.2	525.2	Drinking Water	4,4'-DDT
525.2	525.2	Drinking Water	Acetochlor
525.2	525.2	Drinking Water	alpha-BHC
525.2	525.2	Drinking Water	alpha-Chlordane
525.2	525.2	Drinking Water	beta BHC
525.2	525.2	Drinking Water	Chlorobenzilate
525.2	525.2	Drinking Water	Chloroneb
525.2	525.2	Drinking Water	Chlorothalonil (Draconil, Bravo)
525.2	525.2	Drinking Water	Chlorpyrifos
525.2	525.2	Drinking Water	delta-BHC
525.2	525.2	Drinking Water	Diclorvos (DDVP)
525.2	525.2	Drinking Water	Endosulfan I (Alpha)
525.2	525.2	Drinking Water	Endosulfan II (Beta)
525.2	525.2	Drinking Water	Endosulfan sulfate
525.2	525.2	Drinking Water	Endrin aldehyde

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

# Accreditation/Certification Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

## Laboratory: Eurofins Pomona (Continued)

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.			
Analysis Method	Prep Method	Matrix	Analyte
525.2	525.2	Drinking Water	EPTC
525.2	525.2	Drinking Water	gamma-Chlordane
525.2	525.2	Drinking Water	Isophorone
525.2	525.2	Drinking Water	Malathion
525.2	525.2	Drinking Water	Parathion
525.2	525.2	Drinking Water	Pendimethalin (Penoxaline)
525.2	525.2	Drinking Water	Terbacil
525.2	525.2	Drinking Water	Terbutylazine
525.2	525.2	Drinking Water	Total Permethrin (mixed isomers)
525.2	525.2	Drinking Water	trans-Nonachlor
SM 2320B		Drinking Water	Bicarbonate Alkalinity as CaCO3
SM 2320B		Drinking Water	Carbonate Alkalinity as CaCO3
SM 4500 S2 D		Drinking Water	Sulfide

## Laboratory: Eurofins Calscience

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	Dept. of Defense ELAP	7296.01	11-30-26
A2LA	ISO/IEC 17025	7296.01	11-30-26
Alaska (UST)	State	25-005	03-02-27
Arizona	State	AZ0830	11-17-26
California	Los Angeles County Sanitation Districts	9257304	07-31-26
California	SCAQMD LAP	17LA0919	11-30-26
California	State	3082	07-31-26
Kansas	NELAP	E-10420	07-31-26
Nevada	State	CA00111	07-31-26
Oregon	NELAP	4175	02-02-27
USDA	US Federal Programs	525-23-159-97150	06-08-26
Utah	NELAP	CA00111	02-28-27
Washington	State	C916	10-12-26

# Method Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

Method	Method Description	Protocol	Laboratory
524.2	Total Trihalomethanes	EPA-DW	EA POM
524.2	Volatile Organic Compounds (GC/MS)	EPA-DW	EA POM
525.2	Semivolatile Organic Compounds (GC/MS)	EPA	EA POM
625.1	Semivolatile Organic Compounds (GC/MS)	EPA	EET CAL 4
625.1 SIM	Semivolatile Organic Compounds GC/MS (SIM)	EPA	EET CAL 4
8015B GRO LL	Gasoline Range Organics - (GC)	SW846	EET CAL 4
504.1	EDB, DBCP and 1,2,3-TCP (GC)	EPA-DW2	EA POM
505	Organochlorine Pesticides/PCBs (GC)	EPA	EA POM
8015B	Diesel Range Organics (DRO) (GC) Low Level	SW846	EET CAL 4
8015B	Nonhalogenated Organic Compounds - Direct Injection (GC)	SW846	EET CAL 4
300.0	Anions, Ion Chromatography	EPA	EA POM
200.7 Rev 4.4	Metals (ICP)	EPA	EA POM
200.8	Mercury (ICP/MS)	EPA	EA POM
200.8	Metals (ICP/MS)	EPA	EA POM
SM 2320B	Alkalinity	SM	EA POM
SM 2510B	Conductivity, Specific Conductance	SM	EA POM
SM 2540C	Solids, Total Dissolved (TDS)	SM	EA POM
SM 4500 F C	Fluoride	SM	EA POM
SM 4500 H+ B	pH	SM	EA POM
SM 4500 S2 D	Sulfide, Total	SM	EA POM
200.8	Preparation, Total Recoverable Metals	EPA	EA POM
3510C	Liquid-Liquid Extraction (Separatory Funnel)	SW846	EET CAL 4
5030C	Purge and Trap	SW846	EET CAL 4
504.1	Microextraction	EPA-DW	EA POM
505	Extraction, Organohalide Pesticides	EPA	EA POM
525.2	Extraction of Semivolatile Compounds	EPA	EA POM
625.1	Liquid-Liquid Extraction	40CFR136A	EET CAL 4
None	Autocomplete Prep - Metals - No Digestion required	None	EA POM

## Protocol References:

40CFR136A = "Methods for Organic Chemical Analysis of Municipal Industrial Wastewater", 40CFR, Part 136, Appendix A, October 26, 1984 and subsequent revisions.  
 EPA = US Environmental Protection Agency  
 EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.  
 EPA-DW2 = "Methods For The Determination of Organic Compounds in Drinking Water - Supplement III ", EPA/600/R-95-131, August 1995  
 None = None  
 SM = "Standard Methods For The Examination Of Water And Wastewater"  
 SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

## Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100  
 EET CAL 4 = Eurofins Calscience Tustin, 2841 Dow Avenue, Tustin, CA 92780, TEL (714)895-5494

# Sample Summary

Client: City & County of Honolulu  
Project/Site: RED-HILL

Job ID: 380-206187-1  
SDG: Quarterly: Moanalua Wells

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-206187-1	MOANALUA WELLS (331-223-TP202)	Drinking Water	04/02/26 09:51	04/03/26 10:22	HI0000331
380-206187-2	TB: MOANALUA WELLS (331-223-TP202)	Water	04/02/26 09:51	04/03/26 10:22	

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16

Monrovia, CA (Suite 100)  
 750 Royal Oaks Drive Suite 100  
 Monrovia CA 91016  
 Phone (626) 386-1100

### Chain of Custody Record



Enviro  
 Air



Client Information  
 Client Contact: Kirk Iwamoto  
 City & County of Honolulu  
 Address: 630 South Beretama Street, Chemistry Lab  
 City: Honolulu  
 State Zip: HI 96843  
 Phone: 808-748-5040 (tel)  
 Email: kiwamoto@hbws.org  
 Project Name: RED-HILL  
 Site:

Lab PM: Lopez, Maria  
 E-Mail: Maria.Lopez@et.eurofins.com

Carrier Tracking No(s):  
 State of Origin:  
 COC No: 380-206187 COC  
 Page: Page 1 of 2  
 Job #:

Analysis Requested

Due Date Requested:  
 TAT Requested (days):  
 Compliance Project:  No  Yes  
 PO #: C20525101 exp 05312023  
 WO #:  
 Project #: 38001111  
 SSWO#:

Field Filtered Sample (Yes or No)  Yes  No  
 Perform MS/MSD (Yes or No)  Yes  No

Sample Identification	Sample Date	Sample Time	Sample Type (C-comp, G-grab)	Matrix (Newer, Spill, Operational, BT-Release, Auto)	Preservation Code:	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Analysis Requested	Special Instructions/Note
Moanalua Wells (331-223-TP202)	2-Apr-2026	0951	G	Water		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	504 1 PREC, 505 LL PREC 2320B, 2510B, SM4500, H+ 200 7, 200 8 2540C_Calcd Total dissolved Solids (TDS) SM4500_S2_D Sulfide Total 5.24 2 Pres_PREC, 524 2 SIM_PREC 525 2_PREC 526plus PLUS TICs 300_OF_28D_B, 300_OF_28D_PREC, 300_OF_49H_PREC, 4500_F C 245 1 Local Method 8015B_GRO_LL (MOD) GRO 8015B_DRO_LL_CS HNL Ranges C10-C24/C24-C38/C8-C18 8015B_DAL Ethanol 625 1, 625 1 SIM	M Hexane N None O AcNSO2 P - Na2O4S Q - N2SO3 R - Na2SO3 S H2SO4 T TSP Dodecahydrate U Acetone V MCAA W pH 4-5 X Di Water Y - Trizma Z other (specify)
TB Moanalua Wells (331-223-TP202)	2-Apr-2026	0951	G			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		

Possible Hazard Identification  
 Non-Hazard  Flammable  Skin Irritant  Poison B  Unknown  Radiological  
 Deliverable Requested I II III IV Other (specify)

Empty Kit Relinquished by: [Redacted] Date: 02/29/2026  
 Relinquished by: [Redacted] Date/Time: 02/29/2026  
 Company: HBWS  
 Date/Time: 02/29/2026

Method of Shipment: Fed X 6702 7541 4764  
 Date/Time: 4/3/26  
 Company: [Redacted]  
 Date/Time: 10/22  
 Company: [Redacted]


Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)  
 Return To Client  Disposal By Lab  Archive For \_\_\_\_\_ Months

Special Instructions/OC Requirements  
 Cooler Temperature(s) °C and Other Remarks: (33A) 3.5+0.2 = 3.7 gel-traced  
 Date/Time: 4/17/2026  
 Company: [Redacted]



**Monrovia, CA (Suite 100)**  
 750 Royal Oaks Drive Suite 100  
 Monrovia CA 91016  
 Phone (626) 386-1100

# Chain of Custody Record




<b>Client Information</b>		Sampler <b>Bailey</b>	Lab P/N: Lopez, Maria	Carrier Tracking No(s)	COC No
Client Contact: Kirk Iwamoto		Phone: +1 8087485840	E-Mail: Maria.Lopez@et-euronisus.com	State of Origin:	Page: Page 2 of 2
Company: City & County of Honolulu		PWSID:		Job #:	
Address: 630 South Beretania Street, Chemistry Lab		Due Date Requested		Analysis Requested	
City: Honolulu		TAT Requested (days):		Preservation Codes: MI Hexane N - None O - AsNaO2 P - Na2O4S Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Dodecahydrate U Acetone V - MCAA W - pH 4.5 Y - Trizma Z - other (specify)	
State, Zip: HI 96843		Compliance Project: Δ No		Total Number of containers	
Phone: 808-748-5040 (tel)		PO #: C20525101 exp 05312023		5041 PREC Local Method	
Email: kiwamoto@hbws.org		WO #:		Field Filtered Sample (Yes or No)	
Project Name: RED-HILL		Project #: 38001111		Perform MS/MSD (Yes or No)	
Site:		SSOW#:		R	
Sample Identification		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (Water, Seawater, Other)
Moanalua Wells (331-223-TP202)					Water
TB, Moanalua Wells (331-223-TP202)		2-Apr-2026	0951		
Possible Hazard Identification		Poison B	Unknown	Radiological	
Deliverable Requested I II III IV Other (specify)		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)			
Empty Kit Relinquished by		Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For <input type="checkbox"/> Months			
Relinquished by <b>Bailey</b>		Date/Time: 02/01/2026	Date/Time: 10/13/26	Date/Time: 10/22	Date/Time: 10/22
Relinquished by		Company: HBWS			
Relinquished by		Company: Company			
Custody Seals Intact: Δ Yes Δ No		Cooler Temperature(s) °C and Other Remarks: 631A) 3-5-10-2-3-7 90-1-1-2-10-10			



**Monrovia, CA (Suite 100)**

750 Royal Oaks Drive Suite 100  
 Monrovia CA 91016  
 Phone (626) 386-1100



**Chain of Custody Record**

Envil  
 Arne



Client Information  
 Client Contact: Kirk Iwamoto  
 Phone: +1 808-748-5840  
 Lab PII: Lopez, Maria  
 E-Mail: Maria.Lopez@et.euronisus.com  
 Carrier Tracking No(s):  
 State of Origin:  
 COC No: 380-206187 COC  
 Page: Page 1 of 2  
 Job #:

City & County of Honolulu  
 Address: 630 South Beretania Street, Chemistry Lab  
 City: Honolulu  
 State: HI  
 Zip: 96843  
 Phone: 808-748-5040 (tel)  
 Email: kiwamoto@hbws.org  
 Project Name: RED-HILL  
 Site:  
 Compliance Project: Δ No  
 PO #: C20525101 exp 05312023  
 WO #:  
 Project #: 38001111  
 SSO#:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=organics, A=air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Analysis Requested	Special Instructions/Note
Moanalua Wells (331-223-TP202)	2-Apr-2026	0951	G	Water	X	X	504 I.PREC, 506 LL.PREC 2320B, 2510B, SM4500_H+ 2007, 2008 2540C_Calcd Total dissolved Solids (TDS) SM4500_S2_D Sulfide Total 5.24 2.Pres.PREC, 524 2.SIM.PREC 525.2.PREC 525plus PLUS TICs 300_OF_28D_B, 300_OF_28D_OF_49H.PREC, 4500_F_C 2451_Local Method 5015B_GRO_LL (MOD) GRO 5015B_DRO_LL_CS HNL Ranges C10-C24/C24-C36/C8-C18 5015B_DAI Ethanol 525.1, 525.1.SIM Total Number of Containers	
TB Moanalua Wells (331-223-TP202)	2-Apr-2026	0951	G	Water	X	X	504 I.PREC, 506 LL.PREC 2320B, 2510B, SM4500_H+ 2007, 2008 2540C_Calcd Total dissolved Solids (TDS) SM4500_S2_D Sulfide Total 5.24 2.Pres.PREC, 524 2.SIM.PREC 525.2.PREC 525plus PLUS TICs 300_OF_28D_B, 300_OF_28D_OF_49H.PREC, 4500_F_C 2451_Local Method 5015B_GRO_LL (MOD) GRO 5015B_DRO_LL_CS HNL Ranges C10-C24/C24-C36/C8-C18 5015B_DAI Ethanol 525.1, 525.1.SIM Total Number of Containers	

Possible Hazard Identification  
 Non-Hazard  Flammable  Skin Irritant  Poison B  Unknown  Radiological  
 Deliverable Requested I II III IV Other (specify)  
 Empty Kit Relinquished by: [Redacted] Date: 07/29/2026  
 Relinquished by: [Redacted] Date/Time: 07/29/2026  
 Method of Shipment: Fed X 6702 7541 4764  
 Date/Time: 4/3/26  
 Company: HBWS  
 Received by: [Signature] Date/Time: 10/22  
 Company: [Redacted]  
 Received by: [Redacted] Date/Time: [Redacted]  
 Company: [Redacted]  
 Cooler Temperature(s) °C and Other Remarks: (3.5-10.2 = 3.7 gel-frozen)  
 Custody Seal No: Δ Yes Δ No









## Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-206187-1  
SDG Number: Quarterly: Moanalua Wells

**Login Number: 206187**

**List Number: 1**

**Creator: Edrosa, Rey**

**List Source: Eurofins Pomona**

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	



## Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-206187-1  
SDG Number: Quarterly: Moanalua Wells

**Login Number: 206187**  
**List Number: 2**  
**Creator: Yu, Tiffany**

**List Source: Eurofins Calscience**  
**List Creation: 04/04/26 01:46 PM**

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	3.2,1.4
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	False	Received project as a subcontract.
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

